



Entergy Nuclear Northeast  
Entergy Nuclear Operations, Inc.  
James A. Fitzpatrick NPP  
P.O. Box 110  
Lycoming, NY 13093  
Tel 315 342 3840

February 26, 2001  
JAFP-01-0040

United States Nuclear  
Regulatory Commission  
Region 1  
475 Allendale Road  
King of Prussia, PA 19406

ATTENTION: Mr. Hubert Miller  
Regional Administrator

SUBJECT: JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
DOCKET NO. 50-333, LICENSE NO. DPR-59

Gentlemen:

Attached is the Semi-Annual Radioactive Effluent Release Report for the period of July 1, 2000 through December 31, 2000. This report is submitted in accordance with the requirements of Amendment 93, Appendix B, Section 7.3.C of the James A. FitzPatrick Nuclear Power Plant Technical Specifications.

This report includes, as an Addendum, an Assessment of the Radiation Doses to the public due to the radioactive liquid and gaseous effluents released during the 2000 calendar year. The format used for the effluent data is outlined in Appendix B of Regulatory Guide 1.21, Revision 1. Distribution is in accordance with Regulatory Guide 10.1, Revision 4.

This report also includes an Amendment to Table 1 of the Assessment of Radiation Doses to the Public January-December 1998 which was included as an addendum to the Semi-Annual Radioactive Effluent Release Report for the period of July 1, 1998 through December 31, 1998.

If you have any questions concerning the attached report, please contact Al Jarvis, Chemistry Manager, at the James A. FitzPatrick Nuclear Power Plant.

Very truly yours,

MICHAEL J. COLOMB  
GENERAL MANAGER-PLANT OPERATIONS

MJC/AJ/WH/jbh  
Attachments

Xc: Document Control Desk (USNRC)  
D. Sherman (ANI Library)  
J. Knubel (ENOC/WPO)  
C. Faison (ENOC/WPO)  
J. Kelly (ENOC/WPO)

T. Sullivan  
A. Zaremba  
T. Kurtz (NMPC)  
J. Furfaro (ENOC/WPO)  
P. Merges (NYSDEC)

NRC Resident Inspector  
RMS (JAF)

JE 48

**ENTERGY NUCLEAR OPERATIONS, INC.**  
**JAMES A. FITZPATRICK NUCLEAR POWER PLANT**  
**EFFLUENT AND WASTE DISPOSAL**  
**SEMI-ANNUAL REPORT**  
**JULY 1, 2000 - DECEMBER 31, 2000**

**DOCKET NO.: 50-333**

**LICENSE NO.: DPR-59**

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**SUPPLEMENTAL INFORMATION**

FACILITY: JAFNPP

LICENSEE: ENTERGY NUCLEAR OPERATIONS, INC.

**1. Technical Specification Limits**

a. Fission and Activation Gases:

- (1) The dose rate at or beyond the site boundary due to radioactive materials released from the plant in gaseous effluent shall be limited as follows:
  - (a) Less than or equal to 500 mrem/year to the whole body and less than or equal to 3000 mrem/year to the skin from noble gases.
- (2) The air dose to areas at or beyond the site boundary from noble gases released from the plant in gaseous effluent shall be limited:
  - (a) During any calendar quarter, to less than or equal to 5 mrad from gamma radiation, and less than or equal to 10 mrad from beta radiation; and,
  - (b) During any calendar year, to less than or equal to 10 mrad from gamma radiation and less than or equal to 20 mrad from beta radiation.

b. Tritium, Iodines and Particulates, Half Lives > 8 days:

- (1) The dose to a member of the public at or beyond the site boundary from Iodine-131, Iodine-133, Tritium, and radionuclides in particulate form with half-lives greater than 8 days released from the plant in gaseous effluent shall be limited:
  - (a) During any calendar quarter to less than or equal to 7.5 mrem to any organ; and,
  - (b) During any calendar year to less than or equal to 15 mrem to any organ.
  - (c) Less than 0.1% of the limits of Specification 3.4.a.1 and 3.4.a.2 as a result of burning contaminated oil.
- (2) The dose rate at or beyond the site boundary due to radioactive materials released from the plant in gaseous effluents shall be limited as follows:
  - (a) Less than or equal to 1500 mrem/year to any organ from Iodine-131, Iodine-133, Tritium and for radioactive materials in particulate form with half-lives greater than 8 days (inhalation pathway only).

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**SUPPLEMENTAL INFORMATION (Continued)**

c. Liquid Effluents:

- (1) The concentration of radioactive materials released to the unrestricted areas shall not exceed the values specified in 10 CFR 20, Appendix B, Table II, Column 2. For dissolved or entrained noble gases the concentration shall be limited to 2.00E-04  $\mu\text{Ci/ml}$ .
- (2) The dose to a member of the public from radioactive materials released from the plant in liquid effluents to unrestricted areas shall be limited as follows:
  - (a) During any calendar quarter, limited to less than or equal to 1.5 mrem to the whole body and to less than or equal to 5 mrem to any organ; and,
  - (b) During any calendar year, limited to less than or equal to 3 mrem to the whole body and to less than or equal to 10 mrem to any organ.

**2. Maximum Permissible Concentrations**

a. Fission and activation gases:	(None specified)	
b. Iodines:	(None specified)	
c. Particulates, half-lives >8 days:	(None specified)	
d. Liquid effluents:	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Fission and activation products (mixture MPC) ( $\mu\text{Ci/ml}$ )	5.83E-05	6.84E-05
(2) Tritium ( $\mu\text{Ci/ml}$ )	3.00E-03	3.00E-03
(3) Dissolved and entrained gases ( $\mu\text{Ci/ml}$ )	2.00E-04	2.00E-04

ENERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**SUPPLEMENTAL INFORMATION (Continued)**

3. Average Energy (None specified)
4. Measurements and Approximations of Total Radioactivity
- a. Fission and Activation Gases: Continuous monitor on each release path calibrated to a marinelli grab sample analyzed by gamma spectroscopy; bubbler grab sample analyzed for Tritium.
  - b. Iodines: Gamma spectral analysis of charcoal cartridge and particulate filter on each release path.
  - c. Particulates: Gamma spectral analysis of each particulate filter and charcoal cartridge for each release path. A four week per quarter composite of particulate filters for each release path for Strontium-89 and Strontium-90. One week per month particulate filter for each release path for gross alpha.
  - d. Liquid Effluents: Gamma spectral analysis of each batch discharged, except composite analysis for Strontium-89, Strontium-90, Iron-55, Tritium, and Alpha.
  - e. Solid Waste: Gamma spectral analysis of a representative sample of each waste shipment. Scaling factors established from off-site composite sample analyses to estimate concentration of non-gamma emitters. Low activity trash shipments, curie content estimated by dose rate measurement and application of appropriate scaling factors.
  - f. Error Estimation Method: Overall error for sampling and analysis estimated by combining individual errors using error propagation methods. This process is composed of determinate and undeterminate errors.

Determinate - Pump flowrates, volume measurements and analysis collection yields  
Undeterminate - Random counting error estimated using accepted statistical calculations

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**SUPPLEMENTAL INFORMATION (Continued)**

**5. Batch Releases**

a. Liquid:	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Number of batch releases:	2.00E+00	9.00E+00
(2) Total time period for batch release: (min)	1.55E+02	4.76E+02
(3) Maximum time period for batch release: (min)	9.30E+01	6.90E+01
(4) Average time period for batch release: (min)	7.75E+01	5.29E+01
(5) Minimum time period for batch release: (min)	6.20E+01	1.00E+00
b. Gaseous:	NONE	NONE

There were no gaseous batch releases for this report period.

**6. Abnormal Releases**

a. Liquid:	<u>Quarter 3</u>	<u>Quarter 4</u>
(1) Number of releases:	NONE	NONE
(2) Total activity released:	NONE	NONE
b. Gaseous		
(1) Number of releases:	NONE	NONE
(2) Total activity released:	NONE	NONE

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**TABLE 1A  
 GASEOUS EFFLUENTS--SUMMATION OF ALL RELEASES**

	<u>UNIT</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>	<u>EST TOTAL ERROR %</u>
<b>A. FISSION AND ACTIVATION GASES</b>				
1. Total Release	Ci	7.53E+00	1.04E+01	≤2.50E+01
2. Average release rate for period	μCi/sec	9.47E-01	1.31E+00	
3. Tech. Spec. Limit	%	*	*	
<b>B. IODINE-131</b>				
1. Total Iodine-131	Ci	6.75E-05	2.99E-04	≤2.50E+01
2. Average release rate for period	μCi/sec	8.49E-06	3.76E-05	
3. Tech. Spec. Limit	%	*	*	
<b>C. PARTICULATES</b>				
1. Particulates with half-lives >8 days	Ci	8.42E-05	7.36E-05	≤3.60E+01
2. Average release rate for period	μCi/sec	1.06E-05	9.26E-06	
3. Tech. Spec. Limit	%	*	*	
4. Gross alpha radioactivity	Ci	2.09E-07	2.98E-07	≤2.50E+01
<b>D. TRITIUM</b>				
1. Total Release	Ci	5.91E+00	5.92E+00	≤2.50E+01
2. Average release rate for period	μCi/sec	7.43E-01	7.44E-01	
3. Tech. Spec. Limit	%	*	*	
<b>*E. PERCENT OF TECHNICAL SPECIFICATION LIMITS</b>				
<b>FISSION AND ACTIVATION GASES</b>				
1. Quarterly gamma air dose limit	%	4.40E-03	4.98E-03	
2. Quarterly beta air dose limit	%	2.70E-04	3.67E-04	
3. Yearly gamma air dose limit	%	2.20E-03	2.49E-03	
4. Yearly beta air dose limit	%	1.35E-04	1.84E-04	
5. Whole body dose rate limit	%	3.79E-03	4.15E-03	
6. Skin dose rate limit	%	8.18E-04	8.90E-04	
<b>HALOGENS, TRITIUM AND PARTICULATES WITH HALF-LIVES &gt;8 DAYS</b>				
7. Quarterly dose limit (organ)	%	1.15E-02	6.69E-02	
8. Yearly dose limit (organ)	%	5.77E-03	3.35E-02	
9. Organ dose rate limit	%	1.34E-05	1.11E-04	

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**TABLE 1B**  
**GASEOUS EFFLUENTS--ELEVATED RELEASE**

<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>CONTINUOUS MODE</u>	
		<u>QUARTER 3</u>	<u>QUARTER 4</u>
<b>1. <u>Fission Gases</u></b>			
Argon-41	Ci	3.88E+00	2.16E+00
Krypton-85m	Ci	5.41E-01	8.73E-01
Krypton-87	Ci	6.91E-01	1.16E+00
Krypton-88	Ci	5.04E-01	2.97E-01
Xenon-133	Ci	6.10E-02	6.53E-01
Xenon-135	Ci	5.11E-01	1.43E+00
Xenon-135m	Ci	2.82E-01	1.02E+00
Xenon-138	Ci	1.06E+00	2.29E+00
TOTAL	Ci	7.53E+00	1.04E+01
<b>2. <u>Iodines</u></b>			
Iodine-131	Ci	6.67E-05	4.26E-05
Iodine-133	Ci	1.97E-05	1.19E-04
TOTAL	Ci	8.64E-05	1.62E-04
<b>3. <u>Particulates</u></b>			
Manganese-54	Ci	6.27E-07	-----
Cobalt-58	Ci	1.69E-07	-----
Iron-59	Ci	2.59E-07	-----
Cobalt-60	Ci	2.59E-07	-----
Strontium-89	Ci	9.54E-09	1.18E-06
Strontium-90	Ci	-----	-----
TOTAL	Ci	1.32E-06	1.18E-06
<b>4. <u>Tritium</u></b>			
Hydrogen-3	Ci	7.49E-01	8.50E-01

Note: There were no batch releases for this report period.



ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**TABLE 1C**  
**GASEOUS EFFLUENTS--GROUND LEVEL RELEASES**

<u>NUCLIDES RELEASED</u>	<u>UNIT</u>	<u>CONTINUOUS MODE</u>	
		<u>QUARTER 3</u>	<u>QUARTER 4</u>
<b>1. <u>Fission Gases</u></b>			
None	Ci	-----	-----
TOTAL	Ci	-----	-----
<b>2. <u>Iodines</u></b>			
Iodine-131	Ci	7.83E-07	2.56E-04
Iodine-133	Ci	-----	4.59E-04
TOTAL	Ci	7.83E-07	7.15E-04
<b>3. <u>Particulates</u></b>			
Manganse-54	Ci	2.44E-05	3.57E-05
Cobalt-58	Ci	1.61E-06	1.35E-06
Cobalt-60	Ci	2.21E-05	2.79E-05
Zinc-65	Ci	4.71E-06	5.36E-06
Strontium-89	Ci	2.85E-05	2.15E-06
Strontium-90	Ci	1.46E-06	2.20E-08
TOTAL	Ci	8.28E-05	7.25E-05
<b>4. <u>Tritium</u></b>			
Hydrogen-3	Ci	5.16E+00	5.07E+00

Note: There were no batch releases for this report period.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**TABLE 2A**  
**LIQUID EFFLUENTS--SUMMATION OF ALL RELEASES**

	<u>UNIT</u>	<u>QUARTER 3</u>	<u>QUARTER 4</u>	<u>EST TOTAL ERROR %</u>
<b>A. FISSION AND ACTIVATION PRODUCTS</b>				
1. Total Release (not including tritium, gases and alpha)	Ci	4.31E-04	9.43E-04	≤2.50E+01
2. Average diluted concentration during period	μCi/ml	2.07E-09	2.02E-09	
3. Applicable limit	%	-----	-----	
<b>B. TRITIUM</b>				
1. Total Release	Ci	1.06E+00	3.76E+00	≤2.50E+01
2. Average diluted concentration during period	μCi/ml	5.10E-06	8.05E-06	
3. Applicable limit	%	-----	-----	
<b>C. DISSOLVED AND ENTRAINED GASES</b>				
1. Total Release	Ci	-----	-----	≤2.50E+01
2. Average diluted concentration during period	μCi/ml	-----	-----	
3. Applicable Limit	%	-----	-----	
<b>D. GROSS ALPHA RADIOACTIVITY</b>				
1. Total Release	Ci	-----	3.73E-06	≤4.20E+01
<b>E. VOLUME OF WASTE RELEASED (PRIOR TO DILUTION)</b>				
	liters	8.93E+04	3.16E+05	
<b>F. VOLUME OF DILUTION WATER USED DURING PERIOD</b>				
	liters	1.95E+11	1.48E+11	
<b>*G. PERCENT OF TECHNICAL SPECIFICATION LIMITS</b>				
1. Quarterly Whole Body Dose	%	1.07E-04	5.84E-04	
2. Quarterly Organ Dose	%	8.64E-05	2.74E-04	
3. Annual Whole Body Dose	%	5.33E-05	4.57E-04	
4. Annual Organ Dose	%	4.32E-05	1.37E-04	

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**TABLE 2B  
 LIQUID EFFLUENTS**

NUCLIDES RELEASED	UNIT	BATCH MODE	
		QUARTER 3	QUARTER 4
<b>1. Fission and Activation Products</b>			
Chromium-51	Ci	-----	7.30E-05
Manganese-54	Ci	2.22E-04	3.02E-04
Iron-55	Ci	8.67E-05	3.06E-04
Cobalt-58	Ci	2.21E-05	2.10E-05
Iron-59	Ci	7.10E-06	4.01E-05
Cobalt-60	Ci	7.74E-05	1.42E-04
Zinc-65	Ci	-----	4.82E-05
Strontium-90	Ci	2.23E-06	7.90E-06
Zirconium-97	Ci	1.39E-05	-----
Antimony-124	Ci	-----	2.70E-06
TOTAL	Ci	4.31E-04	9.43E-04
<b>2. <u>Tritium</u></b>			
Hydrogen-3	Ci	1.06E+00	3.76E+00
TOTAL	Ci	1.06E+00	3.76E+00
<b>3. <u>Dissolved and Entrained Gases</u></b>			
NONE	Ci	-----	
TOTAL	Ci	-----	-----

Note: There were no continuous mode discharges during this report period.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**TABLE 3A**  
**SOLID WASTE AND IRRADIATED FUEL SHIPMENTS**

SOLID WASTE SHIPPED OFFSITE FOR DURIAL OR DISPOSAL (NOT IRRADIATED FUEL)						
1.	Type of Waste	Unit	6-month Period			Est. Total Error %
			Class A	Class B	Class C	
a.	Spent resins, filter sludge, evaporator bottoms, etc.	m <sup>3</sup>	0.00E+00	0.00E+00	0.00E+00	1.00E+01
		Ci	0.00E+00	0.00E+00	0.00E+00	1.00E+01
	b. Dry compressible waste, contaminated equipment, etc.	m <sup>3</sup>	0.00E+00	0.00E+00	0.00E+00	1.00E+01
		Ci	0.00E+00	0.00E+00	0.00E+00	1.00E+01
c.	Irradiated components, control rods, etc.	m <sup>3</sup>	0.00E+00	0.00E+00	0.00E+00	1.00E+01
		Ci	0.00E+00	0.00E+00	0.00E+00	1.00E+01
d.	Other: Dry compressible waste, contaminated equipment, spent resins for volume reduction.	m <sup>3</sup>	3.81E+02	0.00E+00	0.00E+00	1.00E+01
		Ci	7.99E -01	0.00E+00	0.00E+00	1.00E+01

2. Estimate of Major Nuclide Composition (by type of waste)

a. Spent resins, filter sludge, evaporator bottoms, etc.

NONE

b. Dry compressible waste, contaminated equipment, etc.

NONE

c. Irradiated components, control rods, etc.

NONE

d. Other: Dry compressible waste, contaminated equipment, spent resins for volume reduction.

<u>Isotope</u>	<u>Percent</u>	<u>Curies</u>		<u>Isotope</u>	<u>Percent</u>	<u>Curies</u>	
Iron-55	6.79E+01	5.43E -01	E	Carbon-14	2.33E+00	1.87E-02	E
Cobalt-60	1.39E+01	1.11E -01	E	Cesium-137	1.33E+00	1.07E-02	E
Manganese-54	9.54E+00	7.62E -02	E	Nickel-63	8.32E -01	6.65E-03	E
Zinc-65	4.13E+00	3.30E -02	E	Strontium-90	7.42E -03	5.93E-05	E

(E- Estimated M- Measured)

Percentage of nuclides and total activities are based on a combination of direct measurements and scaling for non-gamma emitting nuclides.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**TABLE 3A (continued)**  
**SOLID WASTE AND IRRADIATED FUEL SHIPMENTS**

3. Solid Waste Disposition

<u>No. of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
2	Truck	*Diversified Scientific Services, Inc. Kingston, TN
7	Truck	*GTS Duratek/S.E.G. Oak Ridge, TN
*	Volume Reduction Facility	

B. IRRADIATED FUEL SHIPMENTS (Disposition)

<u>No. of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
NONE	-----	-----

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**TABLE 3B  
 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS**

A. NRC CLASS A

<u>SOURCE OF WASTE</u>	<u>PROCESSING EMPLOYED</u>	<u>CONTAINER VOLUME</u>	<u>TYPE OF CONTAINER</u>	<u>NUMBER OF CONTAINERS</u>
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	1280 ft <sup>3</sup>	STC	9
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	92 ft <sup>3</sup>	STC	18
Dry compressible Waste (DAW), Contaminated Equipment, etc.	Non-compacted	7.5 ft <sup>3</sup>	STC	27

B. NRC CLASS B

<u>SOURCE OF WASTE</u>	<u>PROCESSING EMPLOYED</u>	<u>CONTAINER VOLUME</u>	<u>TYPE OF CONTAINER</u>	<u>NUMBER OF CONTAINERS</u>
NONE				

C. NRC CLASS C

<u>SOURCE OF WASTE</u>	<u>PROCESSING EMPLOYED</u>	<u>CONTAINER VOLUME</u>	<u>TYPE OF CONTAINER</u>	<u>NUMBER OF CONTAINERS</u>
NONE				
Solidification Agent:	NONE			

HIC- High Integrity Container  
 STC- Strong Tight Container

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ATTACHMENT NO. 1**

**CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL (ODCM)**

In accordance with Section 7.3.C.3 of Amendment 93 to the James A. FitzPatrick Nuclear Power Plant Technical Specifications, changes made to the Offsite Dose Calculation Manual (ODCM) during the reporting period shall be included in the Semi-Annual Radioactive Effluent Release Report.

There were no changes to the Offsite Dose Calculation Manual (ODCM).

ENERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ATTACHMENT NO. 2**

**SUMMARY OF CHANGES TO THE PROCESS CONTROL PROGRAM**

In accordance with Section 7.3.C.3 of Amendment 93 to the James A. FitzPatrick Nuclear Power Plant Technical Specifications, changes made to the Process Control Program (PCP) during the reporting period shall be included in the Semi-Annual Radioactive Effluent Release Report.

There were no changes to the Process Control Program Procedure or implementing procedures.



ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ATTACHMENT NO. 3**

**SUMMARY OF CHANGES TO THE ENVIRONMENTAL MONITORING AND  
DOSE CALCULATION LOCATIONS**

In accordance with Section 7.3.C.3 of Amendment 93 to the James A. FitzPatrick Nuclear Power Plant Technical Specifications, a listing of new locations for dose calculation and/or environmental monitoring identified by the land use census shall be included in the Semi-Annual Radioactive Effluent Release Report.

CHANGES IN ENVIRONMENTAL MONITORING LOCATIONS

During the report period, no changes in the Environmental Monitoring Locations sampled to implement the requirements of Technical Specifications were made. Sample location selections are based on the annual land use census.

NEW LOCATIONS FOR DOSE CALCULATIONS

During the report period, no changes in Dose Calculation Receptor Locations were required based on the results of the land use census.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ATTACHMENT NO. 4**

**DEVIATIONS FROM THE REQUIRED  
ENVIRONMENTAL SAMPLING SCHEDULE**

In accordance with Section 7.3.C.7 of Amendment 93 to the James A. FitzPatrick Nuclear Power Plant Technical Specifications, the cause for unavailability of any environmental samples required during the report period shall be included in the Semi-Annual Radioactive Effluent Release Report.

EXCEPTIONS TO THE ENVIRONMENTAL SAMPLING PROGRAM

1. The air sampling pumps at the R-1, R-2 and R-5 Environmental Sampling Stations were inoperable for approximately 12 hours on December 18, 2000 (0230 hrs. to 1330 hrs.). The inoperability of the sampling pumps was caused by a power outage, which was the result of a severe winter storm. No corrective action was implemented.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ATTACHMENT NO. 5**

**SEMI-ANNUAL SUMMARY OF HOURLY METEOROLOGICAL DATA**

The James A. FitzPatrick Nuclear Power Plant Radiological Environmental Technical Specification 7.3.c.2 states in part: "The Radioactive Effluent Release Report to be submitted within 60 days after January 1 of each year may include an annual summary of meteorological data collected over the previous year. If the meteorological data is not included, the licensee shall retain it on file and provide it to the U.S. Nuclear Regulatory Commission upon request." In accordance with the aforementioned technical specification, meteorological data is not included in this report. It is retained on file and is available upon request.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ATTACHMENT NO. 6**

**MAJOR MODIFICATIONS TO RADIOACTIVE LIQUID, GASEOUS AND SOLID  
WASTE TREATMENT SYSTEMS**

In accordance with Section 6.18 of Amendment 93 to the James A. FitzPatrick Nuclear Power Plant Technical Specifications, Major Modifications to Radioactive Waste Systems (liquid, gaseous and solid) shall be reported in the Semi-Annual Radioactive Effluent Release Report for the period in which the modification is completed and made operational.

There were no major modifications to liquid, gaseous or solid radioactive waste treatment systems.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ATTACHMENT NO. 7**

**REPORT NOTES**

Table 1A Section D and Table 1B and 1C Section 4

The values for Tritium were calculated from the most recent available sample data. If the actual sample data significantly alters the percent of allowable release limits, the report will be revised and redistributed.

Table 2A Section A and B and Table 2B Normal Liquid Effluents

The values for Tritium, Strontium-89, Strontium-90, and Iron-55 were calculated from the most recent available sample data. If the actual sample data significantly alters the percent of allowable release limits, the report will be revised and redistributed.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ADDENDUM 1**

**ASSESSMENT OF RADIATION DOSES TO THE PUBLIC JANUARY - DECEMBER 2000**

**1. INTRODUCTION**

The James A. FitzPatrick Nuclear Power Plant Radiological Effluent Technical Specifications (RETS) require an assessment of the radiation doses to the public due to radioactive liquid and gaseous effluents. This assessment of doses to the public is based on accepted methodologies found in the Offsite Dose Calculation Manual (ODCM).

**2. DOSE LIMITS**

A. DOSE FROM LIQUID EFFLUENTS (RETS 2.3)

Applicability

Applies to doses from radioactive material in liquid effluents.

Objective

To ensure that the dose limitations of 10 CFR 50, Appendix I, are met.

Specifications

The dose to a member of the public from radioactive materials released from the plant in liquid effluents to unrestricted areas shall be limited as follows:

1. During any calendar quarter, limited to less than or equal to 1.5 mrem to the whole body and to less than or equal to 5 mrem to any organ.
2. During any calendar year, limited to less than or equal to 3 mrem to the whole body and to less than or equal to 10 mrem to any organ.

B. GASEOUS DOSE RATES (RETS 3.2)

Applicability

Applies to the radiation dose from radioactive material in gaseous effluents.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ADDENDUM 1 (continued)**

Objective

To ensure that the dose rates at or beyond the site boundary from gaseous effluents do not exceed the annual dose limits of 10 CFR 20, for unrestricted areas.

Specifications

The dose rate at or beyond the site boundary due to radioactive materials released from the plant in gaseous effluents shall be limited as follows:

1. Less than or equal to 500 mrem/year to the whole body and less than or equal to 3000 mrem/year to the skin from noble gases; and,
2. Less than or equal to 1500 mrem/year to any organ from Iodine-131, Iodine-133, Tritium and for radioactive materials in particulate form with half-lives greater than 8 days (inhalation pathway only).

C. AIR DOSE, NOBLE GASES (RETS 3.3)

Applicability

Applies to the air dose due to noble gases in gaseous effluents.

Objective

To ensure that the noble gas dose limitations of 10 CFR 50, Appendix I, are met.

Specifications

The air dose to areas at or beyond the site boundary from noble gases released from the plant in gaseous effluents shall be limited:

1. During any calendar quarter, to less than or equal to 5 mrad from gamma radiation, and less than or equal to 10 mrad from beta radiation; and,
2. During any calendar year, to less than or equal to 10 mrad from gamma radiation and less than or equal to 20 mrad from beta radiation.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ADDENDUM 1 (continued)**

D. DOSE DUE TO IODINE-131, IODINE-133, TRITIUM AND RADIONUCLIDES IN PARTICULATE FORM (RETS 3.4)

Applicability

Applies to the cumulative dose from Iodine-131, Iodine-133, Tritium, and radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents.

Objective

To ensure that the dose limitations of 10 CFR 50, Appendix I, are met.

Specifications

The dose to a member of the public at or beyond the site boundary from Iodine-131, Iodine-133, Tritium, and radionuclides in particulate form with half-lives greater than 8 days released from the plant in gaseous effluents shall be limited:

1. During any calendar quarter to less than or equal to 7.5 mrem to any organ; and,
2. During any calendar year to less than or equal to 15 mrem to any organ.

E. TOTAL DOSE FROM URANIUM FUEL CYCLE (RETS 5.1)

Applicability

Applies to radiation dose from releases of radioactivity and radiation from uranium fuel cycle sources.

Objective

To ensure that the requirements of 40 CFR 190 are met.



ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ADDENDUM 1 (continued)**

Specifications

The dose or dose commitment to any member of the public, due to releases of radioactivity and radiation, from uranium fuel cycle sources shall be limited as follows:

1. Less than or equal to 25 mrem/year to the whole body; and,
2. Less than or equal to 25 mrem/year to any organ except the thyroid which shall be limited to less than or equal to 75 mrem/year.

**3. DOSE ASSESSMENT**

A. METHODOLOGY

The assessment of radiation doses to the public due to radioactive liquid and gaseous effluents is performed in accordance with the ODCM. The ODCM is based on methodologies and models suggested by the "Guidance Manual For Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants" (NUREG-0133) and "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the purpose of Evaluating Compliance with 10CFR50, Appendix I" (Regulatory Guide 1.109).

B. ASSUMPTIONS

Dose calculations are performed using formulas and constants defined in the ODCM. Specific radioactive release activities used in the dose calculations are listed in the Semi-Annual Radioactive Effluent Release Reports (1.21 Reports) for the period of January 1, 2000 to December 31, 2000. Historical meteorological data was used to generate tables of average dispersion factors. Locations of interest were identified from the 2000 land use census. Dispersion factors and locations of interest used in performing the dose calculations are listed in Table 2.

C. ASSESSMENT RESULTS SUMMARY

The calculated doses to the public due to radioactive effluents are listed in Table 1. The calculated doses are small fractions of their respective dose limits.

ENTERGY NUCLEAR OPERATIONS, INC.  
JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
EFFLUENT AND WASTE DISPOSAL  
SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ADDENDUM 1 (continued)**

**4. 40 CFR 190 DOSE ASSESSMENT**

**A. METHODOLOGY**

Evaluation to demonstrate compliance with the 40 CFR 190 dose limits must be performed when the doses calculated for 10 CFR 50 compliance exceed twice their respective limits. When additional dose assessment is required to demonstrate compliance with 40 CFR 190 it is performed in accordance with the ODCM.

**B. RESULTS SUMMARY**

The cumulative dose contribution from liquid and gaseous effluents for this report period were calculated and are listed in Table 1. The cumulative dose contribution from direct radiation from the reactor unit and from radwaste storage tanks is measured by environmental thermoluminescent dosimeters for the report period. This data is contained in the Annual Environmental Operating Report. The calculated doses from liquid and gaseous effluents are less than twice their respective 10 CFR 50 limits, therefore, additional calculations are not necessary to demonstrate compliance with 40 CFR 190 dose limits (RETS 5.1.b).

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ADDENDUM 1 (continued)**  
**TABLE 1**  
**ANNUAL DOSE ASSESSMENT 2000**

---

A. LIQUIDS					
<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
			(a)	(a)	(a)
Organ (mrem)	NONE	NONE	4.32E-06	1.37E-05	1.62E-05
% of Limit	-----	-----	8.64E-05	2.74E-04	1.62E-04
			(b)	(b)	(b)
Whole Body (mrem)	NONE	NONE	1.60E-06	8.76E-06	9.12E-06
% of Limit	-----	-----	1.07E-04	5.84E-04	3.04E-04

(a) Dose to the Adult Intestinal Tract (GILLI) primarily by the freshwater fish pathway.

(b) Dose to the Child Whole Body primarily by the potable water pathway.

---

B. NOBLE GASES					
<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
Total Body (mrem/yr)	3.61E-03	1.12E-01	1.90E-02	2.08E-02	1.12E-01
% of Limit	7.22E-04	2.25E-02	3.79E-03	4.15E-03	2.25E-02
Skin (mrem/yr)	4.40E-03	1.45E-01	2.45E-02	2.67E-02	1.45E-01
% of Limit	1.47E-04	4.83E-03	8.18E-04	8.90E-04	4.83E-03
Gamma (mrad)	3.31E-04	1.53E-03	2.20E-04	2.49E-04	2.33E-03
% of Limit	6.62E-03	3.06E-02	4.40E-03	4.98E-03	2.33E-02
Beta (mrad)	3.02E-05	2.25E-04	2.70E-05	3.67E-05	3.19E-04
% of Limit	3.02E-04	2.25E-03	2.70E-04	3.67E-04	1.60E-03

---

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ADDENDUM 1 (continued)**

**TABLE 1  
 ANNUAL DOSE ASSESSMENT 2000**

---

C. IODINES AND PARTICULATES

<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
	(a)	(b)	(b)	(c)	(b)
Organ (mrem)	3.18E-04	1.68E-03	8.65E-04	5.02E-03	7.74E-03
% of Limit	4.24E-03	2.24E-02	1.15E-02	6.69E-02	5.16E-02
Organ Dose Rate (mrem/yr)	1.95E-04	4.57E-04	2.02E-04	1.67E-03	1.67E-03
% of Limit	1.30E-05	3.04E-05	1.34E-05	1.11E-04	1.11E-04

---

- (a) Dose to the Child Thyroid primarily by the vegetation pathway.  
 (b) Dose to the Infant Thyroid primarily by the goats milk pathway.  
 (c) Dose to the Infant Thyroid primarily by the cows milk pathway.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ADDENDUM 1 (continued)**

**TABLE 2  
 METEOROLOGICAL DATA AND LOCATIONS OF INTEREST**

RECEPTOR	GEOGRAPHIC LOCATION	ATMOSPHERIC DISPERSION FACTOR		
A. IODINE & PARTICULATES	DISTANCE/ DIRECTION	RELEASE POINT	X/Q (sec/m <sup>3</sup> )	D/Q (l/m <sup>2</sup> )
1. Garden	0.93 mi @ 82°E	ST	2.86E-08*	1.72E-09
Grazing Season	0.93 mi @ 82°E	RX	1.94E-07*	4.76E-09
Cary	0.93 mi @ 82°E	TB	1.76E-07*	4.57E-09
Location No. 78	0.93 mi @ 82°E	RF	1.94E-07*	4.76E-09
	0.93 mi @ 82°E	RW	3.08E-07*	5.45E-09
2. Meat	1.24 mi @ 126°SE	ST	1.70E-08*	6.51E-10
Grazing Season	1.24 mi @ 126°SE	RX	5.17E-08*	1.24E-09
Parkhurst	1.24 mi @ 126°SE	TB	4.97E-08*	1.21E-09
Location No. 26	1.24 mi @ 126°SE	RF	5.17E-08*	1.24E-09
	1.24 mi @ 126°SE	RW	8.74E-08*	1.39E-09
3. Cow	2.2 mi @ 138°SE	ST	1.65E-08*	3.11E-10
Grazing Season	2.2 mi @ 138°SE	RX	3.04E-08*	5.07E-10
France	2.2 mi @ 138°SE	TB	2.98E-08*	4.97E-10
Location No. 10	2.2 mi @ 138°SE	RF	3.04E-08*	5.07E-10
	2.2 mi @ 138°SE	RW	4.66E-08*	5.39E-10
4. Goat	2.5 mi @ 146°SE	ST	1.67E-08*	2.65E-10
Grazing Season	2.5 mi @ 146°SE	RX	2.76E-08*	4.14E-10
Nickolas	2.5 mi @ 146°SE	TB	2.71E-08*	4.07E-10
Location No. 61	2.5 mi @ 146°SE	RF	2.76E-08*	4.14E-10
	2.5 mi @ 146°SE	RW	4.15E-08*	4.36E-10
5. Resident Annual Average				
a. Inhalation	1.55 mi @ 90°E**	ST	2.99E-08	-
	0.93 mi @ 82°E	RX	1.98E-07	-
	0.93 mi @ 82°E	TB	1.81E-07	-
	0.93 mi @ 82°E	RF	1.98E-07	-
	0.93 mi @ 82°E	RW	2.93E-07	-

\*Tritium Dose Calculation Only

\*\*Highest Sector Average X/Q in a populated area.

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**ADDENDUM 1 (continued)**

**TABLE 2  
 METEOROLOGICAL DATA AND LOCATIONS OF INTEREST**

RECEPTOR	GEOGRAPHIC LOCATION	RELEASE POINT	ATMOSPHERIC DISPERSION FACTOR X/Q (sec/m <sup>3</sup> )	D/Q (l/m <sup>2</sup> )
<b>A. IODINE &amp; PARTICULATES</b>				
5 b. Deposition	0.70 mi @ 118 ESE	ST	-	1.61E-09
	0.70 mi @ 118°ESE	RX	-	5.65E-09
	0.70 mi @ 118°ESE	TB	-	5.42E-09
	0.70 mi @ 118°ESE	RF	-	5.65E-09
	0.70 mi @ 118°ESE	RW	-	6.42E-09
<b>B. NOBLE GASES</b>				
1. Air Dose Annual Average	1.55 mi @ 90°E	ST	2.99E-08	-
	0.6 mi @ 90°E	ST(fc)	1.16E-07	-
	0.6 mi @ 90°E	RX	3.58E-07	-
	0.6 mi @ 90°E	TB	3.19E-07	-
	0.6 mi @ 90°E	RF	3.58E-07	-
	0.6 mi @ 90°E	RW	5.39E-07	-
2. Total Body Annual Average	0.6 mi @ 90°E	ST(fc)	1.16E-07	-
	0.6 mi @ 90°E	RX	3.58E-07	-
	0.6 mi @ 90°E	TB	3.19E-07	-
	0.6 mi @ 90°E	RF	3.58E-07	-
	0.6 mi @ 90°E	RW	5.39E-07	-
3. Skin Annual Average	1.55 mi @ 90°E	ST	2.99E-08	-
	0.6 mi @ 90°E	ST(fc)	1.16E-07	-
	0.6 mi @ 90°E	RX	3.58E-07	-
	0.6 mi @ 90°E	TB	3.19E-07	-
	0.6 mi @ 90°E	RF	3.58E-07	-
	0.6 mi @ 90°E	RW	5.39E-07	-

ST = Main Stack  
 RX = Reactor Building  
 TB = Turbine Building Vent  
 RF = Refuel Floor Vent  
 RW = Radwaste Vent  
 fc = Finite Cloud

ENERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**AMENDMENT 1**  
**TABLE 1**  
**ANNUAL DOSE ASSESSMENT 1998**

---

A. LIQUIDS					
<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
				(a)	(a)
Organ (mrem)	NONE	NONE	NONE	2.64E-05	2.64E-05
% of Limit	-----	-----	-----	5.28E-04	2.64E-04
				(b)	(b)
Whole Body (mrem)	NONE	NONE	NONE	2.51E-05	2.51E-05
% of Limit	-----	-----	-----	1.67E-03	8.37E-04

---

(a) Dose to the Child Liver primarily from the potable water pathway  
 (b) Dose to the Child Whole Body primarily from the potable water pathway.

B. NOBLE GASES					
<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
Total Body (mrem/yr)	9.02E-05	8.16E-05	1.93E-04	3.47E-04	3.47E-04
% of Limit	1.80E-05	1.63E-05	3.86E-05	6.95E-05	6.95E-05
Skin (mrem/yr)	1.10E-04	1.02E-04	2.51E-04	4.58E-04	4.58E-04
% of Limit	3.66E-06	3.42E-06	8.36E-06	1.53E-05	1.53E-05
Gamma (mrad)	9.34E-05	8.47E-05	2.00E-04	3.61E-04	7.39E-04
% of Limit	1.87E-03	1.69E-03	4.00E-03	7.22E-03	7.39E-03
Beta (mrad)	8.30E-06	1.08E-05	3.44E-05	6.87E-05	1.22E-04
% of Limit	8.30E-05	1.08E-04	3.44E-04	6.87E-04	6.11E-04

---

ENTERGY NUCLEAR OPERATIONS, INC.  
 JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
 EFFLUENT AND WASTE DISPOSAL  
 SEMI-ANNUAL REPORT JULY 2000-DECEMBER 2000

**AMENDMENT 1**  
**TABLE 1**  
**ANNUAL DOSE ASSESSMENT 1998**

---

C. IODINES AND PARTICULATES

<u>QUARTER</u>	<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>	<u>ANNUAL</u>
	(a)	(a)	(a)	(b)	(b)
Organ (mrem)	1.27E-03	1.75E-03	1.84E-03	1.92E-02	2.26E-02
% of Limit	1.69E-02	2.34E-02	2.46E-02	2.56E-01	1.51E-01
Organ Dose Rate (mrem/yr)	1.79E-03	1.00E-03	7.83E-04	4.95E-03	4.95E-03
% of Limit	1.19E-04	6.70E-05	5.22E-05	3.30E-04	3.30E-04

---

(c) Dose to the Child Thyroid primarily by the vegetation pathway.  
 (d) Dose to the Infant Thyroid primarily by the goats milk pathway.

D. UNMONITORED SHORT-TERM RELEASE  
 QUARTER 4

IODINE AND PARTICULATES

(a)

Organ (mrem)	5.59E-05
% of Limit	7.45E-04

---

(a) Dose to the Infant Liver primarily by the goats milk pathway.