

Monticello Nuclear Generating Plant 2807 West County Road 75 Monticello, MN 55362-9637

Operated by Nuclear Management Company LLC

February 26, 2001

Technical Specification 6.7.A.4

US Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT Docket No. 50-263 License No. DPR-22

Effluent and Waste Disposal Semi-Annual Report for July Through December, 2000

In accordance with Monticello Technical Specification Section 6.7.A.4, we are submitting the following information as attachments:

Attachment A:

Effluent and Waste Disposal Semi-Annual Report for July 1 – December 31,

2000

Attachment B:

Off-Site Radiation Dose Assessment for January 1- December 31, 2000

There were no changes to the Offsite Dose Calculation Manual (ODCM), the Process Control Program (PCP) Manual or the Radiation Environmental Monitoring Program during the reporting period. There were no changes in land use resulting in significant increases in calculated doses. Also, there were no milk and vegetable sampling deviations during this reporting period.

This letter contains no new NRC commitments, nor does it modify any prior commitments. Please contact Sam Shirey at (763) 295-1449 if you require further information.

Byron D. Day

Plant Manager

Monticello Nuclear Generating Plant

c: Regional Administrator - III, NRC NRR Project Manager, NRC Sr. Resident Inspector, NRC Minnesota Department of Commerce J Silberg

IE48

## Attachment A

Effluent and Waste Disposal Semi-Annual Report for July 1 – December 31, 2000

(The attached Report contains 10 pages.)

#### NORTHERN STATES POWER COMPANY MONTICELLO NUCLEAR GENERATING PLANT License No. DPR-22

#### EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT Period: Jul - Dec 2000

#### Supplemental Information

- 1. Regulatory Limits Quarterly levels requiring reporting to Nuclear Regulatory Commission
  - A. Noble Gases:
    - 5 mrad/quarter gamma radiation 10 mrad/quarter beta radiation
  - B. Long Lived Iodines, Particulates, and Tritium:
    - 7.5 mrem/quarter dose to any organ
  - C. Liquid Effluents:
    - 1.5 mrem/quarter dose to the total body
    - 5.0 mrem/quarter dose to any organ
- 2. Maximum Permissible Concentrations
  - A. Noble Gases :
    - 10 CFR Part 20, Appendix B, Table II, Column 1
  - B. Long Lived Iodines, Particulates, and Tritium:
    - 10 CFR Part 20, Appendix B, Table II, Column 1
  - C. Liquid Effluents:
    - 10 CFR Part 20, Appendix B, Table II, Column 2 2.0 E-4 uci/ml for dissolved and entrained gases
- 3. Average Energy

(Not Applicable)

### Supplemental Information (continued)

#### 4. Measurements and Approximations of Total Radioactivity

#### A. Noble Gases:

Continuous gross activity monitors in Reactor Building Vent and Plant Stack exhaust streams. Weekly isotopic analysis of exhaust streams.

#### B. Iodines in Gaseous Effluent :

Continuous monitoring with charcoal cartridges in Reactor Building Vent and Plant Stack exhaust streams with weekly analysis.

#### C. Particulates in Gaseous Effluent :

Continuous monitoring with particulate filters in Reactor Building Vent and Plant Stack exhaust streams with weekly analysis.

#### D. Tritium in Gaseous Effluent :

Weekly grab samples from Reactor Building Vent and Plant Stack exhaust streams.

#### E. Liquid Effluents:

Tank sample analyzed prior to each planned release and continuous monitoring of gross activity during planned release.

#### 5. Batch Releases

#### A. Liquid:

	Number of Batch Releases	0	
2.	Total Time Period for Batch Releases	0.0	min
3.	Maximum Time Period for a Batch Release	0.0	min
4.	Average Time Period for a Batch Release	0.0	min
	Minimum Time Period for a Batch Release	0.0	min
6.	Average River Flow During Release	0.0	cf/sec

#### B. Gaseous:

	Number o							2	
	Total Ti							1397.0	min
	Maximum							982.0	min
4.	Average	Time	Period	for	а	Batch	Release	698.5	min
5.	Minimum	Time	Period	for	а	Batch	Release	415.0	min

## Supplemental Information (continued)

#### 6. Abnormal Releases

Α.	Tiż	.qu	i	d	:
∽.		. ч ч	_	u	•

	1. Number of Releases 2. Total Activity Released	0.0	Ci
В.	Gaseous :		
	<ol> <li>Number of Releases</li> <li>Total Activity Released</li> </ol>	0.0	Ci

## Table 1A Gaseous Effluents - Summation of all Releases

	Units	3rd Qtr	4th Qtr	Est. Total Error, %			
A. Fission & Activation gases				•			
1. Total Release	Ci	4.72E+01	4.98E+01	2.00E+01			
2. Average Release Rate	uci/sec	5.94E+00	6.26E+00				
3. Percent Tech Spec Qtrly							
Reporting Level							
Gamma Radiation	%	2.30E-02	5.37E-02				
Beta Radiation	%	9.21E-03	2.95E-02				
B. Iodines							
1. Total I-131 Release	Ci	8.20E-04	5.72E-04	1.00E+01			
2. Average I-131 Release Rate	uci/sec	1.03E-04	7.19E-05				
C. Particulates				•			
1. Total Particulates	Ci	2.85E-04	1.29E-04	3.00E+01			
2. Average Release Rate	uci/sec	3.59E-05	1.63E-05				
3. Gross Alpha Radioactivity	Ci	8.32E-07	5.30E-07				
D. Tritium							
1. Total Release	Ci	2.58E+00	2.83E+00	1.00E+01			
2. Average Release Rate	uci/sec	3.24E-01	3.56E-01	<u> </u>			
E. Percent Qtrly Tech Spec Reporting Levels							
1. Iodines, Particulates,			<u> </u>				
and Tritium	%	8.39E-02	6.73E-02				

Table 1B Gaseous Effluents - Elevated Releases

		Continuo	ous Mode	Batch		
Nuclides Released	Unit	3rd Qtr	4th Qtr	3rd Qtr	4th Qtr	
1. Fission Gases						
KR-87	Ci	5.75E-01	3.05E-01	0.00E+00	0.00E+00	
KR-88	Ci	1.09E-01	0.00E+00	0.00E+00	0.00E+00	
XE-133	Ci	1.38E+01	9.24E+00	0.00E+00	0.00E+00	
XE-133M	Ci	1.24E-01	0.00E+00	0.00E+00	0.00E+00	
XE-135	Ci	1.92E+00	1.96E+00	0.00E+00	0.00E+00	
XE-135M	Ci	4.32E+00	5.43E+00	0.00E+00	0.00E+00	
XE-137	Ci	1.47E+01	1.56E+01	0.00E+00	0.00E+00	
XE-138	Ci	9.80E+00	9.00E+00	0.00E+00	0.00E+00	
Total for Period	Ci	4.54E+01	4.16E+01	0.00E+00	0.00E+00	
2. Iodines						
I-131	Ci	6.00E-04	3.09E-04	0.00E+00	0.00E+00	
I-133	Ci	5.51E-03	2.54E-03	0.00E+00	0.00E+00	
I-135	Ci	8.42E-03	4.43E-03	0.00E+00	0.00E+00	

#### 3. Particulates

Total for Period

Ci

CO-60	Ci	2.28E-06	6.00E-07	0.00E+00	0.00E+00
CS-137	Ci	1.25E-06	1.16E-07	0.00E+00	0.00E+00
BA-140	Ci	3.02E-05	3.10E-05	0.00E+00	0.00E+00
SR-89	Ci	6.20E-06	1.25E-05	0.00E+00	0.00E+00
SR-90	Ci	9.10E-08	9.75E-08	0.00E+00	0.00E+00
Total for Period	Ci	4 00E-05	4 448-05	0.008.00	0 000
Total for Period	Ci	4.00E-05	4.44E-05	0.00E+00	0.00E+

1.45E-02

7.28E-03

0.00E+00

0.00E+00

Table 1C Gaseous Effluents - Building Vent Releases

		Continuo	ous Mode	Batch	Mode
Nuclides Released	Unit	3rd Qtr	4th Qtr	3rd Qtr	4th Qtr
1. Fission Gases					
XE-135	Ci	1.81E+00	8.21E+00	9.82E-04	0.00E+00
AR-41	Ci	0.00E+00	0.00E+00	6.59E-03	0.00E+00
Total for Period	Ci	1.81E+00	8.21E+00	7.57E-03	0.00E+00
2. Iodines					
I-131	Ci	2.20E-04	2.63E-04	0.00E+00	0.00E+00
I-133	Ci	1.61E-03	1.92E-03	0.00E+00	0.00E+00
	~ .				
Total for Period	Ci	1.83E-03	2.19E-03	0.00E+00	0.00E+00
3. Particulates					
CR-51	Ci	1.04E-05	0.00E+00	0.00E+00	0.00E+00
CO-60	Ci	1.18E-04	4.86E-05	0.00E+00	0.00E+00
CS-137	Ci	1.16E-04	3.49E-05	0.00E+00	0.00E+00
SR-89	Ci	7.20E-07	1.56E-06	0.00E+00	0.00E+00
SR-90	Ci	6.80E-08	1.53E-09	0.00E+00	0.00E+00

2.45E-04 8.50E-05 0.00E+00

## Table 2A Liquid Effluents - Summation of all Releases

	Units	3rd Qtr	4th Qtr	Est. Total Error, %
A. Fission & Activation products	<del></del>	J		
1. Total Release (not including tritium, gases, alpha)	Ci	0.00E+00	0.00E+00	0.00E+00
2. Avg Diluted Concentration	uci/ml	0.00E+00	0.00E+00	•
B. Tritium				
1. Total Release	Ci	2.74E-04	0.00E+00	3.00E+01
2. Avg Diluted Concentration	uci/ml	1.44E-09	0.00E+00	
C. Dissolved and Entrained Gases				
1. Total Release	Ci	0.00E+00	0.00E+00	0.00E+00
2. Avg Diluted Concentration	uci/ml	0.00E+00	0.00E+00	.
D. Percent Qtrly Tech Spec Report:	ing Level			
1. Whole Body Dose	ે	1.77E-10	0.00E+00	
2. Organ Dose	%	5.32E-11	0.00E+00	
E. Gross Alpha Radioactivity				
1. Total Release	Ci	0.00E+00	0.00E+00	0.00E+00
	<del></del>			
F. Volume of Waste Released	Liters	7.88E+04	0.00E+00	3.00E+01
			·	
F. Volume of Dilution Water Used	Liters	2.02E+08	0.00E+00	3.00E+01

## Table 2B Liquid Effluents

		Continuous Mode		Continuous Mode Batch Mod		Mode
Nuclides Released	Unit	3rd Qtr	4th Qtr	3rd Qtr	4th Qtr	

None Released This Period

Table 3 Solid Waste and Irradiated Fuel Shipments
A. Solid Waste Shipped Offsite for Burial or Disposal (not irradiated fuel)

1. Type of Waste	Units		Est. Total
		Period	Error, %
a. Spent resins, filter sludges,	Cu. Meter	0.00E+00	
evaporator bottoms, etc.	Ci	0.00E+00	0.00E+00
b. Dry compressible waste,	Cu. Meter	1.88E+01	
contaminated equipment, etc.	Ci (est)	2.24E-01	3.50E+01
c. Irradiated components,	Cu. Meter	0.00E+00	
control rods, etc.	Ci	0.00E+00	0.00E+00
d. Other (describe)	Cu. Meter	0.00E+00	
	Ci	0.00E+00	0.00E+00

2. Estimate of mag	or nuclide	composition	n (by type o	of waste)
	Type A	Type B	Type C	Type D
Nuclide	percent	percent	percent	percent
H-3		1.05E-01		
C-14		1.24E-01		
Cr-51		3.77E-01		
Mn-54		4.17E+00		
Fe-55		6.36E+01		
Co-58		5.95E-03		
Fe-59		7.08E-02		
Ni-59		2.84E-04		
Co-60		2.03E+01		
Ni-63		4.63E-01		
Zn-65		6.80E+00		
Sr-90		1.45E-02		
I-131		9.94E-02		
Cs-137		1.16E+00		
Ba-140		7.80E-02		
Eu-154		2.57E+00		
Pu-238		2.87E-03		
Pu-239		1.94E-03		
Am-241		6.74E-03		
Pu-241		1.19E-01		
Cm-242		2.00E-03		
Cm-243		1.94E-03		
Eu-152		2.27E+00		

Table 3 Solid Waste and Irradiated Fuel Shipments

## 3. Solid waste disposal

Number of	Mode of		Destination	
Shipments	Transportation			
34	Truck	Envirocare,	Clive, UT.	

## B. Irradiated Fuel Shipments

## 1. Disposition

١	Number of	Mode of	Destination	l
	Shipments	Transportation		l

## None This Period

## C. Shipping Container and Solidification Method

No.	Volume	Activity	Type of	Container	Solidification
	М3	Ci	Waste	Code	Code
9838B	2.18E-01	2.96E-04	В	L	N
0026G	4.53E-01	2.30E-03	В	L	N
0026H	9.06E-02	7.00E-04	В	m L	N
0026I	2.72E-01	7.00E-04	В	L	N
0026J	2.95E-01	4.00E-04	В	L L	N
0026K	2.23E+00	1.01E-01	В	L	N
0026L	1.59E-01	3.20E-02	В	L	N
9917G	6.25E-02	5.00E-04	В	L	N
9917H	4.81E-02	4.00E-04	В	L	N
9906E	1.71E-02	9.00E-05	В В В	다 다 다	N
9906F	1.13E-01	5.00E-04	В	L	N
9908G	3.19E-02	2.16E-04		L	N
9908H	4.65E-02	9.44E-04	В	L	N
99081	5.31E-02	1.70E-03	B B B	L	N
9908J	7.30E-02	3.00E-03		L	N
9908K	3.83E-02	2.42E-04	В	L L	N
9908L	3.64E-01	6.28E-03	B B B	L	N
0026M	2.04E-01	2.59E-04		L	N
0026N	8.61E-01	1.21E-03	В	L L L	N
00260	1.59E-01	1.89E-04	В	L	N
9906G	3.85E-02	2.36E-04	В	L	N
9908M	2.27E-01	1.16E-04	В	L	N
9906H	1.13E-01	4.93E-04	В	L	N
0036H	6.71E-03	1.42E-02	В	L	N
0026P	3.62E-01	9.23E-04	В	${f L}$	N
0036I	4.93E-02	2.98E-03	В	L	N
9906I	6.54E+00	2.89E-02	В	${f L}$	N
9908N	1.79E-02	3.30E-05	В	L	N

## C. Shipping Container and Solidification Method (Cont.)

No.	Volume M3	Activity Ci	Type of Waste	Container Code	Solidification Code
00177		<u> </u>		code	code
9917I	1.40E-02	5.38E-05	В	ப	ļ N
0036J	7.82E-01	1.15E-02	В	L	N
9917J	8.27E-01	2.99E-03	В	L	N
9917K	2.61E+00	4.62E-03	В	${f L}$	N
9917L	5.08E-01	1.29E-03	В	${f L}$	N
99080	8.71E-01	2.60E-03	В	L	N

Container Codes :

L - LSA A - Type A B - Type B Q - Large Quantity

Solidification Codes :

C - Cement U - Urea Formaldehyde D - Dewatering N - Not Applicalble

## **Attachment B**

Off-Site Radiation Dose Assessment for January 1, - December 31, 2000

(The attached Report contains 6 pages.)

# NORTHERN STATES POWER COMPANY MONTICELLO NUCLEAR GENERATING PLANT

## Off-Site Radiation Dose Assessment for January 1, - December 31, 2000

An assessment of radiation dose due to releases from the Monticello Nuclear Generating Plant during 2000 was performed in accordance with the Technical Specifications (T.S.). Computed doses were well below the 40 CFR 190 Standards and 10 CFR Part 50, Appendix I Guidelines.

Off-site dose calculation formulas and meteorological data from the Off-site Dose Calculation Manual were used in making this assessment. Source terms were obtained from the two Semi-Annual Effluent Release Reports for 2000.

## Off-Site Doses from Gaseous Releases (T.S. 6.7.A.4)

Computed doses due to gaseous releases are reported in Table 1. Critical receptor location and pathways for organ doses are reported in Table 2. Doses, both whole body and organ, are a small percentage of Appendix I Guidelines.

## Off-Site Doses From Liquid Releases (T.S. 6.7.A.4)

Doses from liquid releases are listed in Table 1. Doses are based on release of Turbine Building Normal Drain Sump water releases in the second and third quarters with tritium activity present.

## Doses to Individuals Due to Their Activities Inside the Site Boundary (T.S. 6.7.A.4)

There are several groups of concern, contract tree trimmers clearing transmission lines, sportsmen entering the Monticello site for recreational activities and XCEL Energy Company transmission and distribution crews working in the substation. Use of a very conservative assumption of 40 hours/week spent inside the site boundary by these groups would conservatively represent the most exposed individual. The annual whole body, skin and organ dose was computed using plant stack and reactor building vent X/Q values for the abandoned Environmental Protection Agency Field Station location (a bounding location due to predominant wind direction and nearness to the release points) as input to the GASPAR code. This computed dose was reduced by the factor of 40/168 to account for limited occupancy. Dose to the whole body, skin and organ (thyroid) is less than that for the critical receptor location which is reported in Table 1.

## Doses to the Likely Most Exposed Member of the General Public from Reactor Releases and Other Nearby Uranium Fuel Cycle Sources (T.S. 6.7.A.4)

There are no other uranium fuel facilities in the vicinity of the Monticello site. The only artificial source of exposure to the general public in addition to the plant effluent releases is from direct radiation of the reactor and the steam turbines.

Environmental TLDs were used to provide data on direct and skyshine radiation dose and the GASPAR code was used to provide data on dose from airborne pathways. The net dose from the TLDs was added to the GASPAR dose data for locations of off site residences. This data indicates that the annual whole body and organ dose to each of these locations is less than 15 millirem. (see pages 5 and 6 for details)

Therefore, the likely most exposed member of the general public will not receive an annual radiation dose from reactor effluent releases and all other fuel cycle activities in excess of 40 CFR 190 standards of 25 millirem to the whole body, 75 millirem to the thyroid, and 25 millirem to any other organ.

## Changes in Land Use and Non Obtainable Milk or Vegetable Samples

(T.S. 4.16.B.2 & T.S. 4.16.A.5)

There were no changes in land use resulting in significant increases in calculated doses. There were no milk or vegetable samples that could not be obtained during this reporting period.

Table 1

## Off-Site Radiation Dose Assessment - Monticello

## PERIOD: January 1, through December 31, 2000

Maximum Site Boundary Gamma Air Dose		
(mrad/year)	0.004	10
Maximum Site Boundary Beta Air Dose (mrad/year)	0.005	20
Maximum Off-Site Dose to Any Organ (mrem/year)	0.014	15
Maximum Dose to the Likely Most Exposed		
Member of the General Public (mrem/year) Whole Body Skin Organ (Thyroid)	0.007 0.008 0.014	5 15 15
Maximum Off-Site Dose (mrem) Whole Body Organ	2.81E-12 2.81E-12	3 10

## Table 2

## Off-Site Radiation Dose Assessment - Monticello Supplemental Information

PERIOD: January 1, through December 31, 2000

Maximum Site Boundary Dose Location			
(from Reactor Building Vents)			
Sector	S	SE	
Distance (miles)	0.	40	
EPA Field Station			
Sector	S	E	
Distance from Plant Stack (miles)	0.	26	
Distance from Reactor Building Vents	0.	36	
Critical Receptor Location			
		•	
Sector	SS	SW	
Distance from Reactor Building Vents (miles)	0.	60	
Pathways	Plume, Ground, Inhalation, Vegetable		
Age Group		CHILD	
Organ	THY	ROID	
St. Paul Drinking Water Intake Location			
Pathways	Drinking Water	Drinking Water, Fish	
Age Group	Infant	Adult	
Organ	Whole Body	GI Tract	
Dilution Factor (drinking water)	7:1	7:1	

## **Bases for Radiation Dose Statements**

## 40 CFR 190 Limits for Annual Dose Equivalent

Whole Body – 25 mrem

Thyroid – 75 mrem

Any Other Organ – 25 mrem

## **Critical Receptor Locations**

Maximum Organ Dose – 0.6 miles SSW Maximum Site Boundary TLD – 0.4 miles W

## Maximally Exposed Individuals

A. Maximum Offsite Dose from Airborne Effluents

(Calculated by GASPAR program)

Whole Body:

0.007 mrem

Thyroid:

0.014 mrem

Any Other Organ:

0.008 mrem

#### B. Dose from Shine

TLD	Location	Mean Reading (mrem/91 days)	Standard Deviation	
Controls	4 quadrants @ 90° separation	14.7	1.42 (4 sites all >10 mile distance)	
M-09A	0.6 miles SSW	14.4	0.30 (in direction of Critical Recepto	r)
M-12A	0.4 miles W	16.9	0.39 (maximum site boundary TLD)	

The difference (D) between the indicator and control TLDs, the standard deviation of D, and the limits for D at the 90% confidence level are as follows:

TLD	$\overline{\mathbf{D}}$	Std Dev	90% Conf	Limits at 90% Confidence
M-09A	-0.28	0.39	0.64	-0.92 < D < 0.37
M-12A	2.25	0.41	0.67	1.58 < D < 2.92

M-09A – Because zero is in the interval, there may be no difference between the indicator and control TLDs. At the 90% confidence level, the difference is no greater than 0.37 mrem per 91 days, or approximately 1.5 mrem/year.

M-12A – At the 90% confidence level, the difference is no greater than 2.92 mrem per 91 days, or approximately 11.7 mrem/year.

## C. Maximum Total Dose

Annual Dose from effluents to any individual, regardless of location, will be no more than:

Whole Body: 0.007 mrem
Thyroid: 0.014 mrem
Other Organs: 0.008 mrem

Annual Direct Dose will be no more than:

11.7 mrem

Therefore, the maximum dose quantities for comparison to 49 CFR 190 limits are (mrem/year):

<u>Dose</u>	Limit
11.71	25
11.71	75
11.71	25
	11.71 11.71