

ENCLOSURE 1 TO NYN-01038

**Effluent Release Data as Required by
Regulatory Guide 1.21**

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

Supplemental Information 2000

Facility: Seabrook Station Unit 1 Licensee: North Atlantic Energy Service Corporation

1. Regulatory Limits

A. Gaseous Effluents

- a. 5.0 mrad per quarter gamma air dose.
- b. 10.0 mrad per quarter beta air dose.
- c. 7.5 mrem per quarter to any organ.

B. Liquid Effluents

- a. 1.5 mrem per quarter total body.
- b. 5.0 mrem per quarter any organ.
- c. 2.0E-04 $\mu\text{Ci/ml}$ dissolved or entrained gas.

2. Maximum Permissible Concentrations

Provide the MPC's used in determining allowable release rates or concentrations.

- a. Fission and activation gases: 1 MPC
- b. Iodines: 1 MPC
- c. Particulates, half-lives >8 days: 1 MPC
- d. Liquid Effluents: 1 MPC

3. Average Energy

Not applicable

4. Measurements and Approximations of Total Radioactivity

Provide the methods used to measure or approximate the total radioactivity in effluents and the methods used to determine radionuclide composition.

- A. Fission and activation gases: Determined by gamma spectroscopy. Total error is based on stack flow error, analytical error, and calculated sampling error.
- B. Iodines: Determined by collection on charcoal with subsequent gamma spectroscopy analysis. Total error is based on stack flow error, analytical error, and calculated sampling error.
- C. Particulates: Determined by collection on fixed filter with subsequent gamma spectroscopy analysis. Strontium is determined by composite analysis of filters by liquid scintillation, gross alpha by proportional counter and iron 55 by liquid scintillation. Total error is based on stack flow error, analytical error, and calculated sampling error.
- D. Liquid Effluents: Determined by gamma spectroscopy. A composite sample is analyzed for strontium by liquid scintillation, tritium by liquid scintillation, gross alpha by proportional counter and iron 55 by liquid scintillation. Total error is based on the volume discharge error and analytical error.
- E. ND: None Detected or No Detectable Activity

5. Batch Releases

Provide the following information relating to batch releases of radioactive materials in liquid and gaseous effluents.

A. Liquid

- a. Number of batch releases: 130
- b. Total time for batch releases: 26267 minutes
- c. Maximum time period for batch release: 1469 minutes
- d. Average time period for batch release: 220 minutes
- e. Minimum time period for batch release: 27 minutes
- f. Average stream flow during periods of release of effluents into a flowing stream: 1.58E+06 liters per minute

B. Gaseous

- a. Number of batch releases: 41
- b. Total time for batch releases: 16773 minutes
- c. Maximum time period for batch release: 5430 minutes
- d. Average time period for batch release: 419 minutes
- e. Minimum time period for batch release: 2 minutes

6. Abnormal Releases

A. Liquid

- a. Number of releases: 0
- b. Total activity released: N/A

B. Gaseous

- a. Number of releases: 0
- b. Total activity released: N/A

TABLE 1A

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT 2000

GASEOUS EFFLUENTS-SUMMATION OF ALL RELEASES

Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Est. Total Error, %
------	--------------	--------------	--------------	--------------	------------------------

A. Fission and activation gases

1. Total releases	Ci	4.87E-04	3.34E-02	7.75E-02	6.54E-01	1.70E+01
2. Average release rate for period	uci/sec	6.26E-05	4.29E-03	9.75E-03	8.23E-02	
3. Percent of applicable Technical Specification limit	%	1.94E-05	2.20E-03	9.74E-04	6.14E-03	

B. Iodines

1. Total release	Ci	ND	ND	ND	5.38E-08	1.50E+01
2. Average release rate for period	uci/sec	N/A	N/A	N/A	6.92E-09	
3. Percent of applicable Technical Specification limit	%	3.31E-01	4.24E-01	3.81E-01	4.56E-01	

C. Particulates

1. Total release	Ci	2.65E-10	ND	ND	8.03E-06	1.80E+01
2. Average release rate for period	uci/sec	3.41E-11	N/A	N/A	1.03E-06	
3. Percent of applicable Technical Specification limit	%	3.31E-01	4.24E-01	3.81E-01	4.56E-01	
4. Total alpha radioactivity	Ci	2.65E-10	ND	ND	ND	

D. Tritium

1. Total release	Ci	2.46E+01	3.16E+01	2.86E+01	3.31E+01	1.60E+01
2. Average release rate for period	uci/sec	3.16E+00	4.06E+00	3.60E+00	4.16E+00	
3. Percent of applicable Technical Specification limit	%	3.31E-01	4.24E-01	3.81E-01	4.56E-01	

TABLE 1B
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2000)
GASEOUS EFFLUENTS-ELEVATED RELEASES
BATCH

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
-------------------	------	--------------	--------------	--------------	--------------

1. Fission and activation gases

argon-41	Ci	3.19E-04	2.15E-02	3.09E-02	4.50E-01
krypton-85	Ci	ND	ND	ND	2.11E-02
krypton-85m	Ci	ND	ND	ND	ND
krypton-87	Ci	ND	ND	ND	ND
krypton-88	Ci	ND	ND	ND	ND
xenon-131m	Ci	ND	ND	ND	ND
xenon-133	Ci	1.68E-04	1.15E-02	1.05E-02	1.29E-01
xenon-133m	Ci	ND	ND	ND	ND
xenon-135	Ci	ND	ND	7.45E-04	7.73E-03
xenon-135m	Ci	ND	ND	ND	ND
xenon-138	Ci	ND	ND	ND	ND
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	4.87E-04	3.30E-02	4.21E-02	6.08E-01

2. Iodines

iodine-131	Ci	ND	ND	ND	ND
iodine-133	Ci	ND	ND	ND	ND
iodine-135	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

3. Particulates

strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-137	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

TABLE 1B
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2000)
GASEOUS EFFLUENTS-ELEVATED RELEASES
CONTINUOUS

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
-------------------	------	--------------	--------------	--------------	--------------

1. Fission and activation gases

argon-41	Ci	ND	ND	2.20E-03	ND
krypton-85	Ci	ND	ND	ND	ND
krypton-85m	Ci	ND	ND	ND	ND
krypton-87	Ci	ND	ND	ND	ND
krypton-88	Ci	ND	ND	ND	ND
xenon-131m	Ci	ND	ND	ND	ND
xenon-133	Ci	ND	ND	ND	ND
xenon-133m	Ci	ND	ND	ND	ND
xenon-135	Ci	ND	ND	2.25E-04	ND
xenon-135m	Ci	ND	ND	5.32E-06	ND
xenon-138	Ci	ND	ND	ND	ND
	Ci				
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	2.43E-03	0.00E+00

2. Iodines

iodine-131	Ci	ND	ND	ND	ND
iodine-133	Ci	ND	ND	ND	ND
iodine-135	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

3. Particulates

strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-137	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
cobalt-58	Ci	ND	ND	ND	ND
cobalt-60	Ci	ND	ND	ND	ND
chromium-51	Ci	ND	ND	ND	ND
manganese-54	Ci	ND	ND	ND	ND
niobium-95	Ci	ND	ND	ND	ND
iron-59	Ci	ND	ND	ND	ND
bromine-82	Ci	ND	ND	ND	7.88E-06
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	7.88E-06

TABLE 1C
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2000)
GASEOUS EFFLUENTS-GROUND LEVEL RELEASES
BATCH

Nuclides Released	Unit	Quarter	Quarter	Quarter	Quarter
		1	2	3	4

1. Fission and activation gases

argon-41	Ci	ND	ND	ND	ND
krypton-85	Ci	ND	ND	ND	ND
krypton-85m	Ci	ND	ND	ND	ND
krypton-87	Ci	ND	ND	ND	ND
krypton-88	Ci	ND	ND	ND	ND
xenon-131m	Ci	ND	ND	ND	ND
xenon-133m	Ci	ND	ND	ND	ND
xenon-133	Ci	ND	ND	ND	1.13E-03
xenon-135	Ci	ND	ND	ND	ND
xenon-135m	Ci	ND	ND	ND	ND
xenon-138	Ci	ND	ND	ND	ND
	Ci				
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	1.13E-03

2. Iodines

iodine-131	Ci	ND	ND	ND	5.38E-08
iodine-132	Ci	ND	ND	ND	ND
iodine-133	Ci	ND	ND	ND	ND
iodine-135	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	5.38E-08

3. Particulates

strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-136	Ci	ND	ND	ND	ND
cesium-137	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
cobalt-57	Ci	ND	ND	ND	ND
cobalt-58	Ci	ND	ND	ND	6.54E-08
cobalt-60	Ci	ND	ND	ND	ND
manganese-54	Ci	ND	ND	ND	ND
iron-59	Ci	ND	ND	ND	ND
niobium/zirconium-95	Ci	ND	ND	ND	ND
chromium-51	Ci	ND	ND	ND	ND
technetium-99m	Ci	ND	ND	ND	ND
bromine-82	Ci	ND	ND	ND	ND
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	6.54E-08

TABLE 1C
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (2000)
GASEOUS EFFLUENTS-GROUND LEVEL RELEASES
CONTINUOUS

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
-------------------	------	--------------	--------------	--------------	--------------

1. Fission and activation gases

argon-41	Ci	ND	ND	ND	ND
krypton-85	Ci	ND	ND	ND	ND
krypton-85m	Ci	ND	ND	ND	ND
krypton-87	Ci	ND	ND	ND	ND
krypton-88	Ci	ND	ND	ND	ND
xenon-133	Ci	ND	ND	ND	ND
xenon-135	Ci	ND	ND	ND	ND
xenon-135m	Ci	ND	ND	ND	ND
xenon-138	Ci	ND	ND	ND	ND
	Ci				
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

2. Iodines

iodine-131	Ci	ND	ND	ND	ND
iodine-133	Ci	ND	ND	ND	ND
	Ci				
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

3. Particulates

strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-136	Ci	ND	ND	ND	ND
cesium-137	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
cobalt-58	Ci	ND	ND	ND	8.70E-08
cobalt-60	Ci	ND	ND	ND	ND
gross alpha	Ci	2.65E-10	ND	ND	ND
	Ci				
unidentified	Ci	ND	ND	ND	ND
Total for period	Ci	2.65E-10	0.00E+00	0.00E+00	8.70E-08

TABLE 2A

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT 2000

LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Est. Total Error, %
------	-----------	-----------	-----------	-----------	---------------------

A. Fission and activation products

1. Total releases	Ci	7.06E-03	1.35E-02	2.90E-02	7.37E-03	6.00E+00
2. Average diluted concentration	uCi/ml	3.53E-11	5.92E-11	1.18E-10	7.16E-11	
3. Percent of applicable limit	%	9.13E-03	2.03E-02	4.34E-02	6.86E-02	

B. Tritium

1. Total release	Ci	2.01E+01	2.92E+02	1.09E+03	3.09E+01	8.00E+00
2. Average diluted concentration	uCi/ml	1.01E-07	1.28E-06	4.43E-06	3.00E-07	
3. Percent of applicable limit	%	9.13E-03	2.03E-02	4.34E-02	6.86E-02	

C. Dissolved and entrained gases

1. Total release	Ci	ND	ND	1.72E-04	ND	1.90E+01
2. Average diluted concentration	uCi/ml	NA	NA	6.99E-13	NA	
3. Percent of applicable limit	%	NA	NA	3.50E-07	NA	

D. Gross alpha radioactivity

1. Total release	Ci	ND	ND	ND	ND	1.00E+01
------------------	----	----	----	----	----	----------

E. Volume of waste released (prior to	liters	2.11E+07	1.72E+07	1.85E+07	2.25E+07	1.30E+00
F. Volume of dilution water used during period	liters	2.00E+11	2.28E+11	2.46E+11	1.03E+11	9.00E+00

TABLE 2B
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT 2000
LIQUID EFFLUENTS
BATCH MODE

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	1.52E-04	ND	ND	ND
cesium-137	Ci	2.96E-04	ND	3.06E-05	1.00E-05
iodine-131	Ci	7.91E-06	1.53E-05	2.86E-05	ND
iodine-133	Ci	ND	ND	2.58E-05	ND
cobalt-57	Ci	2.58E-05	8.16E-06	3.94E-05	2.46E-06
cobalt-58	Ci	1.13E-03	5.45E-04	7.01E-04	3.98E-03
cobalt-60	Ci	1.13E-03	2.59E-03	3.28E-03	3.85E-04
chromium-51	Ci	ND	ND	ND	1.08E-04
iron-55	Ci	1.07E-03	3.78E-03	7.74E-03	2.10E-03
iron-59	Ci	ND	ND	ND	ND
zinc-65	Ci	ND	ND	ND	ND
manganese-54	Ci	7.48E-05	8.85E-05	3.14E-05	6.01E-06
zirconium-niobium-95	Ci	ND	ND	ND	ND
molybdenum-99	Ci	ND	ND	ND	ND
technetium-99m	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
cerium-141	Ci	ND	ND	ND	ND
antimony-122	Ci	ND	ND	ND	5.46E-06
antimony-124	Ci	ND	ND	ND	ND
antimony-125	Ci	3.17E-03	6.47E-03	1.71E-02	7.67E-04
niobium-97	Ci	ND	1.31E-05	ND	ND
tin-117m	Ci	ND	ND	ND	ND
sodium-24	Ci	ND	ND	ND	ND
unidentified	Ci	ND	ND	ND	ND

Total for period(above)	Ci	7.06E-03	1.35E-02	2.90E-02	7.36E-03
-------------------------	----	----------	----------	----------	----------

xenon-133	Ci	ND	ND	1.70E-04	ND
xenon-135	Ci	ND	ND	ND	ND

TABLE 2B
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT 2000
LIQUID EFFLUENTS
 CONTINUOUS MODE

Nuclides Released	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4
strontium-89	Ci	ND	ND	ND	ND
strontium-90	Ci	ND	ND	ND	ND
cesium-134	Ci	ND	ND	ND	ND
cesium-137	Ci	ND	ND	ND	ND
iodine-131	Ci	ND	ND	ND	ND
iodine-133	Ci	ND	ND	2.28E-06	ND
cobalt-58	Ci	ND	ND	ND	4.10E-06
cobalt-60	Ci	ND	ND	ND	ND
iron-59	Ci	ND	ND	ND	ND
zinc-65	Ci	ND	ND	ND	ND
manganese-54	Ci	ND	ND	ND	7.70E-07
chromium-51	Ci	ND	ND	ND	ND
zirconium-niobium-95	Ci	ND	ND	ND	ND
molybdenum-99	Ci	ND	ND	ND	ND
technetium-99m	Ci	ND	ND	ND	ND
barium-lanthanum-140	Ci	ND	ND	ND	ND
cerium-141	Ci	ND	ND	ND	ND
unidentified	Ci	ND	ND	ND	ND
Total for period(above)	Ci	0.00E+00	0.00E+00	2.28E-06	4.87E-06
xenon-131m	Ci	ND	ND	ND	ND
xenon-133m	Ci	ND	ND	ND	ND
xenon-133	Ci	ND	ND	2.06E-06	ND
xenon-135	Ci	ND	ND	ND	ND

TABLE 3
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT 2000
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not irradiated fuel)

1. Type of waste	Unit	Est. Total Error, %
a. Spent resins, filter sludges, evaporator Bottoms, etc.	21.9 m ³ 403.2 Ci	2.00E+01
b. Dry compressible waste, contaminated Equip, etc.	0 m ³ 0 Ci	NA
c. Irradiated components, control Rods, etc.	0 m ³ 0 Ci	NA
d. Other (describe)	0 m ³ 0 Ci	NA

2. Estimate of major nuclide composition (by waste type)

	Nuclide	%	Ci
a.	H-3	0.08	3.27E-01
	C-14	0.04	1.55E-01
	Mn-54	1.31	5.28E+00
	Fe-55	11.92	4.81E+01
	Co-57	0.08	3.19E-01
	Co-58	0.11	4.31E-01
	Co-60	11.53	4.65E+01
	Ni-59	0.12	5.01E-01
	Ni-63	68.33	2.76E+02
	Sr-89	1.16E-04	4.68E-04
	Sr-90	0.02	6.37E-02
	Sb-125	0.18	7.13E-01
	Cs-134	1.88	7.58E+00
	Cs-137	3.94	1.59E+01
	Ce-144	0.46	1.87E+00
	Pu-238	6.09E-05	2.46E-04
	Pu-239	4.40E-05	1.78E-04
	Pu-241	4.02E-03	1.62E-02
	Am-241	1.84E-05	7.41E-05
	Cm-242	6.72E-06	2.71E-05
	Cm-243	2.94E-03	1.19E-02
b.	NA	NA	NA
c.	NA	NA	NA
d.	NA	NA	NA

3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
5	Flatbed Truck	Chem-Nuclear Barnwell, SC

B. IRRADIATED FUEL SHIPMENTS (Disposition)

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
NA	NA	NA

LIST OF APPENDICES

<u>Appendix</u>	<u>Title</u>
A	Offsite Dose Calculation Manual
B	Process Control Program
C	Radioactive Liquid Effluent Monitoring Instrumentation
D	Radioactive Gaseous Effluent Monitoring Instrumentation
E	Liquid Holdup Tanks
F	Radwaste Treatment Systems
G	Unplanned Releases

Appendix - A

Offsite Dose Calculation Manual

Radiological Effluent Control Section

During 2000 the Offsite Dose Calculation Manual (ODCM) was revised twice.

The first revision, Rev 20, incorporated for use Revision 19 material, which had been sent to the NRC for approval in LAR 97-08. This revision incorporated NRC Generic Letter 89-01 guidance to remove Radiological Effluent Technical Specifications from Technical Specifications and place them in the ODCM. The program as defined in 3/4.3.3.9 & 3.3.10, 3/4.11.1, .2, & .4 of Technical Specifications has been relocated to chapter 5.2 of the Technical Requirements Manual. The applicable sections are: TRP5.2 C.5.1, C.5.2 & C.6.1.1, C.6.2.1, C.6.3.1, C.7.1.1, C.7.2.1, C.7.3.1, C.7.4.1, C.8.1.1, respectively.

The second revision, Rev. 21 incorporated minor administrative changes concerning the location of the ODCM in the Technical Requirements Manual and how ODCM changes will be handled, and changed Control C.4.0.3 to Technical Requirement TR 3.0.4 and 4.0.4. The revision also incorporated into the Bases Sections of C.5.1, C.5.2, C.6.1.1 clarifications, which were previously located in the Technical Clarification Manual.

REMP Section

During 2000, the Barker Farm (TM-21) got out of the dairy business (June) and dropped out of the Program. A replacement farm (Spring Hill) was found. The Spring Hill Farm was designated as TM-22. Location TM-22 is classified as a "backup" Control station. The Barker farm was 17.46 miles from Containment and the Foulks farm is 16.9 miles. In December of 2000, Mr. Robert Foulks owner of the Spring Hill Farm moved his herd to Vermont and thereby dropped out of the Program.

The Radiological Environmental Monitoring program as defined in 3/4.12.1, 2, & 3 of Tech Specs has been relocated to chapter 5.2 of the Technical Requirements Manual. The applicable sections are: TRP5.2 C.9.1.1, TRP5.2 C.9.2.1, and TRP5.2 C.9.3.1 respectively.

For this period, the REMP was conducted as specified in the ODCM. The Land Use Census for 2000 reflects the continued use of Global Positioning technology that more accurately locates and verifies residences and gardens as to distance and sector from containment.

Appendix B

Process Control Program

Requirement:

Technical Specification 6.12.2.a requires that licensee initiated changes to the Process Control Program (PCP) be submitted to the Commission in the Annual Radioactive Effluent Release Report for the period in which the changes were made.

Response:

During 2000, there were no changes to the PCP.

Appendix C

Radioactive Liquid Effluent Monitoring Instrumentation

Requirement: Radioactive Liquid Effluent Monitoring Instrumentation channels are required to be operable in accordance with Technical Requirement Program 5.2-C.5.1. With less than the minimum number of channels operable for 30 days, Technical Requirement Program 5.2-C.5.1 requires an explanation for the delay in correcting the inoperability in the next Annual Radiological Effluent Release Report in accordance with Technical Specification 6.8.1.4.

Response:

A review of the Action Statement Status tracking system for the period from January 1, 2000 to December 31, 2000 indicated Technical Requirement Program 5.2-C.5.1 was not entered for more than 30 consecutive days.

Appendix D

Radioactive Gaseous Effluent Monitoring Instrumentation

Requirement: Radioactive Gaseous Effluent Monitoring Instrumentation Channels are required to be operable in accordance with Technical Requirement Program 5.2-C.5.2. With less than the minimum number of channels operable for 30 days, Technical Requirement Program 5.2-C.5.2 requires an explanation for the delay in correcting the inoperability in the next Annual Radioactive Effluent Release Report in accordance with Technical Specification 6.8.1.4.

Response:

A review of the Action Statement Status tracking system for the period from January 1, 2000 to December 31, 2000 indicated Technical Requirement Program 5.2-C.5.2 was not entered for more than 30 consecutive days.

Appendix E

Liquid Holdup Tanks

Requirement: Technical Specification 3.11.1.4 limits the quantity of radioactive material contained in any outside temporary tank. With the quantity of radioactive material in any outside temporary tank exceeding the limits of Technical Specification 3.11.1.4, a description of the events leading to this condition is required in the next Annual Radiological Effluent Release Report in accordance with Technical Specification 3.11.1.4.

Response: From January 1, 2000 to December 31, 2000, there was no radioactive material stored in any temporary outdoor tank that exceeded the limits of TS 3.11.1.4.

Appendix F

Radwaste Treatment Systems

Requirement: Technical Specification 6.14.1.a requires that licensee initiated changes to the Radwaste Treatment Systems (liquid, gaseous and solid) be submitted to the Commission in the Annual Radioactive Effluent Release Report for the period in which the change was made. Licensees may choose to submit the information called for in Technical Specification 6.14 as part of the FSAR update, pursuant to 10CFR50.71.

Response: For 2000, North Atlantic will submit any changes to the Radwaste Treatment Systems (liquid, gaseous and solid) as part of the FSAR update.

Appendix G

Unplanned Releases

Requirement: Technical Specification 6.8.1.4 requires a list and description of unplanned releases from the site to UNRESTRICTED AREAS of radioactive materials in gaseous and liquid effluents made during the reporting period.

Response: A review of the January 1, 2000 to December 31, 2000 time period indicated there were no unplanned, unanticipated or abnormal releases from the site to unrestricted areas of radioactive materials of gaseous or liquid effluents.

ENCLOSURE 2 TO NYN-01038

**Joint Frequency Distributions of Wind Speed,
Wind Direction and Atmospheric Stability**

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS A CLASS FREQUENCY (PERCENT) = 1.61

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.71	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.71
(2)	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
4-7	0	0	0	1	1	0	3	1	0	0	0	3	0	0	0	0	0	9
(1)	.00	.00	.00	.71	.71	.00	2.13	.71	.00	.00	.00	2.13	.00	.00	.00	.00	.00	6.38
(2)	.00	.00	.00	.01	.01	.00	.03	.01	.00	.00	.00	.03	.00	.00	.00	.00	.00	.10
8-12	1	0	2	4	12	14	27	7	2	3	6	4	6	6	3	1	0	98
(1)	.71	.00	1.42	2.84	8.51	9.93	19.15	4.96	1.42	2.13	4.26	2.84	4.26	4.26	2.13	.71	.00	69.50
(2)	.01	.00	.02	.05	.14	.16	.31	.08	.02	.03	.07	.05	.07	.07	.03	.01	.00	1.12
13-18	0	0	2	4	6	2	1	0	0	0	2	3	5	5	3	0	0	33
(1)	.00	.00	1.42	2.84	4.26	1.42	.71	.00	.00	.00	1.42	2.13	3.55	3.55	2.13	.00	.00	23.40
(2)	.00	.00	.02	.05	.07	.02	.01	.00	.00	.00	.02	.03	.06	.06	.03	.00	.00	.38
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	2	0	4	9	19	16	31	8	2	3	8	10	11	11	6	1	0	141
(1)	1.42	.00	2.84	6.38	13.48	11.35	21.99	5.67	1.42	2.13	5.67	7.09	7.80	7.80	4.26	.71	.00	100.00
(2)	.02	.00	.05	.10	.22	.18	.35	.09	.02	.03	.09	.11	.13	.13	.07	.01	.00	1.61

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS B CLASS FREQUENCY (PERCENT) = 2.45
WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1
(1)	.00	.00	.00	.00	.00	.00	.47	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.47
(2)	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
4-7	3	0	0	0	4	2	4	5	1	1	4	5	1	2	1	2	0	35
(1)	1.40	.00	.00	.00	1.87	.93	1.87	2.34	.47	.47	1.87	2.34	.47	.93	.47	.93	.00	16.36
(2)	.03	.00	.00	.00	.05	.02	.05	.06	.01	.01	.05	.06	.01	.02	.01	.02	.00	.40
8-12	0	0	1	5	22	6	11	5	4	5	17	10	7	21	10	2	0	126
(1)	.00	.00	.47	2.34	10.28	2.80	5.14	2.34	1.87	2.34	7.94	4.67	3.27	9.81	4.67	.93	.00	58.88
(2)	.00	.00	.01	.06	.25	.07	.13	.06	.05	.06	.19	.11	.08	.24	.11	.02	.00	1.44
13-18	0	0	6	7	2	0	0	0	2	3	7	1	3	8	8	2	0	49
(1)	.00	.00	2.80	3.27	.93	.00	.00	.00	.93	1.40	3.27	.47	1.40	3.74	3.74	.93	.00	22.90
(2)	.00	.00	.07	.08	.02	.00	.00	.00	.02	.03	.08	.01	.03	.09	.09	.02	.00	.56
19-24	0	0	1	1	0	0	0	0	0	1	0	0	0	0	0	0	0	3
(1)	.00	.00	.47	.47	.00	.00	.00	.00	.00	.47	.00	.00	.00	.00	.00	.00	.00	1.40
(2)	.00	.00	.01	.01	.00	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.03
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	3	0	8	13	28	8	16	10	7	10	28	16	11	31	19	6	0	214
(1)	1.40	.00	3.74	6.07	13.08	3.74	7.48	4.67	3.27	4.67	13.08	7.48	5.14	14.49	8.88	2.80	.00	100.00
(2)	.03	.00	.09	.15	.32	.09	.18	.11	.08	.11	.32	.18	.13	.35	.22	.07	.00	2.45

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS C CLASS FREQUENCY (PERCENT) = 5.59

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	1	0	0	0	1	0	0	0	0	1	0	0	0	1	0	0	4
(1)	.00	.20	.00	.00	.00	.20	.00	.00	.00	.00	.20	.00	.00	.00	.20	.00	.00	.82
(2)	.00	.01	.00	.00	.00	.01	.00	.00	.00	.00	.01	.00	.00	.00	.01	.00	.00	.05
4-7	4	3	1	3	14	6	10	6	4	7	12	11	13	13	9	2	0	118
(1)	.82	.61	.20	.61	2.86	1.23	2.04	1.23	.82	1.43	2.45	2.25	2.66	2.66	1.84	.41	.00	24.13
(2)	.05	.03	.01	.03	.16	.07	.11	.07	.05	.08	.14	.13	.15	.15	.10	.02	.00	1.35
8-12	4	1	6	19	23	13	15	10	2	16	23	33	31	55	31	7	0	289
(1)	.82	.20	1.23	3.89	4.70	2.66	3.07	2.04	.41	3.27	4.70	6.75	6.34	11.25	6.34	1.43	.00	59.10
(2)	.05	.01	.07	.22	.26	.15	.17	.11	.02	.18	.26	.38	.35	.63	.35	.08	.00	3.31
13-18	0	0	10	2	1	0	0	1	1	3	11	4	5	15	16	2	0	71
(1)	.00	.00	2.04	.41	.20	.00	.00	.20	.20	.61	2.25	.82	1.02	3.07	3.27	.41	.00	14.52
(2)	.00	.00	.11	.02	.01	.00	.00	.01	.01	.03	.13	.05	.06	.17	.18	.02	.00	.81
19-24	0	0	1	0	0	0	0	0	2	0	1	0	0	0	0	1	0	5
(1)	.00	.00	.20	.00	.00	.00	.00	.00	.41	.00	.20	.00	.00	.00	.00	.20	.00	1.02
(2)	.00	.00	.01	.00	.00	.00	.00	.00	.02	.00	.01	.00	.00	.00	.00	.01	.00	.06
GT 24	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	0	0	2
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.20	.00	.00	.00	.20	.00	.00	.41
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.01	.00	.00	.02
ALL SPEEDS	8	5	18	24	38	20	25	17	9	26	49	48	49	83	58	12	0	489
(1)	1.64	1.02	3.68	4.91	7.77	4.09	5.11	3.48	1.84	5.32	10.02	9.82	10.02	16.97	11.86	2.45	.00	100.00
(2)	.09	.06	.21	.27	.43	.23	.29	.19	.10	.30	.56	.55	.56	.95	.66	.14	.00	5.59

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS D CLASS FREQUENCY (PERCENT) = 48.70

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.00	.00	.00	.02	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.02
(2)	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
C-3	16	12	20	8	9	11	3	20	21	16	7	12	22	23	17	25	0	242
(1)	.38	.28	.47	.19	.21	.26	.07	.47	.49	.38	.16	.28	.52	.54	.40	.59	.00	5.68
(2)	.18	.14	.23	.09	.10	.13	.03	.23	.24	.18	.08	.14	.25	.26	.19	.29	.00	2.77
4-7	91	65	62	92	104	72	85	76	66	70	63	95	118	164	165	104	0	1492
(1)	2.14	1.53	1.46	2.16	2.44	1.69	2.00	1.78	1.55	1.64	1.48	2.23	2.77	3.85	3.88	2.44	.00	35.04
(2)	1.04	.74	.71	1.05	1.19	.82	.97	.87	.75	.80	.72	1.09	1.35	1.88	1.89	1.19	.00	17.07
8-12	84	43	123	153	110	63	23	22	22	49	80	113	164	316	228	70	0	1663
(1)	1.97	1.01	2.89	3.59	2.58	1.48	.54	.52	.52	1.15	1.88	2.65	3.85	7.42	5.35	1.64	.00	39.06
(2)	.96	.49	1.41	1.75	1.26	.72	.26	.25	.25	.56	.92	1.29	1.88	3.61	2.61	.80	.00	19.02
13-18	10	10	97	49	26	4	1	7	2	19	51	42	51	180	150	12	0	711
(1)	.23	.23	2.28	1.15	.61	.09	.02	.16	.05	.45	1.20	.99	1.20	4.23	3.52	.28	.00	16.70
(2)	.11	.11	1.11	.56	.30	.05	.01	.08	.02	.22	.58	.48	.58	2.06	1.72	.14	.00	8.13
19-24	1	0	16	3	6	0	1	1	0	7	5	12	7	37	32	0	0	128
(1)	.02	.00	.38	.07	.14	.00	.02	.02	.00	.16	.12	.28	.16	.87	.75	.00	.00	3.01
(2)	.01	.00	.18	.03	.07	.00	.01	.01	.00	.08	.06	.14	.08	.42	.37	.00	.00	1.46
GT 24	0	0	4	0	4	1	0	0	0	2	1	1	0	1	7	0	0	21
(1)	.00	.00	.09	.00	.09	.02	.00	.00	.00	.05	.02	.02	.00	.02	.16	.00	.00	.49
(2)	.00	.00	.05	.00	.05	.01	.00	.00	.00	.02	.01	.01	.00	.01	.08	.00	.00	.24
ALL SPEEDS	202	130	322	306	259	151	113	126	111	163	207	275	362	721	599	211	0	4258
(1)	4.74	3.05	7.56	7.19	6.08	3.55	2.65	2.96	2.61	3.83	4.86	6.46	8.50	16.93	14.07	4.96	.00	100.00
(2)	2.31	1.49	3.68	3.50	2.96	1.73	1.29	1.44	1.27	1.86	2.37	3.15	4.14	8.25	6.85	2.41	.00	48.70

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS E CLASS FREQUENCY (PERCENT) = 27.10

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	1	1	0	0	0	0	0	0	1	0	0	0	2	0	0	0	5
(1)	.00	.04	.04	.00	.00	.00	.00	.00	.00	.04	.00	.00	.00	.08	.00	.00	.00	.21
(2)	.00	.01	.01	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.02	.00	.00	.00	.06
C-3	27	14	12	9	12	18	15	17	25	28	33	47	77	57	48	29	0	468
(1)	1.14	.59	.51	.38	.51	.76	.63	.72	1.06	1.18	1.39	1.98	3.25	2.41	2.03	1.22	.00	19.76
(2)	.31	.16	.14	.10	.14	.21	.17	.19	.29	.32	.38	.54	.88	.65	.55	.33	.00	5.35
4-7	40	24	25	37	32	17	27	33	49	70	110	207	214	199	142	56	0	1282
(1)	1.69	1.01	1.06	1.56	1.35	.72	1.14	1.39	2.07	2.95	4.64	8.74	9.03	8.40	5.99	2.36	.00	54.12
(2)	.46	.27	.29	.42	.37	.19	.31	.38	.56	.80	1.26	2.37	2.45	2.28	1.62	.64	.00	14.66
8-12	2	6	14	24	15	11	9	12	9	23	80	109	79	71	41	7	0	512
(1)	.08	.25	.59	1.01	.63	.46	.38	.51	.38	.97	3.38	4.60	3.33	3.00	1.73	.30	.00	21.61
(2)	.02	.07	.16	.27	.17	.13	.10	.14	.10	.26	.92	1.25	.90	.81	.47	.08	.00	5.86
13-18	2	1	12	13	7	5	0	2	5	2	24	6	5	2	1	0	0	87
(1)	.08	.04	.51	.55	.30	.21	.00	.08	.21	.08	1.01	.25	.21	.08	.04	.00	.00	3.67
(2)	.02	.01	.14	.15	.08	.06	.00	.02	.06	.02	.27	.07	.06	.02	.01	.00	.00	1.00
19-24	0	0	0	6	7	0	0	0	0	0	0	0	0	0	0	0	0	13
(1)	.00	.00	.00	.25	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.55
(2)	.00	.00	.00	.07	.08	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.15
GT 24	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	2
(1)	.00	.00	.00	.00	.04	.04	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.08
(2)	.00	.00	.00	.00	.01	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.02
ALL SPEEDS	71	46	64	89	74	52	51	64	88	124	247	369	375	331	232	92	0	2369
(1)	3.00	1.94	2.70	3.76	3.12	2.20	2.15	2.70	3.71	5.23	10.43	15.58	15.83	13.97	9.79	3.88	.00	100.00
(2)	.81	.53	.73	1.02	.85	.59	.58	.73	1.01	1.42	2.83	4.22	4.29	3.79	2.65	1.05	.00	27.10

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS F CLASS FREQUENCY (PERCENT) = 8.17

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	1	1	0	1	0	0	0	0	0	0	0	2	0	1	0	0	0	6
(1)	.14	.14	.00	.14	.00	.00	.00	.00	.00	.00	.00	.28	.00	.14	.00	.00	.00	.84
(2)	.01	.01	.00	.01	.00	.00	.00	.00	.00	.00	.00	.02	.00	.01	.00	.00	.00	.07
C-3	10	5	5	9	8	2	6	3	10	28	36	43	71	62	32	11	0	341
(1)	1.40	.70	.70	1.26	1.12	.28	.84	.42	1.40	3.92	5.04	6.02	9.94	8.68	4.48	1.54	.00	47.76
(2)	.11	.06	.06	.10	.09	.02	.07	.03	.11	.32	.41	.49	.81	.71	.37	.13	.00	3.90
4-7	3	0	1	3	2	0	1	1	6	14	37	68	87	52	70	12	0	357
(1)	.42	.00	.14	.42	.28	.00	.14	.14	.84	1.96	5.18	9.52	12.18	7.28	9.80	1.68	.00	50.00
(2)	.03	.00	.01	.03	.02	.00	.01	.01	.07	.16	.42	.78	1.00	.59	.80	.14	.00	4.08
8-12	0	0	0	2	0	0	0	1	0	1	0	0	2	1	2	0	0	9
(1)	.00	.00	.00	.28	.00	.00	.00	.14	.00	.14	.00	.00	.28	.14	.28	.00	.00	1.26
(2)	.00	.00	.00	.02	.00	.00	.00	.01	.00	.01	.00	.00	.02	.01	.02	.00	.00	.10
13-18	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.00	.00	.00	.14	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.14
(2)	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	14	6	6	16	10	2	7	5	16	43	73	113	160	116	104	23	0	714
(1)	1.96	.84	.84	2.24	1.40	.28	.98	.70	2.24	6.02	10.22	15.83	22.41	16.25	14.57	3.22	.00	100.00
(2)	.16	.07	.07	.18	.11	.02	.08	.06	.18	.49	.83	1.29	1.83	1.33	1.19	.26	.00	8.17

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA STABILITY CLASS G CLASS FREQUENCY (PERCENT) = 6.38

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	2	1	0	1	0	0	0	0	0	0	1	0	0	0	1	1	0	7
(1)	.36	.18	.00	.18	.00	.00	.00	.00	.00	.00	.18	.00	.00	.00	.18	.18	.00	1.25
(2)	.02	.01	.00	.01	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.01	.01	.00	.08
C-3	7	5	6	6	3	6	0	0	3	12	27	60	133	113	21	13	0	415
(1)	1.25	.90	1.08	1.08	.54	1.08	.00	.00	.54	2.15	4.84	10.75	23.84	20.25	3.76	2.33	.00	74.37
(2)	.08	.06	.07	.07	.03	.07	.00	.00	.03	.14	.31	.69	1.52	1.29	.24	.15	.00	4.75
4-7	0	0	0	2	0	0	0	0	0	1	10	11	32	44	33	3	0	136
(1)	.00	.00	.00	.36	.00	.00	.00	.00	.00	.18	1.79	1.97	5.73	7.89	5.91	.54	.00	24.37
(2)	.00	.00	.00	.02	.00	.00	.00	.00	.00	.01	.11	.13	.37	.50	.38	.03	.00	1.56
8-12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
13-18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	9	6	6	9	3	6	0	0	3	13	38	71	165	157	55	17	0	558
(1)	1.61	1.08	1.08	1.61	.54	1.08	.00	.00	.54	2.33	6.81	12.72	29.57	28.14	9.86	3.05	.00	100.00
(2)	.10	.07	.07	.10	.03	.07	.00	.00	.03	.15	.43	.81	1.89	1.80	.63	.19	.00	6.38

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

43.0 FT WIND DATA

STABILITY CLASS ALL

CLASS FREQUENCY (PERCENT) = 100.00

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	3	3	1	3	0	0	0	0	0	1	1	2	0	3	1	1	0	19
(1)	.03	.03	.01	.03	.00	.00	.00	.00	.00	.01	.01	.02	.00	.03	.01	.01	.00	.22
(2)	.03	.03	.01	.03	.00	.00	.00	.00	.00	.01	.01	.02	.00	.03	.01	.01	.00	.22
C-3	61	37	43	32	32	38	25	40	59	84	104	162	303	255	119	78	0	1472
(1)	.70	.42	.49	.37	.37	.43	.29	.46	.67	.96	1.19	1.85	3.47	2.92	1.36	.89	.00	16.84
(2)	.70	.42	.49	.37	.37	.43	.29	.46	.67	.96	1.19	1.85	3.47	2.92	1.36	.89	.00	16.84
4-7	141	92	89	138	157	97	130	122	126	163	236	400	465	474	420	179	0	3429
(1)	1.61	1.05	1.02	1.58	1.80	1.11	1.49	1.40	1.44	1.86	2.70	4.58	5.32	5.42	4.80	2.05	.00	39.22
(2)	1.61	1.05	1.02	1.58	1.80	1.11	1.49	1.40	1.44	1.86	2.70	4.58	5.32	5.42	4.80	2.05	.00	39.22
8-12	91	50	146	207	182	107	85	57	39	97	206	269	289	470	315	87	0	2697
(1)	1.04	.57	1.67	2.37	2.08	1.22	.97	.65	.45	1.11	2.36	3.08	3.31	5.38	3.60	1.00	.00	30.85
(2)	1.04	.57	1.67	2.37	2.08	1.22	.97	.65	.45	1.11	2.36	3.08	3.31	5.38	3.60	1.00	.00	30.85
13-18	12	11	127	76	42	11	2	10	10	27	95	56	69	210	178	16	0	952
(1)	.14	.13	1.45	.87	.48	.13	.02	.11	.11	.31	1.09	.64	.79	2.40	2.04	.18	.00	10.89
(2)	.14	.13	1.45	.87	.48	.13	.02	.11	.11	.31	1.09	.64	.79	2.40	2.04	.18	.00	10.89
19-24	1	0	18	10	13	0	1	1	2	8	6	12	7	37	32	1	0	149
(1)	.01	.00	.21	.11	.15	.00	.01	.01	.02	.09	.07	.14	.08	.42	.37	.01	.00	1.70
(2)	.01	.00	.21	.11	.15	.00	.01	.01	.02	.09	.07	.14	.08	.42	.37	.01	.00	1.70
GT 24	0	0	4	0	5	2	0	0	0	2	2	1	0	1	8	0	0	25
(1)	.00	.00	.05	.00	.06	.02	.00	.00	.00	.02	.02	.01	.00	.01	.09	.00	.00	.29
(2)	.00	.00	.05	.00	.06	.02	.00	.00	.00	.02	.02	.01	.00	.01	.09	.00	.00	.29
ALL SPEEDS	309	193	428	466	431	255	243	230	236	382	650	902	1133	1450	1073	362	0	8743
(1)	3.53	2.21	4.90	5.33	4.93	2.92	2.78	2.63	2.70	4.37	7.43	10.32	12.96	16.58	12.27	4.14	.00	100.00
(2)	3.53	2.21	4.90	5.33	4.93	2.92	2.78	2.63	2.70	4.37	7.43	10.32	12.96	16.58	12.27	4.14	.00	100.00

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE

(2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD

C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS A CLASS FREQUENCY (PERCENT) = 1.61

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	MNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.00	.00	.71	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.71
(2)	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
4-7	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.71	.00	.00	.00	.00	.71
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.00	.01
8-12	0	0	1	3	9	9	15	1	0	3	3	3	1	1	0	1	0	50
(1)	.00	.00	.71	2.13	6.38	6.38	10.64	.71	.00	2.13	2.13	2.13	.71	.71	.00	.71	.00	35.46
(2)	.00	.00	.01	.03	.10	.10	.17	.01	.00	.03	.03	.03	.01	.01	.00	.01	.00	.57
13-18	1	0	3	5	5	8	9	10	3	0	2	6	5	7	4	1	0	69
(1)	.71	.00	2.13	3.55	3.55	5.67	6.38	7.09	2.13	.00	1.42	4.26	3.55	4.96	2.84	.71	.00	48.94
(2)	.01	.00	.03	.06	.06	.09	.10	.11	.03	.00	.02	.07	.06	.08	.05	.01	.00	.79
19-24	0	0	0	0	2	0	1	5	0	0	2	1	3	5	0	0	0	19
(1)	.00	.00	.00	.00	1.42	.00	.71	3.55	.00	.00	1.42	.71	2.13	3.55	.00	.00	.00	13.48
(2)	.00	.00	.00	.00	.02	.00	.01	.06	.00	.00	.02	.01	.03	.06	.00	.00	.00	.22
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.71	.00	.00	.00	.00	.71
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.00	.01
ALL SPEEDS	1	0	5	8	16	17	25	16	3	3	7	10	11	13	4	2	0	141
(1)	.71	.00	3.55	5.67	11.35	12.06	17.73	11.35	2.13	2.13	4.96	7.09	7.80	9.22	2.84	1.42	.00	100.00
(2)	.01	.00	.06	.09	.18	.19	.29	.18	.03	.03	.08	.11	.13	.15	.05	.02	.00	1.61

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS B CLASS FREQUENCY (PERCENT) = 2.45

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
4-7	2	0	0	0	2	0	1	0	0	0	2	0	1	0	0	0	0	8
(1)	.93	.00	.00	.00	.93	.00	.47	.00	.00	.00	.93	.00	.47	.00	.00	.00	.00	3.74
(2)	.02	.00	.00	.00	.02	.00	.01	.00	.00	.00	.02	.00	.01	.00	.00	.00	.00	.09
8-12	1	0	0	2	15	13	16	4	3	5	7	10	7	5	2	4	0	94
(1)	.47	.00	.00	.93	7.01	6.07	7.48	1.87	1.40	2.34	3.27	4.67	3.27	2.34	.93	1.87	.00	43.93
(2)	.01	.00	.00	.02	.17	.15	.18	.05	.03	.06	.08	.11	.08	.06	.02	.05	.00	1.08
13-18	0	0	4	9	4	1	3	4	2	4	14	4	4	18	10	1	0	82
(1)	.00	.00	1.87	4.21	1.87	.47	1.40	1.87	.93	1.87	6.54	1.87	1.87	8.41	4.67	.47	.00	38.32
(2)	.00	.00	.05	.10	.05	.01	.03	.05	.02	.05	.16	.05	.05	.21	.11	.01	.00	.94
19-24	0	0	2	2	1	0	0	0	0	1	4	1	5	5	6	2	0	29
(1)	.00	.00	.93	.93	.47	.00	.00	.00	.00	.47	1.87	.47	2.34	2.34	2.80	.93	.00	13.55
(2)	.00	.00	.02	.02	.01	.00	.00	.00	.00	.01	.05	.01	.06	.06	.07	.02	.00	.33
GT 24	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	1
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.47	.00	.00	.00	.00	.00	.00	.00	.47
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.01
ALL SPEEDS	3	0	6	13	22	14	20	8	5	11	27	15	17	28	18	7	0	214
(1)	1.40	.00	2.80	6.07	10.28	6.54	9.35	3.74	2.34	5.14	12.62	7.01	7.94	13.08	8.41	3.27	.00	100.00
(2)	.03	.00	.07	.15	.25	.16	.23	.09	.06	.13	.31	.17	.19	.32	.21	.08	.00	2.45

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS C CLASS FREQUENCY (PERCENT) = 5.59

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	2
(1)	.20	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.20	.00	.00	.41
(2)	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.00	.00	.02
4-7	2	3	1	0	8	1	2	0	3	1	4	2	1	6	0	2	0	36
(1)	.41	.61	.20	.00	1.64	.20	.41	.00	.61	.20	.82	.41	.20	1.23	.00	.41	.00	7.36
(2)	.02	.03	.01	.00	.09	.01	.02	.00	.03	.01	.05	.02	.01	.07	.00	.02	.00	.41
8-12	4	1	4	17	19	21	22	12	3	11	15	22	17	26	17	4	0	215
(1)	.82	.20	.82	3.48	3.89	4.29	4.50	2.45	.61	2.25	3.07	4.50	3.48	5.32	3.48	.82	.00	43.97
(2)	.05	.01	.05	.19	.22	.24	.25	.14	.03	.13	.17	.25	.19	.30	.19	.05	.00	2.46
13-18	1	2	10	3	4	3	3	9	0	10	23	21	23	50	19	7	0	188
(1)	.20	.41	2.04	.61	.82	.61	.61	1.84	.00	2.04	4.70	4.29	4.70	10.22	3.89	1.43	.00	38.45
(2)	.01	.02	.11	.03	.05	.03	.03	.10	.00	.11	.26	.24	.26	.57	.22	.08	.00	2.15
19-24	0	0	3	0	0	0	0	1	1	2	6	1	4	13	8	0	0	39
(1)	.00	.00	.61	.00	.00	.00	.00	.20	.20	.41	1.23	.20	.82	2.66	1.64	.00	.00	7.98
(2)	.00	.00	.03	.00	.00	.00	.00	.01	.01	.02	.07	.01	.05	.15	.09	.00	.00	.45
GT 24	0	0	0	0	0	0	0	0	2	1	1	0	2	1	2	0	0	9
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.41	.20	.20	.00	.41	.20	.41	.00	.00	1.84
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.02	.01	.01	.00	.02	.01	.02	.00	.00	.10
ALL SPEEDS	8	6	18	20	31	25	27	22	9	25	49	46	47	96	47	13	0	489
(1)	1.64	1.23	3.68	4.09	6.34	5.11	5.52	4.50	1.84	5.11	10.02	9.41	9.61	19.63	9.61	2.66	.00	100.00
(2)	.09	.07	.21	.23	.35	.29	.31	.25	.10	.29	.56	.53	.54	1.10	.54	.15	.00	5.59

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS D CLASS FREQUENCY (PERCENT) = 48.70

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.00	.00	.00	.00	.02	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.02
(2)	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
C-3	6	4	7	8	9	6	18	9	7	4	4	3	9	4	5	8	0	111
(1)	.14	.09	.16	.19	.21	.14	.42	.21	.16	.09	.09	.07	.21	.09	.12	.19	.00	2.61
(2)	.07	.05	.08	.09	.10	.07	.21	.10	.08	.05	.05	.03	.10	.05	.06	.09	.00	1.27
4-7	35	35	29	67	45	51	68	42	41	26	25	36	35	59	68	37	0	699
(1)	.82	.82	.68	1.57	1.06	1.20	1.60	.99	.96	.61	.59	.85	.82	1.39	1.60	.87	.00	16.42
(2)	.40	.40	.33	.77	.51	.58	.78	.48	.47	.30	.29	.41	.40	.68	.78	.42	.00	8.00
8-12	99	54	70	113	85	99	76	68	44	56	84	84	108	159	141	98	0	1438
(1)	2.33	1.27	1.64	2.66	2.00	2.33	1.79	1.60	1.03	1.32	1.97	1.97	2.54	3.74	3.31	2.30	.00	33.79
(2)	1.13	.62	.80	1.29	.97	1.13	.87	.78	.50	.64	.96	.96	1.24	1.82	1.61	1.12	.00	16.45
13-18	87	51	91	84	35	21	7	23	18	30	80	79	128	293	182	40	0	1249
(1)	2.04	1.20	2.14	1.97	.82	.49	.16	.54	.42	.70	1.88	1.86	3.01	6.88	4.28	.94	.00	29.35
(2)	1.00	.58	1.04	.96	.40	.24	.08	.26	.21	.34	.92	.90	1.46	3.35	2.08	.46	.00	14.29
19-24	16	21	53	27	22	7	1	5	5	14	46	29	52	157	93	3	0	551
(1)	.38	.49	1.25	.63	.52	.16	.02	.12	.12	.33	1.08	.68	1.22	3.69	2.19	.07	.00	12.95
(2)	.18	.24	.61	.31	.25	.08	.01	.06	.06	.16	.53	.33	.59	1.80	1.06	.03	.00	6.30
GT 24	1	8	19	3	10	1	2	3	0	9	8	19	20	64	40	0	0	207
(1)	.02	.19	.45	.07	.23	.02	.05	.07	.00	.21	.19	.45	.47	1.50	.94	.00	.00	4.86
(2)	.01	.09	.22	.03	.11	.01	.02	.03	.00	.10	.09	.22	.23	.73	.46	.00	.00	2.37
ALL SPEEDS	244	173	269	302	207	185	172	150	115	139	247	250	352	736	529	186	0	4256
(1)	5.73	4.06	6.32	7.10	4.86	4.35	4.04	3.52	2.70	3.27	5.80	5.87	8.27	17.29	12.43	4.37	.00	100.00
(2)	2.79	1.98	3.08	3.46	2.37	2.12	1.97	1.72	1.32	1.59	2.83	2.86	4.03	8.42	6.05	2.13	.00	48.70

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS E CLASS FREQUENCY (PERCENT) = 27.09

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.00	.00	.00	.00	.04	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.04
(2)	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
C-3	3	1	8	7	13	12	6	5	1	4	2	3	6	5	5	3	0	84
(1)	.13	.04	.34	.30	.55	.51	.25	.21	.04	.17	.08	.13	.25	.21	.21	.13	.00	3.55
(2)	.03	.01	.09	.08	.15	.14	.07	.06	.01	.05	.02	.03	.07	.06	.06	.03	.00	.96
4-7	18	23	15	18	10	21	35	27	22	26	29	34	24	32	24	15	0	373
(1)	.76	.97	.63	.76	.42	.89	1.48	1.14	.93	1.10	1.22	1.44	1.01	1.35	1.01	.63	.00	15.75
(2)	.21	.26	.17	.21	.11	.24	.40	.31	.25	.30	.33	.39	.27	.37	.27	.17	.00	4.27
8-12	42	34	25	21	14	16	11	29	55	64	103	125	100	155	107	64	0	965
(1)	1.77	1.44	1.06	.89	.59	.68	.46	1.22	2.32	2.70	4.35	5.28	4.22	6.55	4.52	2.70	.00	40.75
(2)	.48	.39	.29	.24	.16	.18	.13	.33	.63	.73	1.18	1.43	1.14	1.77	1.22	.73	.00	11.04
13-18	7	13	17	16	19	6	2	17	24	30	128	130	126	150	93	16	0	794
(1)	.30	.55	.72	.68	.80	.25	.08	.72	1.01	1.27	5.41	5.49	5.32	6.33	3.93	.68	.00	33.53
(2)	.08	.15	.19	.18	.22	.07	.02	.19	.27	.34	1.46	1.49	1.44	1.72	1.06	.18	.00	9.08
19-24	1	3	9	14	8	8	0	8	4	3	27	13	19	9	3	1	0	130
(1)	.04	.13	.38	.59	.34	.34	.00	.34	.17	.13	1.14	.55	.80	.38	.13	.04	.00	5.49
(2)	.01	.03	.10	.16	.09	.09	.00	.09	.05	.03	.31	.15	.22	.10	.03	.01	.00	1.49
GT 24	1	0	2	4	8	2	0	1	0	0	2	0	1	0	0	0	0	21
(1)	.04	.00	.08	.17	.34	.08	.00	.04	.00	.00	.08	.00	.04	.00	.00	.00	.00	.89
(2)	.01	.00	.02	.05	.09	.02	.00	.01	.00	.00	.02	.00	.01	.00	.00	.00	.00	.24
ALL SPEEDS	72	74	76	80	73	65	54	87	106	127	291	305	276	351	232	99	0	2368
(1)	3.04	3.13	3.21	3.38	3.08	2.74	2.28	3.67	4.48	5.36	12.29	12.88	11.66	14.82	9.80	4.18	.00	100.00
(2)	.82	.85	.87	.92	.84	.74	.62	1.00	1.21	1.45	3.33	3.49	3.16	4.02	2.65	1.13	.00	27.09

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS F CLASS FREQUENCY (PERCENT) = 8.17

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
C-3	3	2	2	2	2	4	3	3	2	2	1	2	2	0	3	0	0	33
(1)	.42	.28	.28	.28	.28	.56	.42	.42	.28	.28	.14	.28	.28	.00	.42	.00	.00	4.62
(2)	.03	.02	.02	.02	.02	.05	.03	.03	.02	.02	.01	.02	.02	.00	.03	.00	.00	.38
4-7	7	15	7	3	0	3	4	6	13	13	17	7	10	12	8	8	0	133
(1)	.98	2.10	.98	.42	.00	.42	.56	.84	1.82	1.82	2.38	.98	1.40	1.68	1.12	1.12	.00	18.63
(2)	.08	.17	.08	.03	.00	.03	.05	.07	.15	.15	.19	.08	.11	.14	.09	.09	.00	1.52
8-12	38	7	5	3	0	0	1	8	15	28	49	46	43	53	35	22	0	353
(1)	5.32	.98	.70	.42	.00	.00	.14	1.12	2.10	3.92	6.86	6.44	6.02	7.42	4.90	3.08	.00	49.44
(2)	.43	.08	.06	.03	.00	.00	.01	.09	.17	.32	.56	.53	.49	.61	.40	.25	.00	4.04
13-18	13	0	0	1	1	0	0	2	1	10	28	22	43	30	31	11	0	193
(1)	1.82	.00	.00	.14	.14	.00	.00	.28	.14	1.40	3.92	3.08	6.02	4.20	4.34	1.54	.00	27.03
(2)	.15	.00	.00	.01	.01	.00	.00	.02	.01	.11	.32	.25	.49	.34	.35	.13	.00	2.21
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	2
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.14	.14	.00	.00	.28
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.01	.00	.00	.02
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	61	24	14	9	3	7	8	19	31	53	95	77	98	96	78	41	0	714
(1)	8.54	3.36	1.96	1.26	.42	.98	1.12	2.66	4.34	7.42	13.31	10.78	13.73	13.45	10.92	5.74	.00	100.00
(2)	.70	.27	.16	.10	.03	.08	.09	.22	.35	.61	1.09	.88	1.12	1.10	.89	.47	.00	8.17

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA STABILITY CLASS G CLASS FREQUENCY (PERCENT) = 6.38

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	1
(1)	.00	.00	.00	.00	.18	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.18
(2)	.00	.00	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
C-3	2	1	3	6	2	2	0	1	4	1	3	1	0	2	1	0	0	29
(1)	.36	.18	.54	1.08	.36	.36	.00	.18	.72	.18	.54	.18	.00	.36	.18	.00	.00	5.20
(2)	.02	.01	.03	.07	.02	.02	.00	.01	.05	.01	.03	.01	.00	.02	.01	.00	.00	.33
4-7	12	7	11	2	3	0	4	5	16	14	21	25	21	31	15	13	0	200
(1)	2.15	1.25	1.97	.36	.54	.00	.72	.90	2.87	2.51	3.76	4.48	3.76	5.56	2.69	2.33	.00	35.84
(2)	.14	.08	.13	.02	.03	.00	.05	.06	.18	.16	.24	.29	.24	.35	.17	.15	.00	2.29
8-12	23	6	6	1	0	1	1	2	8	10	35	23	27	43	40	28	0	254
(1)	4.12	1.08	1.08	.18	.00	.18	.18	.36	1.43	1.79	6.27	4.12	4.84	7.71	7.17	5.02	.00	45.52
(2)	.26	.07	.07	.01	.00	.01	.01	.02	.09	.11	.40	.26	.31	.49	.46	.32	.00	2.91
13-18	7	2	2	0	0	0	0	0	1	1	6	6	11	14	17	7	0	74
(1)	1.25	.36	.36	.00	.00	.00	.00	.00	.18	.18	1.08	1.08	1.97	2.51	3.05	1.25	.00	13.26
(2)	.08	.02	.02	.00	.00	.00	.00	.00	.01	.01	.07	.07	.13	.16	.19	.08	.00	.85
19-24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
GT 24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
(1)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
(2)	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
ALL SPEEDS	44	16	22	9	6	3	5	8	29	26	65	55	59	90	73	48	0	558
(1)	7.89	2.87	3.94	1.61	1.08	.54	.90	1.43	5.20	4.66	11.65	9.86	10.57	16.13	13.08	8.60	.00	100.00
(2)	.50	.18	.25	.10	.07	.03	.06	.09	.33	.30	.74	.63	.68	1.03	.84	.55	.00	6.38

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C= CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

SEABROOK JAN00-DEC00 MET DATA JOINT FREQUENCY DISTRIBUTION (210-FOOT TOWER)

209.0 FT WIND DATA

STABILITY CLASS ALL

CLASS FREQUENCY (PERCENT) = 100.00

WIND DIRECTION FROM

SPEED MPH	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	VRBL	TOTAL
CALM	0	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0	0	3
(1)	.00	.00	.00	.00	.03	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.03
(2)	.00	.00	.00	.00	.03	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.03
C-3	15	8	21	23	26	24	27	18	14	11	10	9	17	11	15	11	0	260
(1)	.17	.09	.24	.26	.30	.27	.31	.21	.16	.13	.11	.10	.19	.13	.17	.13	.00	2.97
(2)	.17	.09	.24	.26	.30	.27	.31	.21	.16	.13	.11	.10	.19	.13	.17	.13	.00	2.97
4-7	76	83	63	90	68	76	114	80	95	80	98	104	93	140	115	75	0	1450
(1)	.87	.95	.72	1.03	.78	.87	1.30	.92	1.09	.92	1.12	1.19	1.06	1.60	1.32	.86	.00	16.59
(2)	.87	.95	.72	1.03	.78	.87	1.30	.92	1.09	.92	1.12	1.19	1.06	1.60	1.32	.86	.00	16.59
8-12	207	102	111	160	142	159	142	124	128	177	296	313	303	442	342	221	0	3369
(1)	2.37	1.17	1.27	1.83	1.62	1.82	1.62	1.42	1.46	2.03	3.39	3.58	3.47	5.06	3.91	2.53	.00	38.55
(2)	2.37	1.17	1.27	1.83	1.62	1.82	1.62	1.42	1.46	2.03	3.39	3.58	3.47	5.06	3.91	2.53	.00	38.55
13-18	116	68	127	118	68	39	24	65	49	85	281	268	340	562	356	83	0	2649
(1)	1.33	.78	1.45	1.35	.78	.45	.27	.74	.56	.97	3.22	3.07	3.89	6.43	4.07	.95	.00	30.31
(2)	1.33	.78	1.45	1.35	.78	.45	.27	.74	.56	.97	3.22	3.07	3.89	6.43	4.07	.95	.00	30.31
19-24	17	24	67	43	33	15	2	19	10	20	85	45	83	190	111	6	0	770
(1)	.19	.27	.77	.49	.38	.17	.02	.22	.11	.23	.97	.51	.95	2.17	1.27	.07	.00	8.81
(2)	.19	.27	.77	.49	.38	.17	.02	.22	.11	.23	.97	.51	.95	2.17	1.27	.07	.00	8.81
GT 24	2	8	21	7	18	3	2	4	2	11	11	19	24	65	42	0	0	239
(1)	.02	.09	.24	.08	.21	.03	.02	.05	.02	.13	.13	.22	.27	.74	.48	.00	.00	2.73
(2)	.02	.09	.24	.08	.21	.03	.02	.05	.02	.13	.13	.22	.27	.74	.48	.00	.00	2.73
ALL SPEEDS	433	293	410	441	358	316	311	310	298	384	781	758	860	1410	981	396	0	8740
(1)	4.95	3.35	4.69	5.05	4.10	3.62	3.56	3.55	3.41	4.39	8.94	8.67	9.84	16.13	11.22	4.53	.00	100.00
(2)	4.95	3.35	4.69	5.05	4.10	3.62	3.56	3.55	3.41	4.39	8.94	8.67	9.84	16.13	11.22	4.53	.00	100.00

(1)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PAGE
 (2)=PERCENT OF ALL GOOD OBSERVATIONS FOR THIS PERIOD
 C=CALM (WIND SPEED LESS THAN OR EQUAL TO .95 MPH)

ENCLOSURE 3 TO NYN-01038

Radiation Dose Assessment

**Seabrook Station
Radiological Effluent Impact Assessment For 2000
(Annual Radioactive Effluent Release Report)**

I. Summary

Seabrook Technical Specification Sections 6.7.6.g.4 & 9 require that limitations be placed on the quarterly and annual doses or dose commitments to Members of the Public from radioactive materials in liquid and gaseous effluents released from the station to Unrestricted Areas at or beyond the site boundary conforming to the dose objectives of Appendix I to 10 CFR Part 50. Technical Specification 6.7.6.g.8 requires limitations on the quarterly and annual air doses resulting from noble gases released in gaseous effluents to areas beyond the site boundary also conform to Appendix I to 10 CFR Part 50. In a similar fashion, Technical Specification 6.7.6.g.11 requires limitations on the annual dose or dose commitment to any Member of the Public due to radioactivity and radiation from uranium fuel cycle sources conforming to the EPA Radiation Standards in 40 CFR Part 190. The following table details the above referenced effluent dose limits.

DOSE OBJECTIVE CRITERIA FOR COMPLIANCE

EFFLUENT TYPE	DOSE TYPE	QUARTERLY LIMITS	ANNUAL LIMITS
LIQUIDS (10CFR50, APP. I)	Total Body	1.5 mrem	3 mrem
	Max. Organ	5 mrem	10 mrem
NOBLE GAS (10CFR50, APP. I)	Gamma Air	5 mrad	10 mrad
	Beta Air	10 mrad	20 mrad
GAS PARTICULATE (10CFR50, APP. I)	Max. Organ	7.5 mrem	15 mrem
TOTAL DOSE (40CFR190) [liquids, gas, direct]	Total Body & organ	---	25 mrem
	Thyroid	---	75 mrem

Technical Specification 6.8.1.4 and the Seabrook Offsite Dose Calculation Manual (ODCM) Part A, Section 10.2, provides that the Station's Annual Radioactive Effluent Release Report include a demonstration of compliance with the above off-site dose limitations, as well as the determination of dose impacts to Members of the Public who may be associated with permitted activities inside the site boundary.

Doses resulting from actual liquid and gaseous effluents from Seabrook Station during 2000 were calculated in accordance with Method II as defined in the Station Offsite Dose Calculation Manual. The calculation methods follow the models in Regulatory Guide 1.109 (Reference 1). The assessments included maximum whole body doses and organ doses from all liquid releases, maximum offsite organ doses resulting from airborne iodines, tritium and particulate radionuclides with half-lives greater than eight days, and maximum offsite beta air and gamma air doses from airborne noble gases. In addition, the

potential direct dose from fixed radiation sources from plant operations was evaluated as part of the assessment required under 40 CFR part 190 for doses from the uranium fuel cycle.

Doses were also calculated for the special receptor locations inside the site boundary where the public can have access for recreational or educational purposes. The Science and Nature Center is located in the southwest portion of the site and offers educational opportunities on nuclear power and the environment. The "Rocks" is an area northeast of the main plant facilities where the public has access to Brown's Creek and the tidal marsh that borders the site.

All calculated liquid and gaseous pathway doses for the 2000 reporting period are well below the dose criteria of 10CFR50, Appendix I, and the dose limits for effluent releases stated in the ODCM. In addition, the total dose to the most limiting Member of the Public due to the combined exposure to plant-related direct radiation, and liquid and gaseous effluents, was below the dose standards of 40CFR190.

II. Method for Calculating the Total Body and Maximum Organ Doses Resulting from Liquid Releases

Liquid waste generated during plant operations is processed and discharged to the environment via the station's circulating water cooling system. The cooling system utilizes an offshore submerged multiport diffuser discharge for rapid dissipation and mixing of liquid effluents in the ocean environment. A 22-port diffuser section of the discharge system is located in approximately 50 to 60 feet of water with each nozzle 7 to 10 feet above the sea floor. Eleven riser shafts with two diffuser nozzles each for the diffuser and are spaced about 100 feet apart over a distance of about 1000 feet. Water is discharged in a generally eastward direction away from the shoreline through the multiport diffuser, beginning at a location over one mile off-shore. During power operations, these high velocity jets passively entrain about ten volumes of fresh water into the near field jet mixing region before the plume reaches the water surface. This arrangement also effectively prevents the discharge plume (at least to the 1 degree or 40 to 1 dilution isopleth) from impacting the shoreline over the tidal cycle.

During shutdown periods, the high velocity jet mixing created by the normal circulating water flow at the diffuser nozzles is reduced. However, mixing within the discharge tunnel water volume is significantly increased due to the long transit time for batch discharges to travel the three miles from the plant through the 19-foot diameter tunnels to the diffuser nozzles. Additional mixing of the effluent in the near field assures that an equivalent overall 10 to 1 dilution occurs by the time reaches the ocean surface.

The exposure pathways considered in the calculations of total body and maximum organ doses resulting from liquid discharges from Seabrook Station are limited to ingestion of aquatic foods and exposure to shoreline deposits. The dose calculations do not include the ingestion of potable water or irrigated vegetation as potential exposure pathways because the liquid effluents from the plant are discharged into salt water.

The dose assessment models utilized in the Offsite Dose Calculation Manual (ODCM) (Reference 2) are taken from Regulatory Guide 1.109 (Reference 1). The total body and organ doses are evaluated for each of four age groups (i.e., infant, child, teen and adult) to determine the maximum total body dose and maximum organ dose via all existing exposure pathways (i.e., fish and aquatic invertebrate ingestion, and shoreline exposure) to an age-dependent individual from all detected radionuclides in plant releases. The values for the various factors considered in the model equations are provided in Regulatory Guide 1.109 and the ODCM (see Table D). The flow rate of the liquid effluent (F) and the radionuclide activities (Q_i) are measured specifically prior to each liquid release. The values for half-lives for radionuclides ($T_{1/2}$) and their radioactive decay constants (λ_i) have been taken from Kocher (Reference 3).

Table A presents the calculated liquid pathway doses for each calendar quarter and total for the year. The calculated annual doses as a percent of the applicable regulatory limits are shown in Table C. The estimated quarterly and annual doses resulting from liquid effluents to members of the public are well below all dose limit criteria.

III. Method for Calculating the Gamma and Beta Air Doses from Noble Gases

Gamma and beta air doses due to noble gases in gaseous effluents are calculated for several receptor locations when noble gases are recorded in effluents. Those locations include the points of estimated highest off-site ground level air concentration of radioactive material, site boundary (or closest point on the opposite shoreline in directions which are bordered by the tidal marsh), nearest resident, nearest vegetable garden, and nearest milk animal within five miles for each of the sixteen principle compass directions. The special on-site receptor locations (Science and Nature Center and the "Rocks") are also included.

Atmospheric dispersion factors (i.e., X/Q factors) calculated from recorded concurrent site meteorological data (i.e., meteorological data measurements taken during the time of the release) are used in the estimation of receptor specific air concentrations due to station effluents. The atmospheric dispersion estimations utilize methodology generally consistent with US NRC Regulatory Guide 1.111 (Reference 4). Beta air doses use undepleted X/Q's and assume a semi-infinite plume at the point of exposure. Gamma air doses are calculated using the finite cloud model presented in "Meteorology and Atomic Energy – 1968" (Reference 5). That model is implemented through the definition of an effective gamma atmospheric dispersion factor $[X/Q']$ (Reference 6) and the replacement of the undepleted X/Q in the infinite cloud dose equation by $[X/Q']$.

The release point of effluents is also considered in the atmospheric dispersion calculation. The primary vent stack is treated as a "mixed-mode" release, as defined in Regulatory Guide 1.111. These effluents are considered to be part-time ground level / part-time elevated releases depending on the ratio of primary vent stack exit velocity relative to the speed of prevailing wind. All other release points (e.g., Turbine Building and Chemistry lab hoods) are considered ground-level releases. The beta air and gamma air dose calculations are consistent with the models presented in Regulatory Guide 1.109 (Reference 1). The values for the dose factors, DF_i^γ and DF_i^β , have been taken from Table B-1 in Regulatory Guide 1.109.

Table A presents the calculated maximum off-site gamma air and beta air doses for each calendar quarter and year. The calculated annual doses as a percent of the applicable regulatory limit are shown in Table C. The estimated quarterly and annual air doses resulting from noble gas effluents are well below all dose limit criteria.

IV. Method for Calculating the Critical Organ Dose Resulting from Iodines, Tritium and Particulates with T 1/2 Greater than 8 Days in Gaseous Releases

Regulatory Guide 1.109 dose models are applied in the calculation of the critical organ doses from iodines, tritium and particulate radionuclides released into the atmosphere during the reporting period. Atmospheric dispersion and deposition factors (i.e., depleted X/Q and D/Q factors) calculated with concurrent meteorological data (i.e., meteorological data measurements taken during the time of the release) are used in the determination of gaseous pathway doses. The dispersion models are described in Section B.7.3.2 & .3 of the Seabrook ODCM.

Potential exposure pathways associated with gaseous effluent are (i) external irradiation from radioactivity deposited on the ground surface, (ii) inhalation, and (iii) ingestion of vegetables (both fresh leafy and stored), meat, and milk. Dose estimates were determined for the site boundary and for the locations of the nearest resident, vegetable garden, and milk animal in each of the sixteen principle compass directions. The locations of the nearest resident, vegetable garden and milk animal in each sector were identified by the 2000 Annual Land Use Census as required by ODCM Control C.9.2.1 (see Table F). Additionally, doses were calculated at the point of approximate maximum ground level air concentration of radioactive materials in gaseous effluent. Conservatism in the dose estimates was maintained by assuming that the vegetable garden pathway was active at each milk animal location. Though not required to be part of the land use census, meat animal (cattle) locations are included in the assessment when identified. Meat and milk animals were assumed to receive their entire intake from pasture during the second and third quarters. This is a conservative assumption because most dairy operations utilize supplemental feeding when animals are on pasture, or actually restrict animals to full time silage feeding throughout the entire year. Table E provides the reference sources for dose model parameter assumptions used in the dose assessment.

The maximum organ doses were determined by summing the contributions from all exposure pathways at each location, and sorting in descending order. Doses were calculated for the whole body, GI-LLI, bone, liver, kidney, thyroid, lung, and skin for adults, teenagers, children, and infants. The estimated quarterly and annual organ doses due to iodines, tritium and particulates at the location of the maximally exposed individual are reported in Table A.

The estimated organ doses from iodines, tritium and particulates in gaseous effluents are well below the 10CFR50, Appendix I dose criteria for the reporting period (See Table C for calculated dose as a percentage of annual limit).

V. Total Dose (40 CFR Part 190)

40 CFR 190 states that the annual dose equivalent should not exceed 25 mrem to the whole body, 75 mrem to the Thyroid, or 25 mrem to any other organ of any Member of the Public from all uranium fuel cycle sources. To show compliance with this standard, the maximum doses for both the liquid and gaseous pathways from Seabrook Station are added together with the whole body dose from noble gas releases and any direct radiation component attributed to plant fixed sources to the maximum receptor location. Since there are no other uranium fuel cycle facilities within five miles of Seabrook, no additional impacts from sources beyond Seabrook Station need be considered.

The sum of the maximum annual whole body doses to Members of the Public from all exposure pathways for liquid and gaseous effluents, plus the direct external dose from station fixed sources, was 2.10E-02 mrem to a hypothetical individual at or beyond the site boundary. The maximum organ dose (including the thyroid) to any age group from all exposure pathways including direct radiation was 2.34E-02 mrem.

Table B illustrates the total dose projections from station sources to the maximum potential off-site individual for the year 2000 and demonstrates compliance with the EPA's environmental radiation standard for the uranium fuel cycle per 10 CFR Part 190 (See Table C for total dose as a percentage of annual limit).

VI. References

1. Regulatory Guide 1.109, Revision 1, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purposes of Evaluating Compliance with 10CFR Part 50, Appendix I", USNRC, October 1977.
2. Seabrook Station Offsite Dose Calculation Manual (ODCM), Revision 21.
3. Kocher, D.C., Dose-Rate Conversion Factors for Exposure to Photons and Electrons, Health Physics, Vol. 45, No. 3, Sept. 1983.
4. Regulatory Guide 1.111, Revision 1, "Method for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water Cooled Reactors", USNRC, July 1977.
5. Slade, D.H., "Meteorology and Atomic Energy – 1968", USAEC, July 1968.
6. Hamawi, J.N., "AEOLUS-2 A computer Code for the Determination of Continuous and Intermittent-Release Atmospheric Dispersion and Deposition of Nuclear Power Plant Effluents in Open-Terrain Sites, Coastal Sites, and Deep-River Valleys for the Assessment of Ensuing Doses and Finite-Cloud Gamma Radiation Exposures", Entech Engineering, Inc., March 1988.

Table A

Seabrook Station
2000 Annual Radioactive Effluent Release Report

Maximum^(a) Off-Site Doses and Dose Commitments to Members of the Public

Release Type		Dose (mrem) ^(b)				
		1 st Quarter	2nd Quarter	3rd Quarter	4th Quarter	Year ^(c)
Liquid Effluents:						
	Total Body Dose	3.15E-05 (1)	1.25E-04 (1)	3.71E-04 (1)	4.00E-04 (1)	9.28E-04
	Organ Dose	9.88E-05 (3)	2.58E-04 (2)	5.83E-04 (3)	2.35E-03 (3)	3.29E-03
Airborne Effluents:						
	Organ Dose from Iodines, Tritium, and Particulates	3.58E-03 (4)	7.86E-03 (4)	4.24E-03 (4)	4.32E-03 (5)	2.00E-02
Noble Gases	Beta Air (mrad)	2.09E-07 (6)	3.83E-06 (7)	7.18E-06 (9)	6.60E-05 (10)	7.72E-05
	Gamma Air (mrad)	6.06E-07 (6)	1.42E-05 (8)	1.62E-05 (9)	1.48E-04 (11)	1.79E-04
Doses (mrem) at Receptor Locations Inside Site Boundary ^(d) :						
Science and Nature Center (SW, 488m):						
	Beta Air Dose (mrad)	0.00E+00	0.00E+00	6.01E-10	1.02E-07	1.03E-07
	Gamma Air Dose (mrad)	0.00E+00	0.00E+00	1.76E-08	1.46E-07	1.64E-07
	Organ Dose (mrem)	2.90E-06 (12)	6.31E-06 (12)	3.22E-06 (12)	9.83E-07 (13)	1.34E-05
The "Rocks" (NE/ENE, 244m):						
	Beta Air Dose (mrad)	0.00E+00	2.50E-06	1.06E-06	1.22E-05	1.58E-05
	Gamma Air Dose (mrad)	0.00E+00	1.37E-06	7.39E-07	7.44E-06	9.55E-06
	Organ Dose (mrem)	1.20E-04 (12)	1.44E-04 (12)	1.46E-04 (12)	1.44E-04 (12)	5.54E-04
Direct Dose From Plant Operation ^(e)					0	

Table A (continued)

Seabrook Station
2000 Annual Radioactive Effluent Release Report

Maximum^(a) Off-Site Doses and Dose Commitments to Members of the Public

NOTES:

- (a) "Maximum means the largest fraction of corresponding 10CFR50, Appendix I, dose design objective.
- (b) The numbered footnotes indicate the age group, organ, and location (compass sector and distance from stack in meters) of the dose receptor, where appropriate.
 - (1) Adult.
 - (2) Bone of a child, & GI-LLI of an adult
 - (3) GI-LLI of an adult.
 - (4) Liver, kidney, lung, GI-LLI, thyroid, and whole body of a child, SW 1130m.
 - (5) Thyroid of a child, SE 2357 m.
 - (6) SSE 914 m.
 - (7) NE 2276 m.
 - (8) ENE 2276 m.
 - (9) NNW 914 m.
 - (10) WSW 1022 m.
 - (11) S 930 m.
 - (12) Liver, kidney, lung, GILII, thyroid, and whole body of a teen
 - (13) Thyroid of a teen
- (c) "Maximum" dose for the year is the sum of the maximum doses for each quarter. This results in a conservative yearly dose estimate, but still well within the limits of 10CFR50.
- (d) For each special receptor location, the whole body and organ doses calculated for the airborne effluent releases were adjusted by the occupancy factor provided in Seabrook's ODCM (i.e., 0.0014 for the Science and Nature Center and 0.0076 for the "Rocks").
- (e) Only station sources are considered since there are no other facilities within five miles of Seabrook Station. 2000 data for the closest off-site environmental TLD locations in each sector (as listed in Table B.4-1 of Seabrook's ODCM) were compared to preoperation data from 1986-1988 for the same locations. No statistical difference which could be attributed to station sources was identified.

Table B
 Seabrook Station
 2000 Annual Radioactive Effluent Release Report

Total Dose to Maximum Off-Site Individual
(40CFR190)

Release Source	Total Body (mrem)	Maximum Organ(a) (mrem)
Liquids	9.28E-04	3.29E-03
Noble Gases	1.19E-04	1.19E-04
Gas Iodines, Tritium & Particulates	2.00E-02	2.00E-02
Direct Radiation	0.00E+00	0.00E+00
Annual Total	2.10E-02	2.34E-02

(a) Maximum organ includes consideration of the thyroid.

Table C

Seabrook Station
2000 Annual Radioactive Effluent Release Report

Calculated 2000 Maximum Doses Versus Applicable Limits

Receptor	Applicable ODCM Control	ODCM Annual Limit	Calculated Annual (2000) Dose	Percent of Limit
Offsite				
Liquid Effluents				
Whole Body Dose	C.6.2.1.b	3 mrem	9.28E-04 mrem	0.03%
Organ Dose	C.6.2.1.b	10 mrem	3.29E-03 mrem	0.03%
Airborne Effluents				
Organ Dose (iodines, tritium, and part.)	C.7.3.1.b	15 mrem	2.00E-02 mrem	0.13%
Gamma Air Dose (noble gases)	C.7.2.1.b	10 mrad	1.79E-04 mrad	0.002%
Beta Air Dose (noble gases)	C.7.2.1.b	20 mrad	7.72E-05 mrad	0.0004%
All Plant Sources (a)				
Whole Body Dose	C.8.1.1	25 mrem	2.10E-02 mrem	0.08%
Organ Dose	C.8.1.1	25 mrem	2.34E-02 mrem	0.09%
Onsite (Science and Nature Center, 488m SW)				
Airborne Effluents				
Organ Dose (iodines, tritium, and part.)	C.7.3.1.b(b)	15 mrem	1.34E-05 mrem	0.0001%
Gamma Air Dose (noble gases)	C.7.2.1.b(b)	10 mrad	1.64E-07 mrad	0.000002%
Beta Air Dose (noble gases)	C.7.2.1.b(b)	20 mrad	1.03E-07 mrad	0.0000005%
Onsite (The "Rocks", 244m NE/ENE)				
Airborne Effluents				
Organ Dose (iodines, tritium, and part.)	C.7.3.1.b(b)	15 mrem	5.54E-04 mrem	0.004%
Gamma Air Dose (noble gases)	C.7.2.1.b(b)	10 mrad	9.55E-06 mrad	0.0001%
Beta Air Dose (noble gases)	C.7.2.1.b(b)	20 mrad	1.58E-05 mrad	0.00008%

- (a) The "all plant sources" doses are the sum of the whole body doses and maximum organ doses from liquid, noble gas, and iodines/tritium/particulate releases as well as direct radiation from fixed station sources.
- (b) ODCM Part A, Section 10.2 states that the annual effluent report shall include an assessment of the radiation doses from radioactive liquids and gaseous effluents to members of the public due to their activities inside the site boundary during the report period. The referenced limits (C.7.2.1.b & C.7.3.1.b) are the acceptable doses from liquid and gaseous effluents to areas at and beyond the site boundary and are considered to be appropriate for comparison purposes.

Table D
 Seabrook Station
 2000 Annual Radioactive Effluent Release Report
Sources of the Values of Factors Used in Liquid Dose Equations

Factor	Definition	Source
U_{ap}	Usage factor	Table B.7-1, Station ODCM
M_p	Mixing ratio	Section B.7.1, Station ODCM (value=0.1 for aquatic foods and 0.025 for shoreline)
B_{ip}	Equilibrium bioaccumulation factor	Table A-1, Reg. Guide 1.109
D_{aipj}	Dose factor	Tables E-11 through E-14, R.G. 1.109
t_p	Nuclide transit time	Table E-15, Reg. Guide 1.109
K_c	Transfer coefficient from water to sediment	Reg. Guide 1.109
t_b	Period of activity buildup in sediment or soil	Table B.7-2, Station ODCM
W	Shoreline width factor	Table A-2, Reg. Guide 1.109 (value=0.5)

Table E

Seabrook Station
2000 Annual Radioactive Effluent Release Report

Sources of Values for the Factors Used in Dose Equations for Gaseous Releases

Factor	Definition	Source
t_b	Period of activity buildup in sediment or soil	Table B.7-2, Station ODCM
λ_i	Nuclide decay constant	Kocher (Reference 3)
DFG_{ij}	Ground plane dose factor	Table E-6, Reg. Guide 1.109
$[X/Q]^D$	Atmospheric dispersion factor	Calculated following Reg. Guide 1.111
R_a	Breathing rate	Table B.7-3, Station ODCM
DFA_{ija}	Inhalation dose factor	Tables E-7 through E-10, Reg. Guide 1.109
d_j	Nuclide deposition rate	Reg. Guide 1.109
P	Soil surface density	Table B.7-2, Station ODCM
t_e	Crop, leafy vegetable, or pasture grass exposure period	Table B.7-2, Station ODCM
t_h	Average time from crop harvest to consumption	Table B.7-2, Station ODCM
Y_v	Agricultural productivity by unit area	Table B.7-2, Station ODCM
r	Fraction of deposited activity retained on crops, leafy vegetables, or pasture grass	Table E-15, Reg. Guide 1.109
B_{iv}	Stable element transfer coefficient from soil to produce, leafy vegetable, or pasture grass	Table E-1, Reg. Guide 1.109
p	Fractional equilibrium ratio	Reg. Guide 1.109
H	Ambient absolute humidity	Table B.7-2, Station ODCM
F_m	Stable element transfer coefficient from feed to milk	Tables E-1 and E-2, Reg. Guide 1.109

Table E (continued)

Seabrook Station
2000 Annual Radioactive Effluent Release Report

Sources of Values for the Factors Used in Dose Equations for Gaseous Releases

Factor	Definition	Source
t_f	Average time from feed to milk to consumption	Reg. Guide 1.109
f_p	Fraction of the year that animals graze on pasture	Table B.7-2, Station ODCM
f_s	Fraction daily feed pasture grass	Table B.7-2, Station ODCM
F_f	Stable element transfer coefficient from feed to meat	Table E-1, Reg. Guide 1.109
t_s	Average time from meat animal slaughter to consumption	Table E-15, Reg. Guide 1.109
DFI_{ija}	Ingestion dose factor	Tables E-11 through E-14, R.G.1.109
U_a^y	Annual intake of produce	Table B.7-3, Station ODCM
U_a^m	Annual intake of milk	Table B.7-3, Station ODCM
U_a^F	Annual intake of meat	Table B.7-3, Station ODCM
U_a^L	Annual intake of leafy vegetables	Table B.7-3, Station ODCM
f_g	Ingestion rate fractions for garden produce	Reg. Guide 1.109
f_l	Ingestion rate fractions for garden leafy vegetables	Reg. Guide 1.109
λ_w	Rate constant for activity removal from plant and leaf surfaces by weathering	Table E-15, Reg. Guide 1.109
Q_F	Animal consumption rate	Table E-3, Reg. Guide 1.109

Table F
 Seabrook Station
 2000 Annual Radioactive Effluent Release Report
Receptor Locations* for Seabrook Station

Sector	Nearest Resident mile (km)	Nearest Garden mile (km)	Milk Animals within 5 Mile Radius mile (km)
N	2.69 (4.34)	2.76 (4.44)	---
NNE	1.89 (3.04)	1.95 (3.14)	---
NE	1.82 (2.92)	1.89 (3.04)	---
ENE	1.44 (2.31)	---	---
E	1.60 (2.58)	---	---
ESE	1.70 (2.73)	---	---
SE	1.46 (2.36)	---	---
SSE	2.13 (3.43)	---	---
S	0.75 (1.21)	0.75 (1.21)	---
SSW	0.69 (1.12)	0.76 (1.22)	---
SW	0.70 (1.13)	0.84 (1.34)	3.26 (5.24)
WSW	1.02 (1.64)	0.84 (1.34)	5.51 (8.87)
W	0.82 (1.32)	0.83 (1.33)	---
WNW	0.69 (1.11)	0.85 (1.37)	3.80 (6.10) 4.73 (7.61)
NW	0.79 (1.26)	0.79 (1.27)	4.30 (6.93)
NNW	0.63 (1.01)	0.75 (1.21)	3.30 (5.32)

* Locations based on 2000 Land Use Census.