

Exelon Generation Company, LLC
Byron Station
4450 North German Church Road
Byron, IL 61010-9794
www.exeloncorp.com

Nuclear
10 CFR 50.36a

April 26, 2002

LTR: BYRON 2002-0034
File: 2.12.1522

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001


Byron Station, Units 1 and 2
Facility Operating License Nos. NPF-37 and NPF-66
NRC Docket Nos. STN 50-454 and STN 50-455

Subject: 2001 Annual Radioactive Effluent Release Report

Enclosed is the Annual Radioactive Effluent Release Report for Byron Station. This report is being submitted in accordance with 10 CFR 50.36a, "Technical specifications on effluents from nuclear power reactors," paragraph (a)(2), and includes a summary of radiological liquid and gaseous effluents and solid waste released from the site from January 2001, through December 2001.

If you have any questions regarding this information, please contact W. Grundmann, Regulatory Assurance Manager, at (815) 406-2800.

Respectfully,


Richard P. Lopriore
Site Vice President
Byron Nuclear Generating Station

RPL/DAT/rf/bka

Attachment

cc: Regional Administrator – NRC Region III
NRC Senior Resident Inspector – Byron Station
NRC Project Manager – NRR – Byron Station (w/o enclosure)
Office of Nuclear Facility Safety / Illinois Department of Nuclear Safety
U.S. Environmental Protection Agency, Air and Radiation Division – Region V

IE48

BYRON NUCLEAR POWER STATION
UNIT 1/2 DOCKET NUMBER STN-50-454/455
RADIOACTIVE EFFLUENT RELEASE REPORT
January, 2001 THROUGH December, 2001
Supplemental Information

1. Regulatory Limits

a. Fission and activation gases:

Tech Spec Whole Body = 500 mrem/year
Skin = 3000 mrem/year

10CFR50 Gamma = 5 mrad/quarter; 10 mrad/year
Beta = 10 mrad/quarter; 20 mrad/year

b. Iodine: (summed with particulate, see below)

c. Particulates with half-lives > 8 days:

Tech Spec Organ = 1500 mrem/year
10CFR50 Organ = 7.5 mrem/quarter; 15 mrem/year

d. Liquid Effluents:

10CFR50 Whole Body = 1.5 mrem/quarter; 3 mrem/year
Organ = 5 mrem/quarter; 10 mrem/year

e. Total Effective Dose Equivalent:

10CFR20 TEDE = 100 mrem/year

2. Maximum Permissible Concentration

- a. Fission and Activation Gases: 10CFR20 Appendix B Table 2
- b. Iodine: 10CFR20 Appendix B Table 2
- c. Particulates: 10CFR20 Appendix B Table 2
- d. Liquid Effluents: 10 X 10CFR20 Appendix B Table 2

3. Average Energy: This item is not applicable. Release rates are calculated using an isotopic mix rather than average energy.

4. Measurements and Approximations of Total Radioactivity

- a. Fission and Activation Gases: Prior to release, the isotopic content is determined. Released activity is calculated using volume of release, which is determined by the change in tank or containment pressure. Additional methods of calculation utilize historical data and assign an isotopic mix which is representative of normal vent stack isotopics.
- b. Particulate, Tritium and Iodine sampling media for the plant vent stacks are collected and isotopically analyzed weekly for the plant vent stacks.

BYRON NUCLEAR POWER STATION
UNIT 1/2 DOCKET NUMBER STN-50-454/455
RADIOACTIVE EFFLUENT RELEASE REPORT
January, 2001 THROUGH December, 2001
Supplemental Information

- c. Liquid effluents: Batch releases are isotopically analyzed prior to release. Total release activity is calculated using volume of release. Total tritium activity released is calculated from the highest of a monthly circulating water blowdown composite activity or a sum of the input composite activities.
 - d. Analysis results which are less than the lower limit of detection (<LLD) are reported in units of Ci/ml unless otherwise noted. All LLD values are listed in Attachment A.
5. Batch Releases:
- a. Liquid:
 - 1. Number of batch releases = 142
 - 2. Total time period for batch releases = 14,936 minutes
 - 3. Maximum time period for a batch release = 329 minutes
 - 4. Average time period for a batch release = 105 minutes
 - 5. Minimum time period for a batch release = 09 minutes
 - 6. Average stream flow during periods of release of effluent into a flowing stream = 236.8 m³/sec, based on information from the National Weather Service or Army Corps of Engineers for the Rock River.
 - b. Gaseous:
 - 1. Number of batch releases = 279
 - 2. Total time period for batch releases = 48,540 minutes
 - 3. Maximum time period for a batch release = 4,940 minutes
 - 4. Average time period for batch releases = 174 minutes
 - 5. Minimum time period for a batch release = 46 minutes
6. Abnormal Releases:
- a. Liquid - None
 - b. Gaseous – None

BYRON NUCLEAR POWER STATION
UNIT 1 DOCKET NUMBER STN-50-454
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

A. FISSION AND ACTIVATION GAS RELEASES

| | | | | | |
|--------------------------------------|---------|----------|----------|----------|----------|
| 1. Total Release Activity: | Ci | 2.18E-01 | 2.68E-01 | 1.23E-01 | 3.04E-01 |
| 2. Maximum Release Rate for Quarter: | uCi/sec | 4.27E+00 | 1.56E+00 | 1.56E+00 | 3.74E+00 |

3. % of Tech. Spec. Limits *

| | | | | | |
|------------------------------|---|------|------|------|------|
| a. Whole Body (500 mrem/yr): | % | 0.00 | 0.00 | 0.00 | 0.00 |
| b. Skin (3000 mrem/yr): | % | 0.00 | 0.00 | 0.00 | 0.00 |

4. % of 10CFR50 Limits

| | | | | | |
|------------------------------|---|------|------|------|------|
| a. Gamma Quarterly (5 mrad): | % | 0.00 | 0.00 | 0.00 | 0.00 |
| b. Beta Quarterly (10 mrad): | % | 0.00 | 0.00 | 0.00 | 0.00 |
| c. Gamma Annual (10 mrad): | % | 0.00 | 0.00 | 0.00 | 0.00 |
| d. Beta Annual (20 mrad): | % | 0.00 | 0.00 | 0.00 | 0.00 |

B. IODINE RELEASES **

| | | | | | |
|--------------------------------|---------|----------|----------|----------|----------|
| 1. Total I-131 Activity: | Ci | <LLD | <LLD | <LLD | <LLD |
| 2. Average I-131 Release Rate: | uCi/sec | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |

C. PARTICULATE (>8 day half-life) RELEASES **

| | | | | | |
|--------------------------------------|---------|----------|----------|----------|----------|
| 1. Total Particulate Activity: | Ci | <LLD | 6.96E-06 | <LLD | <LLD |
| 2. Average Particulate Release Rate: | uCi/sec | 0.00E+00 | 8.85E-07 | 0.00E+00 | 0.00E+00 |
| 3. Gross Alpha Activity for Quarter: | Ci | <LLD | <LLD | <LLD | <LLD |

D. TRITIUM RELEASES **

| | | | | | |
|----------------------------------|---------|----------|----------|----------|----------|
| 1. Total Tritium Activity: | Ci | 8.00E-01 | 2.46E-01 | 4.98E-01 | 6.99E-01 |
| 2. Average Tritium Release Rate: | uCi/sec | 1.03E-01 | 3.12E-02 | 6.27E-02 | 8.79E-02 |

* % of Tech. Spec. limits is based on the maximum release rate for the period considered.

** Iodine, particulate, and tritium are expressed as a total limit. See Step E.

BYRON NUCLEAR POWER STATION
UNIT 1 DOCKET NUMBER STN-50-454
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES (CONT.)

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

E. TOTAL OF IODINE, PARTICULATE (>8 day half-life), AND TRITIUM RELEASES

| | | | | | |
|---------------------------------------|----|----------|----------|----------|----------|
| 1. Total Activity: | Ci | 8.00E-01 | 2.46E-01 | 4.98E-01 | 6.99E-01 |
| 2. % of Tech. Spec. Limits | | | | | |
| a. Any Organ (1500 mrem/yr): | % | 0.00 | 0.00 | 0.00 | 0.00 |
| 3. % of 10CFR50 Limit | | | | | |
| a. Quarterly Any Organ (7.5 mrem): | % | 0.00 | 0.00 | 0.00 | 0.00 |
| b. Annual Any Organ (15 mrem): | % | 0.00 | 0.00 | 0.01 | 0.00 |

GASEOUS EFFLUENTS - VENT STACK RELEASES - BATCH MODE

F. FISSION AND ACTIVATION GAS RELEASES

| | | | | | |
|----------|----|----------|----------|----------|----------|
| Ar-41: | Ci | 4.25E-05 | 3.32E-03 | 5.36E-03 | 5.44E-03 |
| Kr-85: | Ci | <LLD | <LLD | <LLD | <LLD |
| Kr-85m: | Ci | <LLD | <LLD | <LLD | 2.01E-04 |
| Kr-87: | Ci | <LLD | <LLD | <LLD | <LLD |
| Kr-88: | Ci | <LLD | <LLD | <LLD | <LLD |
| Xe-131m: | Ci | <LLD | <LLD | 1.27E-03 | <LLD |
| Xe-133: | Ci | 1.09E-01 | 9.51E-02 | 9.35E-02 | 2.41E-01 |
| Xe-133m: | Ci | 1.30E-03 | 5.21E-04 | 7.00E-04 | 3.98E-03 |
| Xe-135: | Ci | 3.41E-03 | 9.27E-05 | 1.09E-03 | 1.24E-02 |
| Xe-138: | Ci | <LLD | <LLD | <LLD | <LLD |

BYRON NUCLEAR POWER STATION
 UNIT 1 DOCKET NUMBER STN-50-454
 RADIOACTIVE EFFLUENT RELEASE REPORT
 JANUARY, 2001 THROUGH DECEMBER, 2001

GASEOUS EFFLUENTS - VENT STACK RELEASES - BATCH MODE (CONT.)

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

G. IODINE RELEASES

| | | | | | |
|--------|----|---|---|---|---|
| I-131: | Ci | * | * | * | * |
| I-133: | Ci | * | * | * | * |
| I-135: | Ci | * | * | * | * |

* Value reported as CONTINUOUS RELEASE MODE.

H. PARTICULATE (>8 day half-life) RELEASES

| | | | | | |
|--------|----|---|---|---|---|
| Sr-89: | Ci | * | * | * | * |
| Sr-90: | Ci | * | * | * | * |

* Value reported as CONTINUOUS RELEASE MODE.

GASEOUS EFFLUENTS - VENT STACK RELEASES - CONTINUOUS MODE

I. FISSION AND ACTIVATION GAS RELEASES

| | | | | | |
|---------|----|----------|----------|----------|----------|
| Xe-133: | Ci | 1.04E-01 | 1.70E-01 | 2.07E-02 | 4.14E-02 |
|---------|----|----------|----------|----------|----------|

BYRON NUCLEAR POWER STATION
UNIT 1 DOCKET NUMBER STN-50-454
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

GASEOUS EFFLUENTS - VENT STACK RELEASES - CONTINUOUS MODE (CONT.)

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

J. IODINE RELEASES

| | | | | | |
|--------|----|------|------|------|------|
| I-131: | Ci | <LLD | <LLD | <LLD | <LLD |
| I-133: | Ci | <LLD | <LLD | <LLD | <LLD |
| I-135: | Ci | <LLD | <LLD | <LLD | <LLD |

K. PARTICULATE (>8 day half-life) RELEASES

| | | | | | |
|--------|----|------|----------|------|------|
| Sr-89: | Ci | <LLD | <LLD | <LLD | <LLD |
| Sr-90: | Ci | <LLD | <LLD | <LLD | <LLD |
| Cr-51: | Ci | <LLD | 5.28E-06 | <LLD | <LLD |
| Co-60: | Ci | <LLD | 1.68E-06 | <LLD | <LLD |

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

L. FISSION AND ACTIVATION PRODUCT RELEASES

| | | | | | |
|------------------------------------------------|--------|----------|----------|----------|----------|
| 1. Total Activity Released: | Ci | 1.66E-02 | 3.37E-02 | 5.54E-02 | 3.68E-02 |
| 2. Average Concentration Released For Quarter: | uCi/ml | 5.18E-09 | 1.04E-08 | 1.51E-08 | 1.12E-08 |

3. % of 10CFR50 Limits

| | | | | | |
|-------------------------------------|---|------|------|------|------|
| a. Quarterly Whole Body (1.5 mrem): | % | 0.04 | 0.03 | 0.04 | 0.05 |
| b. Quarterly Any Organ (5.0 mrem): | % | 0.01 | 0.02 | 0.02 | 0.02 |
| c. Annual Whole Body (3.0 mrem): | % | 0.02 | 0.02 | 0.02 | 0.03 |
| d. Annual Any Organ (10.0 mrem): | % | 0.00 | 0.01 | 0.01 | 0.01 |

BYRON NUCLEAR POWER STATION
UNIT 1 DOCKET NUMBER STN-50-454
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES (CONT.)

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

M. TRITIUM

1. Total Activity Released:
2. Average Concentration Released For Quarter:
3. % of Tech Spec Limit (1.00E-2 uCi/ml):

| | | | | |
|--------|----------|----------|----------|----------|
| Ci | 3.03E+02 | 1.95E+02 | 3.22E+02 | 3.85E+02 |
| uCi/ml | 9.47E-05 | 6.04E-05 | 8.75E-05 | 1.17E-04 |
| % | 0.95 | 0.60 | 0.88 | 1.17 |

N. DISSOLVED NOBLE GASES

1. Total Activity Released:
2. Average Concentration Released For Quarter:
3. % of Tech. Req. Manual Limit (2.00E-4 uCi/ml):

| | | | | |
|--------|----------|----------|----------|----------|
| Ci | 2.64E-03 | 5.10E-03 | 8.91E-05 | 6.86E-04 |
| uCi/ml | 8.24E-10 | 1.58E-09 | 2.42E-11 | 2.09E-10 |
| % | 4.12E-04 | 7.90E-04 | 1.21E-05 | 1.04E-04 |

O. GROSS ALPHA

1. Total Activity Released:
2. Average Concentration Released For Quarter:

| | | | | |
|--------|----------|----------|----------|----------|
| Ci | <LLD | <LLD | <LLD | <LLD |
| uCi/ml | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |

P. VOLUME OF WASTE RELEASED PER UNIT:

| | | | | |
|--------|----------|----------|----------|----------|
| liters | 1.23E+06 | 1.47E+06 | 1.44E+06 | 1.70E+06 |
|--------|----------|----------|----------|----------|

Q. VOLUME OF DILUTION WATER PER UNIT:

| | | | | |
|--------|----------|----------|----------|----------|
| liters | 3.20E+09 | 3.23E+09 | 3.68E+09 | 3.29E+09 |
|--------|----------|----------|----------|----------|

LIQUID EFFLUENTS - CONTINUOUS MODE

R. LIQUID EFFLUENTS

- Fe-55:
Sr-89:
Sr-90:

* Value reported as LIQUID EFFLUENTS - BATCH MODE

| | | | | |
|----|---|---|---|---|
| Ci | * | * | * | * |
| Ci | * | * | * | * |
| Ci | * | * | * | * |

BYRON NUCLEAR POWER STATION
UNIT 1 DOCKET NUMBER STN-50-454
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

LIQUID EFFLUENTS - BATCH MODE

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

S. LIQUID EFFLUENTS

| | | | | | |
|----------|----|----------|----------|----------|----------|
| Fe-55: | Ci | 3.15E-03 | 7.65E-04 | 5.00E-04 | 8.12E-03 |
| Sr-89: | Ci | <LLD | <LLD | <LLD | <LLD |
| Sr-90: | Ci | <LLD | <LLD | <LLD | <LLD |
| H-3: | Ci | 3.03E+02 | 1.95E+02 | 3.22E+02 | 3.85E+02 |
| Ar-41: | Ci | <LLD | <LLD | <LLD | <LLD |
| Cr-51: | Ci | <LLD | 1.17E-04 | 1.72E-03 | 3.59E-05 |
| Mn-54: | Ci | 1.19E-04 | 4.67E-05 | 2.34E-04 | 4.40E-05 |
| Fe-59: | Ci | 2.78E-06 | 7.92E-06 | <LLD | <LLD |
| Co-57: | Ci | 5.01E-05 | 1.14E-05 | 1.80E-05 | 5.31E-06 |
| Co-58: | Ci | 7.51E-03 | 3.90E-03 | 3.66E-03 | 7.26E-04 |
| Co-60: | Ci | 1.64E-03 | 1.40E-03 | 2.78E-03 | 2.12E-03 |
| Zn-65: | Ci | <LLD | <LLD | <LLD | <LLD |
| Kr-85: | Ci | 2.05E-03 | 3.66E-03 | <LLD | 3.70E-04 |
| Kr-85m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Kr-87: | Ci | <LLD | <LLD | <LLD | <LLD |
| Kr-88: | Ci | <LLD | <LLD | <LLD | <LLD |
| Sr-92: | Ci | 3.89E-06 | <LLD | <LLD | <LLD |
| Nb-95: | Ci | 1.50E-05 | 8.35E-06 | 1.12E-04 | <LLD |
| Zr-95: | Ci | 6.11E-06 | <LLD | <LLD | <LLD |
| Zr-97: | Ci | <LLD | <LLD | <LLD | <LLD |
| Mo-99: | Ci | <LLD | <LLD | <LLD | <LLD |
| Tc-99m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Tc-104: | Ci | <LLD | <LLD | <LLD | <LLD |
| Ag-110m: | Ci | 2.81E-05 | 1.04E-05 | 1.19E-05 | 1.48E-04 |
| Sn-113: | Ci | <LLD | <LLD | <LLD | <LLD |
| Te-121m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Te-123m: | Ci | 5.14E-05 | 5.10E-04 | 1.43E-05 | 3.42E-04 |
| Te-125m: | Ci | 2.80E-03 | 2.38E-02 | 3.54E-03 | 2.75E-02 |
| Sb-122: | Ci | <LLD | 9.24E-06 | <LLD | <LLD |
| Sb-124: | Ci | 3.73E-04 | 2.51E-04 | 2.87E-03 | 3.29E-05 |
| Sb-125: | Ci | 3.97E-03 | 3.12E-03 | 4.04E-02 | 5.97E-03 |
| Sb-126: | Ci | <LLD | 7.97E-06 | <LLD | <LLD |

BYRON NUCLEAR POWER STATION
UNIT 1 DOCKET NUMBER STN-50-454
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

LIQUID EFFLUENTS - BATCH MODE (CONT.)

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

S. LIQUID EFFLUENTS (CONT.)

| | | | | | |
|----------|----|----------|----------|----------|----------|
| I-131: | Ci | <LLD | 1.62E-05 | 1.81E-06 | 3.25E-06 |
| I-132: | Ci | <LLD | 2.49E-04 | <LLD | <LLD |
| I-133: | Ci | <LLD | 2.37E-06 | <LLD | <LLD |
| I-135: | Ci | <LLD | <LLD | <LLD | <LLD |
| Xe-131m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Xe-133: | Ci | 5.69E-04 | 1.37E-03 | 8.91E-05 | 3.16E-04 |
| Xe-133m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Xe-135: | Ci | 1.14E-05 | 7.67E-05 | <LLD | <LLD |
| Xe-135m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Xe-138: | Ci | <LLD | <LLD | <LLD | <LLD |
| Cs-134: | Ci | <LLD | <LLD | <LLD | <LLD |
| Cs-137: | Ci | <LLD | <LLD | <LLD | <LLD |
| Ba-140: | Ci | <LLD | <LLD | <LLD | <LLD |
| La-140: | Ci | <LLD | <LLD | <LLD | <LLD |
| Ce-141: | Ci | <LLD | <LLD | <LLD | <LLD |
| Ce-144: | Ci | <LLD | <LLD | <LLD | <LLD |
| Sr-85: | Ci | 9.09E-06 | 1.61E-05 | <LLD | <LLD |
| Te-132: | Ci | <LLD | 2.17E-04 | 3.71E-05 | <LLD |
| Ba-133: | Ci | <LLD | 3.19E-06 | <LLD | <LLD |
| Na-24: | Ci | <LLD | <LLD | 2.35E-05 | <LLD |

T. 10CFR20 PUBLIC TEDE COMPLIANCE

1. % OF 10CFR20 TEDE LIMIT
(100 mrem/yr):

| | | | | |
|---|------|------|------|------|
| % | 0.00 | 0.00 | 0.00 | 0.00 |
|---|------|------|------|------|

U. 40CFR190 Compliance

1. % of 40CFR190 DDE (25 mrem/yr)
2. % of 40CFR190 CDE (25 mrem/yr)
3. % of 40CFR190 CDE (Thyroid)
(75 mrem/yr)

| | | | | |
|---|------|------|------|------|
| % | 0.00 | 0.00 | 0.00 | 0.00 |
| % | 0.00 | 0.00 | 0.00 | 0.00 |
| % | 0.00 | 0.00 | 0.00 | 0.00 |
| % | 0.00 | 0.00 | 0.00 | 0.00 |

BYRON NUCLEAR POWER STATION
UNIT 2 DOCKET NUMBER STN-50-455
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

A. FISSION AND ACTIVATION GAS RELEASES

| | | | | | |
|--------------------------------------|---------|----------|----------|----------|----------|
| 1. Total Release Activity: | Ci | 2.18E-01 | 2.73E-01 | 9.13E-02 | 2.55E-01 |
| 2. Maximum Release Rate for Quarter: | uCi/sec | 4.27E+00 | 1.22E+00 | 9.84E-01 | 3.74E+00 |

3. % of Tech. Spec. Limits:*

| | | | | | |
|------------------------------|---|------|------|------|------|
| a. Whole Body (500 mrem/yr): | % | 0.00 | 0.00 | 0.00 | 0.00 |
| b. Skin (3000 mrem/yr): | % | 0.00 | 0.00 | 0.00 | 0.00 |

4. % of 10CFR50 Limits

| | | | | | |
|------------------------------|---|------|------|------|------|
| a. Gamma Quarterly (5 mrad): | % | 0.00 | 0.00 | 0.00 | 0.00 |
| b. Beta Quarterly (10 mrad): | % | 0.00 | 0.00 | 0.00 | 0.00 |
| c. Gamma Annual (10 mrad): | % | 0.00 | 0.00 | 0.00 | 0.00 |
| d. Beta Annual (20 mrad): | % | 0.00 | 0.00 | 0.00 | 0.00 |

B. IODINE RELEASES **

| | | | | | |
|--------------------------------|---------|----------|----------|----------|----------|
| 1. Total I-131 Activity: | Ci | <LLD | <LLD | <LLD | <LLD |
| 2. Average I-131 Release Rate: | uCi/sec | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |

C. PARTICULATE (>8 day half-life) RELEASES **

| | | | | | |
|--------------------------------------|---------|----------|----------|----------|----------|
| 1. Total Particulate Activity: | Ci | <LLD | 1.18E-06 | 1.36E-06 | 1.78E-07 |
| 2. Average Particulate Release Rate: | uCi/sec | 0.00E+00 | 1.50E-07 | 1.71E-07 | 2.24E-08 |
| 3. Gross Alpha Activity for Quarter: | Ci | <LLD | <LLD | <LLD | <LLD |

D. TRITIUM RELEASES **

| | | | | | |
|----------------------------------|---------|----------|----------|----------|----------|
| 1. Total Tritium Activity: | Ci | 2.84E+00 | 7.26E-01 | 4.16E-01 | 5.99E-01 |
| 2. Average Tritium Release Rate: | uCi/sec | 3.65E-01 | 9.23E-02 | 5.23E-02 | 7.53E-02 |

* % of Tech. Spec. limits is based on the maximum release rate for the period considered.

** Iodine, particulate, and tritium are expressed as a total limit. See Step E.

BYRON NUCLEAR POWER STATION
UNIT 2 DOCKET NUMBER STN-50-455
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES (CONT.)

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

E. TOTAL OF IODINE, PARTICULATE (>8 day half-life), AND TRITIUM RELEASES

1. Total Activity:

| | | | | |
|----|----------|----------|----------|----------|
| Ci | 2.84E+00 | 7.26E-01 | 4.16E-01 | 5.99E-01 |
|----|----------|----------|----------|----------|

2. % of Tech. Spec. Limits

a. Any Organ (1500 mrem/yr):

| | | | | |
|---|------|------|------|------|
| % | 0.00 | 0.00 | 0.00 | 0.00 |
|---|------|------|------|------|

3. % of 10CFR50 Limit

a. Quarterly Any Organ
(7.5 mrem):

| | | | | |
|---|------|------|------|------|
| % | 0.02 | 0.01 | 0.01 | 0.01 |
|---|------|------|------|------|

a. Annual Any Organ
(15 mrem):

| | | | | |
|---|------|------|------|------|
| % | 0.01 | 0.00 | 0.00 | 0.00 |
|---|------|------|------|------|

GASEOUS EFFLUENTS - VENT STACK RELEASES - BATCH MODE

F. FISSION AND ACTIVATION GAS RELEASES

| | | | | | |
|----------|----|----------|----------|----------|----------|
| Ar-41: | Ci | 7.17E-03 | <LLD | <LLD | 2.23E-04 |
| Kr-85: | Ci | <LLD | <LLD | <LLD | <LLD |
| Kr-85m: | Ci | <LLD | <LLD | <LLD | 2.01E-04 |
| Kr-87: | Ci | <LLD | <LLD | <LLD | <LLD |
| Kr-88: | Ci | <LLD | <LLD | <LLD | <LLD |
| Xe-131m: | Ci | <LLD | <LLD | 1.27E-03 | <LLD |
| Xe-133: | Ci | 1.01E-01 | 1.03E-01 | 6.85E-02 | 1.97E-01 |
| Xe-133m: | Ci | 4.28E-03 | 5.21E-04 | 7.00E-04 | 3.98E-03 |
| Xe-135: | Ci | 2.61E-03 | 9.27E-05 | 1.14E-04 | 1.24E-02 |
| Xe-138: | Ci | <LLD | <LLD | <LLD | <LLD |

BYRON NUCLEAR POWER STATION
 UNIT 2 DOCKET NUMBER STN-50-455
 RADIOACTIVE EFFLUENT RELEASE REPORT
 JANUARY, 2001 THROUGH DECEMBER, 2001

GASEOUS EFFLUENTS - VENT STACK RELEASES - BATCH MODE (CONT.)

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

G. IODINE RELEASES

| | | | | | |
|--------|----|---|---|---|---|
| I-131: | Ci | * | * | * | * |
| I-133: | Ci | * | * | * | * |
| I-135: | Ci | * | * | * | * |

* Value reported as CONTINUOUS RELEASE MODE.

H. PARTICULATE (>8 day half-life) RELEASES

| | | | | | |
|--------|----|---|---|---|---|
| Sr-89: | Ci | * | * | * | * |
| Sr-90: | Ci | * | * | * | * |

* Value reported as CONTINUOUS RELEASE MODE.

GASEOUS EFFLUENTS - VENT STACK RELEASES - CONTINUOUS MODE

I. FISSION AND ACTIVATION GAS RELEASES

| | | | | | |
|---------|----|----------|----------|----------|----------|
| Xe-133: | Ci | 1.04E-01 | 1.70E-01 | 2.07E-02 | 4.14E-02 |
|---------|----|----------|----------|----------|----------|

BYRON NUCLEAR POWER STATION
UNIT 2 DOCKET NUMBER STN-50-455
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

GASEOUS EFFLUENTS - VENT STACK RELEASES - CONTINUOUS MODE (CONT.)

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

J. IODINE RELEASES

| | | | | | |
|--------|----|----------|------|------|------|
| I-131: | Ci | <LLD | <LLD | <LLD | <LLD |
| I-133: | Ci | 6.73E-06 | <LLD | <LLD | <LLD |
| I-135: | Ci | <LLD | <LLD | <LLD | <LLD |

K. PARTICULATE (>8 day half-life) RELEASES

| | | | | | |
|--------|----|------|----------|----------|----------|
| Sr-89: | Ci | <LLD | <LLD | <LLD | <LLD |
| Sr-90: | Ci | <LLD | <LLD | <LLD | <LLD |
| Co-60: | Ci | <LLD | 1.18E-06 | 1.36E-06 | 1.78E-07 |

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

L. FISSION AND ACTIVATION PRODUCT RELEASES

| | | | | | |
|------------------------------------------------|--------|----------|----------|----------|----------|
| 1. Total Activity Released: | Ci | 1.66E-02 | 3.37E-02 | 5.54E-02 | 3.68E-02 |
| 2. Average Concentration Released For Quarter: | uCi/ml | 5.18E-09 | 1.04E-08 | 1.51E-08 | 1.12E-08 |

3. % of 10CFR50 Limits

| | | | | | |
|-------------------------------------|---|------|------|------|------|
| a. Quarterly Whole Body (1.5 mrem): | % | 0.04 | 0.03 | 0.04 | 0.05 |
| b. Quarterly Any Organ (5.0 mrem): | % | 0.01 | 0.02 | 0.02 | 0.02 |
| c. Annual Whole Body (3.0 mrem): | % | 0.02 | 0.02 | 0.02 | 0.03 |
| d. Annual Any Organ (10.0 mrem): | % | 0.00 | 0.01 | 0.01 | 0.01 |

BYRON NUCLEAR POWER STATION
UNIT 2 DOCKET NUMBER STN-50-455
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES (CONT.)

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

M. TRITIUM

1. Total Activity Released:
2. Average Concentration Released For Quarter:
3. % of Tech Spec Limit (1.00E-2 uCi/ml):

| | | | | |
|--------|----------|----------|----------|----------|
| Ci | 3.03E+02 | 1.95E+02 | 3.22E+02 | 3.85E+02 |
| uCi/ml | 9.47E-05 | 6.04E-05 | 8.75E-05 | 1.17E-04 |
| % | 0.95 | 0.60 | 0.88 | 1.17 |

N. DISSOLVED NOBLE GASES

1. Total Activity Released:
2. Average Concentration Released For Quarter:
3. % of Tech. Reqt. Manual Limit (2.00E-4 uCi/ml):

| | | | | |
|--------|----------|----------|----------|----------|
| Ci | 2.64E-03 | 5.10E-03 | 8.91E-05 | 6.86E-04 |
| uCi/ml | 8.24E-10 | 1.58E-09 | 2.42E-11 | 2.09E-10 |
| % | 4.12E-04 | 7.90E-04 | 1.21E-05 | 1.04E-04 |

O. GROSS ALPHA

1. Total Activity Released:
2. Average Concentration Released For Quarter:

| | | | | |
|--------|----------|----------|----------|----------|
| Ci | <LLD | <LLD | <LLD | <LLD |
| uCi/ml | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |

P. VOLUME OF WASTE RELEASED PER UNIT:

| | | | | |
|--------|----------|----------|----------|----------|
| liters | 1.23E+06 | 1.47E+06 | 1.44E+06 | 1.70E+06 |
|--------|----------|----------|----------|----------|

Q. VOLUME OF DILUTION WATER PER UNIT:

| | | | | |
|--------|----------|----------|----------|----------|
| liters | 3.20E+09 | 3.23E+09 | 3.68E+09 | 3.29E+09 |
|--------|----------|----------|----------|----------|

LIQUID EFFLUENTS - CONTINUOUS MODE

R. LIQUID EFFLUENTS

- Fe-55:
Sr-89:
Sr-90:

* Value reported as LIQUID EFFLUENTS - BATCH MODE

| | | | | |
|----|---|---|---|---|
| Ci | * | * | * | * |
| Ci | * | * | * | * |
| Ci | * | * | * | * |

BYRON NUCLEAR POWER STATION
UNIT 2 DOCKET NUMBER STN-50-455
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

LIQUID EFFLUENTS - BATCH MODE

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

S. LIQUID EFFLUENTS

| | | | | | |
|----------|----|----------|----------|----------|----------|
| Fe-55: | Ci | 3.15E-03 | 7.65E-04 | 5.00E-04 | 8.12E-03 |
| Sr-89: | Ci | <LLD | <LLD | <LLD | <LLD |
| Sr-90: | Ci | <LLD | <LLD | <LLD | <LLD |
| H-3: | Ci | 3.03E+02 | 1.95E+02 | 3.22E+02 | 3.85E+02 |
| Ar-41: | Ci | <LLD | <LLD | <LLD | <LLD |
| Cr-51: | Ci | <LLD | 1.17E-04 | 1.72E-03 | 3.59E-05 |
| Mn-54: | Ci | 1.19E-04 | 4.67E-05 | 2.34E-04 | 4.40E-05 |
| Fe-59: | Ci | 2.78E-06 | 7.92E-06 | <LLD | <LLD |
| Co-57: | Ci | 5.01E-05 | 1.14E-05 | 1.80E-05 | 5.31E-06 |
| Co-58: | Ci | 7.51E-03 | 3.90E-03 | 3.66E-03 | 7.26E-04 |
| Co-60: | Ci | 1.64E-03 | 1.40E-03 | 2.78E-03 | 2.12E-03 |
| Zn-65: | Ci | <LLD | <LLD | <LLD | <LLD |
| Kr-85: | Ci | 2.05E-03 | 3.66E-03 | <LLD | 3.70E-04 |
| Kr-85m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Kr-87: | Ci | <LLD | <LLD | <LLD | <LLD |
| Kr-88: | Ci | <LLD | <LLD | <LLD | <LLD |
| Sr-92: | Ci | 3.89E-06 | <LLD | <LLD | <LLD |
| Nb-95: | Ci | 1.50E-05 | 8.35E-06 | 1.12E-04 | <LLD |
| Zr-95: | Ci | 6.11E-06 | <LLD | <LLD | <LLD |
| Zr-97: | Ci | <LLD | <LLD | <LLD | <LLD |
| Mo-99: | Ci | <LLD | <LLD | <LLD | <LLD |
| Tc-99m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Tc-104: | Ci | <LLD | <LLD | <LLD | <LLD |
| Ag-110m: | Ci | 2.81E-05 | 1.04E-05 | 1.19E-05 | 1.48E-04 |
| Sn-113: | Ci | <LLD | <LLD | <LLD | <LLD |
| Te-121m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Te-123m: | Ci | 5.14E-05 | 5.10E-04 | 1.43E-05 | 3.42E-04 |
| Te-125m: | Ci | 2.80E-03 | 2.38E-02 | 3.54E-03 | 2.75E-02 |
| Sb-122: | Ci | <LLD | 9.24E-06 | <LLD | <LLD |
| Sb-124: | Ci | 3.73E-04 | 2.51E-04 | 2.87E-03 | 3.29E-05 |
| Sb-125: | Ci | 3.97E-03 | 3.12E-03 | 4.04E-02 | 5.97E-03 |
| Sb-126: | Ci | <LLD | 7.97E-06 | <LLD | <LLD |

BYRON NUCLEAR POWER STATION
UNIT 2 DOCKET NUMBER STN-50-455
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

LIQUID EFFLUENTS - BATCH MODE (CONT.)

| UNITS | 1st Quarter | 2nd Quarter | 3rd Quarter | 4th Quarter |
|-------|-------------|-------------|-------------|-------------|
|-------|-------------|-------------|-------------|-------------|

S. LIQUID EFFLUENTS (CONT.)

| | | | | | |
|----------|----|----------|----------|----------|----------|
| I-131: | Ci | <LLD | 1.62E-05 | 1.81E-06 | 3.25E-06 |
| I-132: | Ci | <LLD | 2.49E-04 | <LLD | <LLD |
| I-133: | Ci | <LLD | 2.37E-06 | <LLD | <LLD |
| I-135: | Ci | <LLD | <LLD | <LLD | <LLD |
| Xe-131m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Xe-133: | Ci | 5.69E-04 | 1.37E-03 | 8.91E-05 | 3.16E-04 |
| Xe-133m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Xe-135: | Ci | 1.14E-05 | 7.67E-05 | <LLD | <LLD |
| Xe-135m: | Ci | <LLD | <LLD | <LLD | <LLD |
| Xe-138: | Ci | <LLD | <LLD | <LLD | <LLD |
| Cs-134: | Ci | <LLD | <LLD | <LLD | <LLD |
| Cs-137: | Ci | <LLD | <LLD | <LLD | <LLD |
| Ba-140: | Ci | <LLD | <LLD | <LLD | <LLD |
| La-140: | Ci | <LLD | <LLD | <LLD | <LLD |
| Ce-141: | Ci | <LLD | <LLD | <LLD | <LLD |
| Ce-144: | Ci | <LLD | <LLD | <LLD | <LLD |
| Sr-85: | Ci | 9.09E-06 | 1.61E-05 | <LLD | <LLD |
| Te-132: | Ci | <LLD | 2.17E-04 | 3.71E-05 | <LLD |
| Ba-133: | Ci | <LLD | 3.19E-06 | <LLD | <LLD |
| Na-24: | Ci | <LLD | <LLD | 2.35E-05 | <LLD |

T. 10CFR20 PUBLIC TEDE COMPLIANCE

1. % OF 10CFR20 TEDE LIMIT:
(100 mrem/yr)

| | | | | |
|---|------|------|------|------|
| % | 0.00 | 0.00 | 0.00 | 0.00 |
|---|------|------|------|------|

U. 40CFR190 Compliance

1. % of 40CFR190 DDE (25 mrem/yr)
2. % of 40CFR190 CDE (25 mrem/yr)
3. % of 40CFR190 CDE (Thyroid)
(75 mrem/yr)

| | | | | |
|---|------|------|------|------|
| % | 0.00 | 0.00 | 0.00 | 0.00 |
| % | 0.00 | 0.00 | 0.00 | 0.00 |
| % | 0.00 | 0.00 | 0.00 | 0.00 |
| % | 0.00 | 0.00 | 0.00 | 0.00 |

BYRON NUCLEAR POWER STATION
UNIT 1/2, DOCKET NUMBER STN-50-454/455
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

SOLID RADIOACTIVE WASTE FOR BURIAL 1ST QUARTER, 2001

| DATE | DISPOSITION OF MATERIAL (DESCRIPTION, CLASS, TYPE AND SOLIDIFYING AGENT) | MODE OF TRANSPORT | DESTINATION | VOLUME PER SHIPMENT | Curies* Per Shipment |
|------------------|------------------------------------------------------------------------------------------------------|----------------------|----------------------|---------------------------|----------------------------|
| 01/04/2001 | MECHANICAL FILTERS, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, RQ, CLASS C, TYPE A CONTAINER, NONE | EXCLUSIVE-USE | OAK RIDGE, TN | 5.83E+00 | 3.60E+01 |
| 01/18/2001 | DRY ACTIVE WASTE, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG-TIGHT CONTAINER, NONE | EXCLUSIVE-USE | OAK RIDGE, TN | 3.63E+01 | 2.24E-01 |
| 03/26/2001 | DRY ACTIVE WASTE, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG-TIGHT CONTAINER, NONE | EXCLUSIVE-USE | OAK RIDGE, TN | 7.25E+01 | 1.52E-02 |
| Quarterly Totals | | | | 1.15E+02 | 3.62E+01 |
| | | | Number of Shipments: | 3 | |
| | | | | CUBIC M | CURIES |

* Calculated using measured ratios

BYRON NUCLEAR POWER STATION
UNIT 1/2, DOCKET NUMBER STN-50-454/455
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

SOLID RADIOACTIVE WASTE FOR BURIAL 2ND QUARTER, 2001

| DATE | DISPOSITION OF MATERIAL (DESCRIPTION, CLASS, TYPE AND SOLIDIFYING AGENT) | MODE OF TRANSPORT | DESTINATION | VOLUME PER SHIPMENT | Curies* Per Shipment |
|------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|---------------|---------------------------|----------------------------|
| 04/02/2001 | MIXED BED ION-EXCHANGE MEDIA, nos, 7, UN2982, RQ, CLASS B, TYPE B CONTAINER, NONE | EXCLUSIVE-USE | BARNWELL, SC | 3.41E+00 | 1.52E+02 |
| 05/09/2001 | DRY ACTIVE WASTE, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, MIXED WASTE, D001, F005, PAINT SOLVENTS CONTAINING METHYL ETHYL KETONE, (RQ-D001), CLASS A, STRONG-TIGHT CONTAINER, NONE | EXCLUSIVE-USE | RICHLAND, WA | 3.63E+01 | 8.20E-02 |
| 05/24/2001 | DRY ACTIVE WASTE, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG-TIGHT CONTAINER, NONE | EXCLUSIVE-USE | OAK RIDGE, TN | 7.25E+01 | 1.16E-01 |
| 06/07/2001 | DRY ACTIVE WASTE, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG TIGHT CONTAINER, NONE | EXCLUSIVE-USE | OAK RIDGE, TN | 3.63E+01 | 6.70E-02 |
| 06/20/2001 | MIXED BED ION-EXCHANGE MEDIA, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A,TYPE A CONTAINER, NONE | EXCLUSIVE-USE | BARNWELL, SC | 5.83E+00 | 3.51E+01 |
| Quarterly Totals | | | | 1.54E+02 | 1.87E+02 |
| * Calculated using measured ratios | | | | CUBIC M | CURIES |

Number of Shipments: 5

BYRON NUCLEAR POWER STATION
UNIT 1/2, DOCKET NUMBER STN-50-454/455
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

SOLID RADIOACTIVE WASTE FOR BURIAL 3RD QUARTER, 2001

| DATE | DISPOSITION OF MATERIAL (DESCRIPTION, CLASS, TYPE AND SOLIDIFYING AGENT) | MODE OF TRANSPORT | DESTINATION | VOLUME PER SHIPMENT | Curies* Per Shipment |
|----------------------|------------------------------------------------------------------------------------------------------------------|----------------------|---------------|---------------------------|----------------------------|
| 07/11/2001 | DRY ACTIVE WASTE, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG-TIGHT CONTAINER, NONE | EXCLUSIVE-USE | OAK RIDGE, TN | 3.63E+01 | 3.68E-01 |
| 08/15/2001 | MIXED BED ION-EXCHANGE MEDIA, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG-TIGHT CONTAINER, NONE | EXCLUSIVE-USE | ERWIN, TN | 5.87E+00 | 1.62E+01 |
| 08/31/2001 | OIL, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG-TIGHT CONTAINER, NONE | EXCLUSIVE-USE | RICHLAND, WA | 2.40E+01 | 5.46E-03 |
| 08/31/2001 | DRY ACTIVE WASTE, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG TIGHT CONTAINER, NONE | EXCLUSIVE-USE | OAK RIDGE, TN | 7.25E+01 | 6.00E-02 |
| Quarterly Totals | | | | 1.39E+02 | 1.66E+01 |
| Number of Shipments: | | | 4 | CUBIC M | CURIES |

* Calculated using measured ratios

BYRON NUCLEAR POWER STATION
UNIT 1/2, DOCKET NUMBER STN-50-454/455
RADIOACTIVE EFFLUENT RELEASE REPORT
JANUARY, 2001 THROUGH DECEMBER, 2001

SOLID RADIOACTIVE WASTE FOR BURIAL 4TH QUARTER, 2001

| DATE | DISPOSITION OF MATERIAL (DESCRIPTION, CLASS, TYPE AND SOLIDIFYING AGENT) | MODE OF TRANSPORT | DESTINATION | VOLUME PER SHIPMENT | Curies* Per Shipment |
|----------------------|----------------------------------------------------------------------------------------------------------------------------------------|----------------------|---------------|---------------------------|----------------------------|
| 10/09/2001 | DRY ACTIVE WASTE, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG-TIGHT CONTAINER, NONE | EXCLUSIVE-USE | OAK RIDGE, TN | 3.63E+01 | 3.27E-05 |
| 10/23/2001 | MIXED BED ION-EXCHANGE MEDIA, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, RQ, CLASS A, STRONG TIGHT CONTAINER, NONE | EXCLUSIVE-USE | KINGSTON, TN | 4.84E+00 | 2.00E+01 |
| 11/07/2001 | DRY ACTIVE WASTE, MIXED BED ION- EXCHANGE MEDIA, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG-TIGHT CONTAINER, NONE | EXCLUSIVE-USE | OAK RIDGE, TN | 3.63E+01 | 1.18E-03 |
| 11/15/2001 | DRY ACTIVE WASTE, LOW SPECIFIC ACTIVITY, nos, 7, UN2912, CLASS A, STRONG-TIGHT CONTAINER, NONE | EXCLUSIVE-USE | OAK RIDGE, TN | 7.25E+01 | 1.80E-01 |
| Quarterly Totals | | | | 1.50E+02 | 2.02E+01 |
| Number of Shipments: | | | 4 | CUBIC M | CURIES |

* Calculated using measured ratios

Solid Radioactive Waste for Burial, Addendum

A. Estimated Solid Waste Composition

| Resins, Filters, Evap Bottoms | | |
|-------------------------------|-----------|----------|
| Percent | | |
| Nuclide | Abundance | uCi/ml |
| H-3 | 0.896 | 8.99E-02 |
| Be-7 | 2.256 | 2.26E-01 |
| C-14 | 0.275 | 2.76E-02 |
| Cr-51 | 0.362 | 3.63E-02 |
| Mn-54 | 5.499 | 5.52E-01 |
| Fe-55 | 24.989 | 2.51E+00 |
| Fe-59 | 0.081 | 8.13E-03 |
| Co-57 | 0.519 | 5.21E-02 |
| Co-58 | 35.164 | 3.53E+00 |
| Co-60 | 13.361 | 1.34E+00 |
| Ni-63 | 14.888 | 1.49E+00 |
| Zn-65 | 0.143 | 1.44E-02 |
| Sr-90 | 0.008 | 8.03E-04 |
| Zr-95 | 0.171 | 1.72E-02 |
| Nb-95 | 0.223 | 2.24E-02 |
| Mo-99 | 0.000 | 2.24E-07 |
| Tc-99 | 0.001 | 1.23E-04 |
| Sn-113 | 0.030 | 3.01E-03 |
| Sb-125 | 0.398 | 4.00E-02 |
| I-129 | 0.001 | 1.42E-04 |
| I-131 | 0.000 | 1.49E-06 |
| Cs-134 | 0.001 | 1.00E-04 |
| Cs-137 | 0.157 | 1.58E-02 |
| La-140 | 0.004 | 4.02E-04 |
| Ce-144 | 0.566 | 5.68E-02 |
| Pu-238 | 0.001 | 8.97E-05 |
| Pu-239 | 0.000 | 4.40E-05 |
| Pu-241 | 0.008 | 8.03E-04 |
| Am-241 | 0.001 | 5.42E-05 |
| Cm-242 | 0.000 | 1.52E-05 |
| Cm-243 | 0.000 | 2.14E-08 |

| Dry Active Waste | | |
|------------------|-----------|----------|
| Percent | | |
| Nuclide | Abundance | uCi/ml |
| H-3 | 2.779 | 6.29E-05 |
| C-14 | 0.073 | 1.65E-06 |
| Cr-51 | 34.093 | 7.71E-04 |
| Mn-54 | 1.030 | 2.33E-05 |
| Fe-55 | 7.353 | 1.66E-04 |
| Fe-59 | 1.731 | 3.92E-05 |
| Co-57 | 0.065 | 1.47E-06 |
| Co-58 | 33.881 | 7.67E-04 |
| Co-60 | 3.748 | 8.48E-05 |
| Ni-63 | 3.976 | 9.00E-05 |
| Zn-65 | 0.162 | 3.67E-06 |
| Sr-90 | 0.000 | 2.13E-09 |
| Zr-95 | 2.152 | 4.87E-05 |
| Zr-97 | 0.008 | 1.81E-07 |
| Nb-95 | 2.840 | 6.43E-05 |
| Mo-99 | 0.011 | 2.49E-07 |
| Tc-99 | 0.000 | 1.11E-09 |
| Ag-110m | 0.041 | 9.28E-07 |
| Sn-113 | 0.066 | 1.49E-06 |
| Sb-125 | 0.077 | 1.74E-06 |
| Te-123m | 0.023 | 5.20E-07 |
| Te-125m | 4.950 | 1.12E-04 |
| I-129 | 0.000 | 1.28E-09 |
| Cs-134 | 0.000 | 5.08E-09 |
| Cs-137 | 0.048 | 1.09E-06 |
| Ce-144 | 0.742 | 1.68E-05 |
| Hf-181 | 0.149 | 3.37E-06 |
| Pu-238 | 0.000 | 7.43E-10 |
| Pu-239 | 0.000 | 3.62E-10 |
| Pu-241 | 0.002 | 4.88E-08 |
| Am-241 | 0.000 | 4.50E-10 |
| Cm-242 | 0.000 | 5.34E-10 |
| Cm-243 | 0.000 | 5.67E-10 |

| Other (Contaminated Oil) | | |
|--------------------------|-----------|----------|
| Percent | | |
| Nuclide | Abundance | uCi/ml |
| H-3 | 66.807 | 2.18E-05 |
| Be-7 | 1.217 | 3.97E-07 |
| C-14 | 0.130 | 4.24E-08 |
| Mn-54 | 0.606 | 1.98E-07 |
| Fe-55 | 12.526 | 4.08E-06 |
| Co-58 | 0.902 | 2.94E-07 |
| Co-60 | 6.523 | 2.13E-06 |
| Ni-63 | 7.059 | 2.30E-06 |
| Sr-90 | 0.002 | 6.52E-10 |
| Tc-99 | 0.000 | 2.84E-11 |
| I-129 | 0.000 | 3.28E-11 |
| Cs-134 | 0.098 | 3.19E-08 |
| Cs-137 | 3.646 | 1.19E-06 |
| Ce-144 | 0.480 | 1.56E-07 |
| Pu-238 | 0.000 | 2.06E-11 |
| Pu-239 | 0.000 | 1.01E-11 |
| Pu-241 | 0.004 | 1.24E-09 |
| Am-241 | 0.000 | 1.25E-11 |
| Cm-242 | 0.000 | 1.08E-11 |
| Cm-243 | 0.000 | 3.28E-11 |

BYRON NUCLEAR POWER STATION
UNIT 1/2 DOCKET NUMBER STN-50-454/455
RADIOACTIVE EFFLUENT RELEASE REPORT
January, 2001 THROUGH December, 2001

- A. Changes to Radioactive Waste Process Control Program for 2001 were primarily administrative in nature. Operationally, the Process Control Program remains unchanged.
- B. Error Analysis

The following is an estimate of the errors associated with effluent monitoring and analysis. The estimate is calculated using the square root of the sum of the squares methodology.

1. Gaseous Effluents

Sampling error = 1 to 3.5%
Calibration error = 5%
Counting statistics error = 5%
Vent stack flowrates error = 1.5%

Total error = 7 – 8%

2. Liquid Effluents

Sampling error = 1%
Calibration error = 5%
Sample volume error = 1%
Discharged volume error = 2%
Counting statistics error = 0.41%

Total error = 5.6%

3. Waste Resin

Sample prep = 5%
Sampling error = 1%
Counting statistic error = 1%
Weight error = 0.5%
Calibration error = 5%

Total error = 7.2%

4. DAW, Mechanical Filters, and Contaminated Metal

Counting statistic error = 1%
Calibration error = 5%
Instrument calibration error = 10%

Total error = 11%

BYRON NUCLEAR POWER STATION
UNIT 1/2 DOCKET NUMBER STN-50-454/455
RADIOACTIVE EFFLUENT RELEASE REPORT
January, 2001 THROUGH December, 2001

- C. Meteorological and environmental impact information is reported in the Station Annual Radiological Environmental Operating Report as required by Technical Specification 5.6.2.
- D. No limits were exceeded in liquid hold up tanks as stated in Technical Specification 5.5.12 or in waste gas decay tanks as stated in Technical Specification 5.5.12.
- E. There were no irradiated fuel shipments during this period.
- F. There were no elevated releases. All releases are considered vent or ground level releases.
- G. No liquid or Gaseous Effluent Monitor exceeded the specified LCO time limit.
- H. In the third quarter of 2001, the REMP well location BY-14-1, was added to replace well sampling location BY-14. The original collection site had its electrical service discontinued to the pump, and samples were no longer able to be acquired. The new location is in Sector H at a distance of 1.6 km.
- J. Attached are Offsite Dose Calculations for January through December of 2001.

Attachment A, 2001 Radioactive Effluent Release Report

Lower Limit of Detection
Gaseous Effluents

| Nuclides | LLD (Ci/ml) |
|-------------|-------------|
| H3 | 4.03E-14 |
| Ar41 | 6.25E-12 |
| Cr51 | 3.29E-18 |
| Mn54 | 7.63E-19 |
| Co58 | 5.76E-19 |
| Fe59 | 1.70E-18 |
| Co60 | 1.25E-18 |
| Zn65 | 1.84E-18 |
| Kr85m | 2.39E-18 |
| Kr87 | 5.79E-18 |
| Kr88 | 7.10E-18 |
| Sr89 | 4.80E-18 |
| Sr-90 | 8.46E-19 |
| Mo99 | 3.38E-19 |
| I131 | 6.13E-19 |
| Xe131m | 1.06E-16 |
| I133 | 7.04E-08 |
| Xe133 | 7.13E-18 |
| Xe133m | 2.20E-17 |
| Cs134 | 5.19E-19 |
| I135 | 3.83E-18 |
| Xe135 | 2.13E-18 |
| Cs137 | 7.05E-19 |
| Xe138 | 8.41E-18 |
| Ba140 | 2.06E-18 |
| La140 | 3.51E-19 |
| Ce141 | 5.86E-19 |
| Ce144 | 2.27E-18 |
| Gross Alpha | 1.76E-18 |

Lower Limit of Detection
Aqueous Effluents

| Nuclides | LLD (Ci/ml) |
|-------------|-------------|
| H3 | 1.68E-12 |
| Na24 | 4.63E-14 |
| Cr51 | 1.73E-13 |
| Mn54 | 5.25E-14 |
| Fe55 | 2.10E-13 |
| Co57 | 1.89E-14 |
| Co58 | 3.81E-14 |
| Fe59 | 1.05E-13 |
| Co60 | 7.62E-14 |
| Zn65 | 1.13E-13 |
| Sr85 | 2.43E-14 |
| Sr89 | 1.17E-14 |
| Sr-90 | 2.70E-15 |
| Sr92 | 5.11E-14 |
| Nb95 | 3.15E-14 |
| Zr95 | 7.77E-14 |
| Mo99 | 2.41E-14 |
| Ag110m | 2.83E-14 |
| Sb122 | 4.79E-14 |
| Te123m | 1.95E-14 |
| Sb124 | 1.11E-13 |
| Sb125 | 1.08E-13 |
| Te125m | 6.93E-12 |
| Sb126 | 1.81E-14 |
| I131 | 2.52E-14 |
| I132 | 4.78E-14 |
| Te132 | 2.13E-14 |
| I133 | 3.52E-14 |
| Xe133 | 8.11E-14 |
| Cs134 | 5.25E-14 |
| Xe135 | 2.49E-14 |
| Cs137 | 5.36E-14 |
| Ba140 | 8.96E-14 |
| La140 | 5.21E-14 |
| Ce141 | 4.75E-14 |
| Ce144 | 1.67E-13 |
| Gross Alpha | 6.76E-14 |

* DELIVER TO HEALTH PHYSICS *

AIRBORNE Effluents- 10CFR50 Listing

24-mar-2002 07:34:14

STATION: BYRON STATION
UNIT: 1
PERIOD: 01/01/01 12/31/01
NAME: THOMPSON
REPORT: ANNUAL
MODE: ACTUAL

BYRON STATION UNIT ONE

ACTUAL 2001

MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 INFANT RECEPTOR

| TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|---------------------|----------------------------------------------|---------------------------|----------------------------------------------|----------------------------------------------|--------------------|
| GAMMA AIR (MRAD) | 8.65E-07 (SSE) | 1.23E-06 (SSE) | 8.39E-07 (SSE) | 1.70E-06 (SSE) | 4.63E-06 (SSE) |
| BETA AIR (MRAD) | 3.34E-06 (SSE) | 4.13E-06 (SSE) | 2.03E-06 (SSE) | 4.99E-06 (SSE) | 1.45E-05 (SSE) |
| TOT. BODY (MREM) | 6.11E-07 (SSE) | 8.76E-07 (SSE) | 6.10E-07 (SSE) | 1.22E-06 (SSE) | 3.32E-06 (SSE) |
| SKIN (MREM) | 1.71E-06 (SSE) | 2.24E-06 (SSE) | 1.40E-06 (SSE) | 3.14E-06 (SSE) | 8.50E-06 (SSE) |
| ORGAN (MREM) | 3.51E-04 (NE) | 1.10E-04 (NE) | 2.20E-04 (NE) | 3.07E-04 (NE) | 9.88E-04 (NE) |
| | LIVER THYROID KIDNEY LUNG GI_LLI | LUNG | LIVER THYROID KIDNEY LUNG GI_LLI | LIVER THYROID KIDNEY LUNG GI_LLI | LUNG |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10CFR 50 APP. I
 INFANT RECEPTOR

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|------------------|--------------|----------------------------------------------|--------------------|----------------------------------------------|----------------------------------------------|-------------|----------------|
| GAMMA AIR (MRAD) | 5.0 | 0.00 | 0.00 | 0.00 | 0.00 | 10.0 | 0.00 |
| BETA AIR (MRAD) | 10.0 | 0.00 | 0.00 | 0.00 | 0.00 | 20.0 | 0.00 |
| TOT. BODY (MREM) | 2.5 | 0.00 | 0.00 | 0.00 | 0.00 | 5.0 | 0.00 |
| SKIN (MREM) | 7.5 | 0.00 | 0.00 | 0.00 | 0.00 | 15.0 | 0.00 |
| ORGAN (MREM) | 7.5 | 0.00 | 0.00 | 0.00 | 0.00 | 15.0 | 0.01 |
| | | LIVER THYROID KIDNEY LUNG GI_LLI | LUNG | LIVER THYROID KIDNEY LUNG GI_LLI | LIVER THYROID KIDNEY LUNG GI_LLI | | LUNG |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

ACTUAL 2001
 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 CHILD RECEPTOR

| TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|---------------------|----------------------------------------------|---------------------------|----------------------------------------------|----------------------------------------------|--------------------|
| GAMMA AIR (MRAD) | 8.65E-07 (SSE) | 1.23E-06 (SSE) | 8.39E-07 (SSE) | 1.70E-06 (SSE) | 4.63E-06 (SSE) |
| BETA AIR (MRAD) | 3.34E-06 (SSE) | 4.13E-06 (SSE) | 2.03E-06 (SSE) | 4.99E-06 (SSE) | 1.45E-05 (SSE) |
| TOT. BODY (MREM) | 6.11E-07 (SSE) | 8.76E-07 (SSE) | 6.10E-07 (SSE) | 1.22E-06 (SSE) | 3.32E-06 (SSE) |
| SKIN (MREM) | 1.71E-06 (SSE) | 2.24E-06 (SSE) | 1.40E-06 (SSE) | 3.14E-06 (SSE) | 8.50E-06 (SSE) |
| ORGAN (MREM) | 2.47E-04 (NE) | 2.56E-04 (SSE) | 8.64E-04 (SSE) | 3.40E-04 (S) | 1.53E-03 (SE) |
| | LIVER THYROID KIDNEY LUNG GI_LLI | LUNG | LIVER THYROID KIDNEY LUNG GI_LLI | LIVER THYROID KIDNEY LUNG GI_LLI | LUNG |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10CFR 50 APP. I
 CHILD RECEPTOR

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|------------------|--------------|----------------------------------------------|--------------------|----------------------------------------------|----------------------------------------------|-------------|----------------|
| GAMMA AIR (MRAD) | 5.0 | 0.00 | 0.00 | 0.00 | 0.00 | 10.0 | 0.00 |
| BETA AIR (MRAD) | 10.0 | 0.00 | 0.00 | 0.00 | 0.00 | 20.0 | 0.00 |
| TOT. BODY (MREM) | 2.5 | 0.00 | 0.00 | 0.00 | 0.00 | 5.0 | 0.00 |
| SKIN (MREM) | 7.5 | 0.00 | 0.00 | 0.00 | 0.00 | 15.0 | 0.00 |
| ORGAN (MREM) | 7.5 | 0.00 | 0.00 | 0.01 | 0.00 | 15.0 | 0.01 |
| | | LIVER THYROID KIDNEY LUNG GI_LLI | LUNG | LIVER THYROID KIDNEY LUNG GI_LLI | LIVER THYROID KIDNEY LUNG GI_LLI | | LUNG |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

ACTUAL 2001
 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 TEENAGER RECEPTOR

| TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|---------------------|----------------------------------------------|---------------------------|----------------------------------------------|----------------------------------------------|--------------------|
| GAMMA AIR (MRAD) | 8.65E-07 (SSE) | 1.23E-06 (SSE) | 8.39E-07 (SSE) | 1.70E-06 (SSE) | 4.63E-06 (SSE) |
| BETA AIR (MRAD) | 3.34E-06 (SSE) | 4.13E-06 (SSE) | 2.03E-06 (SSE) | 4.99E-06 (SSE) | 1.45E-05 (SSE) |
| TOT. BODY (MREM) | 6.11E-07 (SSE) | 8.76E-07 (SSE) | 6.10E-07 (SSE) | 1.22E-06 (SSE) | 3.32E-06 (SSE) |
| SKIN (MREM) | 1.71E-06 (SSE) | 2.24E-06 (SSE) | 1.40E-06 (SSE) | 3.14E-06 (SSE) | 8.50E-06 (SSE) |
| ORGAN (MREM) | 1.61E-04 (NE) | 1.70E-04 (SE) | 5.63E-04 (SSE) | 2.44E-04 (S) | 1.04E-03 (S) |
| | LIVER THYROID KIDNEY LUNG GI_LLI | LUNG | LIVER THYROID KIDNEY LUNG GI_LLI | LIVER THYROID KIDNEY LUNG GI_LLI | LUNG |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10CFR 50 APP. I
 TEENAGER RECEPTOR

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|------------------|--------------|----------------------------------------------|--------------------|----------------------------------------------|----------------------------------------------|-------------|----------------|
| GAMMA AIR (MRAD) | 5.0 | 0.00 | 0.00 | 0.00 | 0.00 | 10.0 | 0.00 |
| BETA AIR (MRAD) | 10.0 | 0.00 | 0.00 | 0.00 | 0.00 | 20.0 | 0.00 |
| TOT. BODY (MREM) | 2.5 | 0.00 | 0.00 | 0.00 | 0.00 | 5.0 | 0.00 |
| SKIN (MREM) | 7.5 | 0.00 | 0.00 | 0.00 | 0.00 | 15.0 | 0.00 |
| ORGAN (MREM) | 7.5 | 0.00 | 0.00 | 0.01 | 0.00 | 15.0 | 0.01 |
| | | LIVER THYROID KIDNEY LUNG GI_LLI | LUNG | LIVER THYROID KIDNEY LUNG GI_LLI | LIVER THYROID KIDNEY LUNG GI_LLI | | LUNG |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

ACTUAL 2001
 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 ADULT RECEPTOR

| TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|---------------------|----------------------------------------------|---------------------------|----------------------------------------------|----------------------------------------------|--------------------|
| GAMMA AIR (MRAD) | 8.65E-07 (SSE) | 1.23E-06 (SSE) | 8.39E-07 (SSE) | 1.70E-06 (SSE) | 4.63E-06 (SSE) |
| BETA AIR (MRAD) | 3.34E-06 (SSE) | 4.13E-06 (SSE) | 2.03E-06 (SSE) | 4.99E-06 (SSE) | 1.45E-05 (SSE) |
| TOT. BODY (MREM) | 6.11E-07 (SSE) | 8.76E-07 (SSE) | 6.10E-07 (SSE) | 1.22E-06 (SSE) | 3.32E-06 (SSE) |
| SKIN (MREM) | 1.71E-06 (SSE) | 2.24E-06 (SSE) | 1.40E-06 (SSE) | 3.14E-06 (SSE) | 8.50E-06 (SSE) |
| ORGAN (MREM) | 2.24E-04 (S) | 1.69E-04 (S) | 5.02E-04 (SE) | 2.93E-04 (S) | 1.17E-03 (S) |
| | LIVER THYROID KIDNEY LUNG GI_LLI | GI_LLI | LIVER THYROID KIDNEY LUNG GI_LLI | LIVER THYROID KIDNEY LUNG GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10CFR 50 APP. I
 ADULT RECEPTOR

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|------------------|--------------|----------------------------------------------|--------------------|----------------------------------------------|----------------------------------------------|-------------|----------------|
| GAMMA AIR (MRAD) | 5.0 | 0.00 | 0.00 | 0.00 | 0.00 | 10.0 | 0.00 |
| BETA AIR (MRAD) | 10.0 | 0.00 | 0.00 | 0.00 | 0.00 | 20.0 | 0.00 |
| TOT. BODY (MREM) | 2.5 | 0.00 | 0.00 | 0.00 | 0.00 | 5.0 | 0.00 |
| SKIN (MREM) | 7.5 | 0.00 | 0.00 | 0.00 | 0.00 | 15.0 | 0.00 |
| ORGAN (MREM) | 7.5 | 0.00 | 0.00 | 0.01 | 0.00 | 15.0 | 0.01 |
| | | LIVER THYROID KIDNEY LUNG GI_LLI | GI_LLI | LIVER THYROID KIDNEY LUNG GI_LLI | LIVER THYROID KIDNEY LUNG GI_LLI | | GI_LLI |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

* DELIVER TO HEALTH PHYSICS *

AQUATIC Effluents- 10CFR50 Listing

24-mar-2002 07:39:32

STATION: BYRON STATION
UNIT: 1
PERIOD: 01/01/01 12/31/01
NAME: THOMPSON
REPORT: ANNUAL
MODE: ACTUAL

BYRON STATION UNIT ONE

ACTUAL 2001
 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 INFANT RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-------------------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL BODY | 5.23E-04 | 3.36E-04 | 5.55E-04 | 6.63E-04 | 2.08E-03 |
| INTERNAL ORGAN | 5.23E-04 | 3.37E-04 | 5.55E-04 | 6.64E-04 | 2.08E-03 |
| | GI_LLI | THYROID | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|--------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| TOTAL BODY (MREM) | 1.5 | 0.03 | 0.02 | 0.04 | 0.04 | 3.0 | 0.07 |
| CRIT. ORGAN (MREM) | 5.0 | 0.01 | 0.01 | 0.01 | 0.01 | 10.0 | 0.02 |
| | | GI_LLI | THYROID | GI_LLI | GI_LLI | | GI_LLI |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

2001 ANNUAL REPORT

PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM *
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 INFANT RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-------------------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL BODY | 5.23E-04 | 3.36E-04 | 5.55E-04 | 6.63E-04 | 2.08E-03 |
| INTERNAL ORGAN | 5.23E-04 | 3.37E-04 | 5.55E-04 | 6.64E-04 | 2.08E-03 |
| | GI_LLI | THYROID | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 40 CFR 141

| TYPE | ANNUAL LIMIT | % OF LIMIT |
|-------------------|--------------|------------|
| TOTAL BODY | 4.0 MREM | 0.052 |
| INTERNAL ORGAN | 4.0 MREM | 0.052 |

GI_LLI

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

ACTUAL 2001
 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 CHILD RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-------------------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL BODY | 6.00E-04 | 4.02E-04 | 6.37E-04 | 7.77E-04 | 2.42E-03 |
| INTERNAL ORGAN | 6.25E-04 | 5.23E-04 | 7.13E-04 | 9.06E-04 | 2.77E-03 |
| | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|--------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| TOTAL BODY (MREM) | 1.5 | 0.04 | 0.03 | 0.04 | 0.05 | 3.0 | 0.08 |
| CRIT. ORGAN (MREM) | 5.0 | 0.01 | 0.01 | 0.01 | 0.02 | 10.0 | 0.03 |
| | | GI_LLI | GI_LLI | GI_LLI | GI_LLI | | GI_LLI |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

2001 ANNUAL REPORT
 PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM *
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 CHILD RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-------------------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL BODY | 5.26E-04 | 3.38E-04 | 5.58E-04 | 6.67E-04 | 2.09E-03 |
| INTERNAL ORGAN | 5.26E-04 | 3.40E-04 | 5.59E-04 | 6.70E-04 | 2.10E-03 |
| | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 40 CFR 141

| TYPE | ANNUAL LIMIT | % OF LIMIT |
|-------------------|--------------|------------|
| TOTAL BODY | 4.0 MREM | 0.052 |
| INTERNAL ORGAN | 4.0 MREM | 0.052 |

GI_LLI

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

ACTUAL 2001
 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 TEENAGER RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-------------------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL BODY | 3.61E-04 | 2.44E-04 | 3.83E-04 | 4.69E-04 | 1.46E-03 |
| INTERNAL ORGAN | 4.36E-04 | 5.66E-04 | 5.99E-04 | 8.10E-04 | 2.41E-03 |
| | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|--------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| TOTAL BODY (MREM) | 1.5 | 0.02 | 0.02 | 0.03 | 0.03 | 3.0 | 0.05 |
| CRIT. ORGAN (MREM) | 5.0 | 0.01 | 0.01 | 0.01 | 0.02 | 10.0 | 0.02 |
| | | GI_LLI | GI_LLI | GI_LLI | GI_LLI | | GI_LLI |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

2001 ANNUAL REPORT

PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM *
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 TEENAGER RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-----------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL | 2.74E-04 | 1.76E-04 | 2.91E-04 | 3.48E-04 | 1.09E-03 |
| BODY | | | | | |
| INTERNAL | 2.76E-04 | 1.79E-04 | 2.93E-04 | 3.51E-04 | 1.10E-03 |
| ORGAN | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 40 CFR 141

| TYPE | ANNUAL LIMIT | % OF LIMIT |
|----------|--------------|------------|
| TOTAL | 4.0 MREM | 0.027 |
| BODY | | |
| INTERNAL | 4.0 MREM | 0.027 |
| ORGAN | | |

GI_LLI

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

ACTUAL 2001
 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 ADULT RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL | 5.01E-04 | 3.34E-04 | 5.31E-04 | 6.46E-04 | 2.01E-03 |
| BODY INTERNAL ORGAN | 6.07E-04 | 7.53E-04 | 8.38E-04 | 1.09E-03 | 3.28E-03 |
| | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|--------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| TOTAL BODY (MREM) | 1.5 | 0.03 | 0.02 | 0.04 | 0.04 | 3.0 | 0.07 |
| CRIT. ORGAN (MREM) | 5.0 | 0.01 | 0.02 | 0.02 | 0.02 | 10.0 | 0.03 |
| | | GI_LLI | GI_LLI | GI_LLI | GI_LLI | | GI_LLI |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

2001 ANNUAL REPORT

PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM *
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 ADULT RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-----------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL | 3.89E-04 | 2.50E-04 | 4.13E-04 | 4.94E-04 | 1.55E-03 |
| BODY | | | | | |
| INTERNAL | 3.91E-04 | 2.54E-04 | 4.15E-04 | 4.98E-04 | 1.56E-03 |
| ORGAN | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 40 CFR 141

| TYPE | ANNUAL LIMIT | % OF LIMIT |
|----------|--------------|------------|
| TOTAL | 4.0 MREM | 0.039 |
| BODY | | |
| INTERNAL | 4.0 MREM | 0.039 |
| ORGAN | | |

GI_LLI

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

* DELIVER TO HEALTH PHYSICS *

24-mar-2002 07:29:59

Total Effective Dose Equivalent - 10CFR20 Listing

STATION: BYRON STATION
UNIT: 1
PERIOD: 01/01/01 12/31/01
NAME: THOMPSON
REPORT: ANNUAL
MODE: ACTUAL

For ADULT dose calculations, the included pathways are:

INHALATION
MILK
PRODUCE
VEGETABLES
MEAT
GROUND DEPOSITION
FISH
WATER
SKYSHINE
WHOLE BODY

Airborne Effluents are complete from 01/01/01 to 12/31/01
Aquatic Effluents are complete from 01/01/01 to 12/31/01

BYRON STATION UNIT ONE

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/01 TO 12/31/01

CALCULATED 03/24/02

1. 10 CFR 20.1301 (a)(1) Compliance

| | |
|------------------------------------------|---------------|
| Total Effective Dose Equivalent, mrem/yr | 2.60E-03 |
| 10 CFR 20.1301 (a)(1) limit | mrem/yr 100.0 |
| % of limit | 0.00 |

Compliance Summary - 10CFR20

| | 1st Qtr | 2nd Qtr | 3rd Qtr | 4th Qtr | % of Limit |
|------|------------|------------|------------|------------|---------------|
| TEDE | 5.30E-04 | 4.86E-04 | 7.91E-04 | 7.98E-04 | 0.00 |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
ODCM SOFTWARE VERSION 1.1 January 1995
ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT ONE

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/01 TO 12/31/01

CALCULATED 03/24/02

2. 10 CFR 20.1301 (d)/40 CFR 190 Compliance

| | | Dose (mrem) | Limit (mrem) | % of Limit |
|---------------------|-----------|----------------|-----------------|---------------|
| Whole Body (DDE) | Plume | 3.32E-06 | | |
| | Skyshine | 0.00E+00 | | |
| | Ground | 4.65E-06 | | |
| | Total | 7.97E-06 | 25.0 | 0.00 |
| Organ Dose (CDE) | Thyroid | 2.30E-03 | 75.0 | 0.00 |
| | Gonads | 2.32E-03 | 25.0 | 0.01 |
| | Breast | 2.24E-03 | 25.0 | 0.01 |
| | Lung | 2.23E-03 | 25.0 | 0.01 |
| | Marrow | 2.62E-03 | 25.0 | 0.01 |
| | Bone | 6.34E-03 | 25.0 | 0.03 |
| | Remainder | 2.79E-03 | 25.0 | 0.01 |
| | CEDE | 2.60E-03 | | |
| TEDE | 2.60E-03 | 100.0 | 0.00 | |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

* DELIVER TO HEALTH PHYSICS *

AIRBORNE Effluents- 10CFR50 Listing

24-mar-2002 09:19:43

STATION: BYRON STATION
UNIT: 2
PERIOD: 01/01/01 12/31/01
NAME: THOMPSON
REPORT: ANNUAL
MODE: ACTUAL

BYRON STATION UNIT TWO

ACTUAL 2001

MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 INFANT RECEPTOR

| TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|---------------------|---------------------------|---------------------------|---------------------------|---------------------------|--------------------|
| GAMMA AIR (MRAD) | 1.35E-06 (SSE) | 1.01E-06 (SSE) | 3.38E-07 (SSE) | 1.16E-06 (SSE) | 3.85E-06 (SSE) |
| BETA AIR (MRAD) | 3.57E-06 (SSE) | 4.08E-06 (SSE) | 1.37E-06 (SSE) | 4.10E-06 (SSE) | 1.31E-05 (SSE) |
| TOT. BODY (MREM) | 9.74E-07 (SSE) | 7.13E-07 (SSE) | 2.38E-07 (SSE) | 8.24E-07 (SSE) | 2.75E-06 (SSE) |
| SKIN (MREM) | 2.34E-06 (SSE) | 1.98E-06 (SSE) | 6.73E-07 (SSE) | 2.33E-06 (SSE) | 7.33E-06 (SSE) |
| ORGAN (MREM) | 1.24E-03 (NE) | 3.24E-04 (NE) | 1.85E-04 (NE) | 3.20E-04 (NE) | 2.07E-03 (NE) |

THYROID LUNG LUNG LUNG THYROID

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10CFR 50 APP. I
 INFANT RECEPTOR

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| GAMMA AIR (MRAD) | 5.0 | 0.00 | 0.00 | 0.00 | 0.00 | 10.0 | 0.00 |
| BETA AIR (MRAD) | 10.0 | 0.00 | 0.00 | 0.00 | 0.00 | 20.0 | 0.00 |
| TOT. BODY (MREM) | 2.5 | 0.00 | 0.00 | 0.00 | 0.00 | 5.0 | 0.00 |
| SKIN (MREM) | 7.5 | 0.00 | 0.00 | 0.00 | 0.00 | 15.0 | 0.00 |
| ORGAN (MREM) | 7.5 | 0.02 | 0.00 | 0.00 | 0.00 | 15.0 | 0.01 |

THYROID LUNG LUNG LUNG THYROID

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

ACTUAL 2001
 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 CHILD RECEPTOR

| TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|---------------------|---------------------------|---------------------------|---------------------------|---------------------------|--------------------|
| GAMMA AIR (MRAD) | 1.35E-06 (SSE) | 1.01E-06 (SSE) | 3.38E-07 (SSE) | 1.16E-06 (SSE) | 3.85E-06 (SSE) |
| BETA AIR (MRAD) | 3.57E-06 (SSE) | 4.08E-06 (SSE) | 1.37E-06 (SSE) | 4.10E-06 (SSE) | 1.31E-05 (SSE) |
| TOT. BODY (MREM) | 9.74E-07 (SSE) | 7.13E-07 (SSE) | 2.38E-07 (SSE) | 8.24E-07 (SSE) | 2.75E-06 (SSE) |
| SKIN (MREM) | 2.34E-06 (SSE) | 1.98E-06 (SSE) | 6.73E-07 (SSE) | 2.33E-06 (SSE) | 7.33E-06 (SSE) |
| ORGAN (MREM) | 8.77E-04 (NE) | 7.59E-04 (SSE) | 7.25E-04 (SSE) | 6.65E-04 (SE) | 2.60E-03 (S) |

THYROID LUNG GI_LLI GI_LLI GI_LLI
 THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10CFR 50 APP. I
 CHILD RECEPTOR

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| GAMMA AIR (MRAD) | 5.0 | 0.00 | 0.00 | 0.00 | 0.00 | 10.0 | 0.00 |
| BETA AIR (MRAD) | 10.0 | 0.00 | 0.00 | 0.00 | 0.00 | 20.0 | 0.00 |
| TOT. BODY (MREM) | 2.5 | 0.00 | 0.00 | 0.00 | 0.00 | 5.0 | 0.00 |
| SKIN (MREM) | 7.5 | 0.00 | 0.00 | 0.00 | 0.00 | 15.0 | 0.00 |
| ORGAN (MREM) | 7.5 | 0.01 | 0.01 | 0.01 | 0.01 | 15.0 | 0.02 |

THYROID LUNG GI_LLI GI_LLI GI_LLI

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

ACTUAL 2001

MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES

PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02

TEENAGER RECEPTOR

| TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|---------------------|---------------------------|---------------------------|---------------------------|---------------------------|--------------------|
| GAMMA AIR (MRAD) | 1.35E-06 (SSE) | 1.01E-06 (SSE) | 3.38E-07 (SSE) | 1.16E-06 (SSE) | 3.85E-06 (SSE) |
| BETA AIR (MRAD) | 3.57E-06 (SSE) | 4.08E-06 (SSE) | 1.37E-06 (SSE) | 4.10E-06 (SSE) | 1.31E-05 (SSE) |
| TOT. BODY (MREM) | 9.74E-07 (SSE) | 7.13E-07 (SSE) | 2.38E-07 (SSE) | 8.24E-07 (SSE) | 2.75E-06 (SSE) |
| SKIN (MREM) | 2.34E-06 (SSE) | 1.98E-06 (SSE) | 6.73E-07 (SSE) | 2.33E-06 (SSE) | 7.33E-06 (SSE) |
| ORGAN (MREM) | 5.72E-04 (NE) | 5.02E-04 (SE) | 4.74E-04 (SSE) | 4.40E-04 (SE) | 1.85E-03 (S) |

THYROID LUNG GI_LLI GI_LLI GI_LLI

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10CFR 50 APP. I

TEENAGER RECEPTOR

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| GAMMA AIR (MRAD) | 5.0 | 0.00 | 0.00 | 0.00 | 0.00 | 10.0 | 0.00 |
| BETA AIR (MRAD) | 10.0 | 0.00 | 0.00 | 0.00 | 0.00 | 20.0 | 0.00 |
| TOT. BODY (MREM) | 2.5 | 0.00 | 0.00 | 0.00 | 0.00 | 5.0 | 0.00 |
| SKIN (MREM) | 7.5 | 0.00 | 0.00 | 0.00 | 0.00 | 15.0 | 0.00 |
| ORGAN (MREM) | 7.5 | 0.01 | 0.01 | 0.01 | 0.01 | 15.0 | 0.01 |

THYROID LUNG GI_LLI GI_LLI GI_LLI

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

ACTUAL 2001
 MAXIMUM DOSES RESULTING FROM AIRBORNE RELEASES
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 ADULT RECEPTOR

| TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|---------------------|---------------------------|---------------------------|---------------------------|---------------------------|--------------------|
| GAMMA AIR (MRAD) | 1.35E-06 (SSE) | 1.01E-06 (SSE) | 3.38E-07 (SSE) | 1.16E-06 (SSE) | 3.85E-06 (SSE) |
| BETA AIR (MRAD) | 3.57E-06 (SSE) | 4.08E-06 (SSE) | 1.37E-06 (SSE) | 4.10E-06 (SSE) | 1.31E-05 (SSE) |
| TOT. BODY (MREM) | 9.74E-07 (SSE) | 7.13E-07 (SSE) | 2.38E-07 (SSE) | 8.24E-07 (SSE) | 2.75E-06 (SSE) |
| SKIN (MREM) | 2.34E-06 (SSE) | 1.98E-06 (SSE) | 6.73E-07 (SSE) | 2.33E-06 (SSE) | 7.33E-06 (SSE) |
| ORGAN (MREM) | 7.95E-04 (S) | 4.98E-04 (S) | 4.23E-04 (SE) | 4.54E-04 (S) | 2.15E-03 (S) |

THYROID GI_LLI GI_LLI GI_LLI GI_LLI

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10CFR 50 APP. I
 ADULT RECEPTOR

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| GAMMA AIR (MRAD) | 5.0 | 0.00 | 0.00 | 0.00 | 0.00 | 10.0 | 0.00 |
| BETA AIR (MRAD) | 10.0 | 0.00 | 0.00 | 0.00 | 0.00 | 20.0 | 0.00 |
| TOT. BODY (MREM) | 2.5 | 0.00 | 0.00 | 0.00 | 0.00 | 5.0 | 0.00 |
| SKIN (MREM) | 7.5 | 0.00 | 0.00 | 0.00 | 0.00 | 15.0 | 0.00 |
| ORGAN (MREM) | 7.5 | 0.01 | 0.01 | 0.01 | 0.01 | 15.0 | 0.01 |

THYROID GI_LLI GI_LLI GI_LLI GI_LLI

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

* DELIVER TO HEALTH PHYSICS *

AQUATIC Effluents- 10CFR50 Listing

24-mar-2002 07:41:17

STATION: BYRON STATION
UNIT: 2
PERIOD: 01/01/01 12/31/01
NAME: THOMPSON
REPORT: ANNUAL
MODE: ACTUAL

BYRON STATION UNIT TWO

ACTUAL 2001
 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 INFANT RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-------------------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL BODY | 5.23E-04 | 3.36E-04 | 5.55E-04 | 6.63E-04 | 2.08E-03 |
| INTERNAL ORGAN | 5.23E-04 | 3.37E-04 | 5.55E-04 | 6.64E-04 | 2.08E-03 |
| | GI_LLI | THYROID | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|--------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| TOTAL BODY (MREM) | 1.5 | 0.03 | 0.02 | 0.04 | 0.04 | 3.0 | 0.07 |
| CRIT. ORGAN (MREM) | 5.0 | 0.01 | 0.01 | 0.01 | 0.01 | 10.0 | 0.02 |
| | | GI_LLI | THYROID | GI_LLI | GI_LLI | | GI_LLI |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

2001 ANNUAL REPORT
 PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM *
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 INFANT RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-----------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL | 5.23E-04 | 3.36E-04 | 5.55E-04 | 6.63E-04 | 2.08E-03 |
| BODY | | | | | |
| INTERNAL | 5.23E-04 | 3.37E-04 | 5.55E-04 | 6.64E-04 | 2.08E-03 |
| ORGAN | GI_LLI | THYROID | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 40 CFR 141

| TYPE | ANNUAL LIMIT | % OF LIMIT |
|----------|--------------|------------|
| TOTAL | 4.0 MREM | 0.052 |
| BODY | | |
| INTERNAL | 4.0 MREM | 0.052 |
| ORGAN | | |

GI_LLI

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

ACTUAL 2001
 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 CHILD RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-----------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL | 6.00E-04 | 4.02E-04 | 6.37E-04 | 7.77E-04 | 2.42E-03 |
| BODY | | | | | |
| INTERNAL | 6.25E-04 | 5.23E-04 | 7.13E-04 | 9.06E-04 | 2.77E-03 |
| ORGAN | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|--------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| TOTAL BODY (MREM) | 1.5 | 0.04 | 0.03 | 0.04 | 0.05 | 3.0 | 0.08 |
| CRIT. ORGAN (MREM) | 5.0 | 0.01 | 0.01 | 0.01 | 0.02 | 10.0 | 0.03 |
| | | GI_LLI | GI_LLI | GI_LLI | GI_LLI | | GI_LLI |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

2001 ANNUAL REPORT

PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM *
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 CHILD RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-----------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL | 5.26E-04 | 3.38E-04 | 5.58E-04 | 6.67E-04 | 2.09E-03 |
| BODY | | | | | |
| INTERNAL | 5.26E-04 | 3.40E-04 | 5.59E-04 | 6.70E-04 | 2.10E-03 |
| ORGAN | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 40 CFR 141

| TYPE | ANNUAL LIMIT | % OF LIMIT |
|----------|--------------|------------|
| TOTAL | 4.0 MREM | 0.052 |
| BODY | | |
| INTERNAL | 4.0 MREM | 0.052 |
| ORGAN | | |

GI_LLI

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

ACTUAL 2001
 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 TEENAGER RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-------------------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL BODY | 3.61E-04 | 2.44E-04 | 3.83E-04 | 4.69E-04 | 1.46E-03 |
| INTERNAL ORGAN | 4.36E-04 | 5.66E-04 | 5.99E-04 | 8.10E-04 | 2.41E-03 |
| | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|--------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| TOTAL BODY (MREM) | 1.5 | 0.02 | 0.02 | 0.03 | 0.03 | 3.0 | 0.05 |
| CRIT. ORGAN (MREM) | 5.0 | 0.01 | 0.01 | 0.01 | 0.02 | 10.0 | 0.02 |
| | | GI_LLI | GI_LLI | GI_LLI | GI_LLI | | GI_LLI |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

2001 ANNUAL REPORT
 PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM *
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 TEENAGER RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-----------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL | 2.74E-04 | 1.76E-04 | 2.91E-04 | 3.48E-04 | 1.09E-03 |
| BODY | | | | | |
| INTERNAL | 2.76E-04 | 1.79E-04 | 2.93E-04 | 3.51E-04 | 1.10E-03 |
| ORGAN | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 40 CFR 141

| TYPE | ANNUAL LIMIT | % OF LIMIT |
|----------|--------------|------------|
| TOTAL | 4.0 MREM | 0.027 |
| BODY | | |
| INTERNAL | 4.0 MREM | 0.027 |
| ORGAN | | |

GI_LLI

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

ACTUAL 2001
 MAXIMUM DOSES (MREM) RESULTING FROM AQUATIC EFFLUENTS
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 ADULT RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|-----------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL | 5.01E-04 | 3.34E-04 | 5.31E-04 | 6.46E-04 | 2.01E-03 |
| BODY | | | | | |
| INTERNAL | 6.07E-04 | 7.53E-04 | 8.38E-04 | 1.09E-03 | 3.28E-03 |
| ORGAN | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 10 CFR 50 APP. I

----- % OF APP I. -----

| | QTRLY OBJ | 1ST QTR JAN-MAR | 2ND QTR APR-JUN | 3RD QTR JUL-SEP | 4TH QTR OCT-DEC | YRLY OBJ | % OF APP. I |
|--------------------|--------------|--------------------|--------------------|--------------------|--------------------|-------------|----------------|
| TOTAL BODY (MREM) | 1.5 | 0.03 | 0.02 | 0.04 | 0.04 | 3.0 | 0.07 |
| CRIT. ORGAN (MREM) | 5.0 | 0.01 | 0.02 | 0.02 | 0.02 | 10.0 | 0.03 |
| | | GI_LLI | GI_LLI | GI_LLI | GI_LLI | | GI_LLI |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

2001 ANNUAL REPORT
 PROJECTED DOSE AT NEAREST COMMUNITY WATER SYSTEM *
 PERIOD OF RELEASE - 01/01/01 TO 12/31/01 CALCULATED 03/24/02
 ADULT RECEPTOR

| DOSE TYPE | 1ST QUARTER JAN-MAR | 2ND QUARTER APR-JUN | 3RD QUARTER JUL-SEP | 4TH QUARTER OCT-DEC | ANNUAL |
|---------------------------|---------------------------|---------------------------|---------------------------|---------------------------|----------|
| TOTAL | 3.89E-04 | 2.50E-04 | 4.13E-04 | 4.94E-04 | 1.55E-03 |
| BODY INTERNAL ORGAN | 3.91E-04 | 2.54E-04 | 4.15E-04 | 4.98E-04 | 1.56E-03 |
| | GI_LLI | GI_LLI | GI_LLI | GI_LLI | GI_LLI |

THIS IS A REPORT FOR THE CALENDAR YEAR 2001

COMPLIANCE STATUS - 40 CFR 141

| TYPE | ANNUAL LIMIT | % OF LIMIT |
|---------------------------|--------------|------------|
| TOTAL | 4.0 MREM | 0.039 |
| BODY INTERNAL ORGAN | 4.0 MREM | 0.039 |

GI_LLI

* THIS CALCULATION OF DOSE IS BASED ON TECHNIQUES DESCRIBED IN THE COMMONWEALTH EDISON OFFSITE DOSE CALCULATION MANUAL. THESE TECHNIQUES DIFFER FROM THOSE DESCRIBED IN 40 CFR 141.

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995

* DELIVER TO HEALTH PHYSICS *

24-mar-2002 07:31:11

Total Effective Dose Equivalent - 10CFR20 Listing

STATION: BYRON STATION
UNIT: 2
PERIOD: 01/01/01 12/31/01
NAME: THOMPSON
REPORT: ANNUAL
MODE: ACTUAL

For ADULT dose calculations, the included pathways are:

INHALATION
MILK
PRODUCE
VEGETABLES
MEAT
GROUND DEPOSITION
FISH
WATER
SKYSHINE
WHOLE BODY

Airborne Effluents are complete from 01/01/01 to 12/31/01
Aquatic Effluents are complete from 01/01/01 to 12/31/01

BYRON STATION UNIT TWO

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/01 TO 12/31/01

CALCULATED 03/24/02

1. 10 CFR 20.1301 (a)(1) Compliance

| | |
|------------------------------------------|----------|
| Total Effective Dose Equivalent, mrem/yr | 3.44E-03 |
| 10 CFR 20.1301 (a)(1) limit mrem/yr | 100.0 |
| % of limit | 0.00 |

Compliance Summary - 10CFR20

| | 1st Qtr | 2nd Qtr | 3rd Qtr | 4th Qtr | % of Limit |
|------|------------|------------|------------|------------|---------------|
| TEDE | 1.02E-03 | 7.61E-04 | 7.28E-04 | 9.30E-04 | 0.00 |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
ODCM SOFTWARE VERSION 1.1 January 1995
ODCM DATABASE VERSION 1.1 January 1995

BYRON STATION UNIT TWO

10 CFR 20 COMPLIANCE ASSESSMENT

PERIOD OF ASSESSMENT 01/01/01 TO 12/31/01

CALCULATED 03/24/02

2. 10 CFR 20.1301 (d)/40 CFR 190 Compliance

| | | Dose (mrem) | Limit (mrem) | % of Limit |
|---------------------|-----------|----------------|-----------------|---------------|
| Whole Body (DDE) | Plume | 2.75E-06 | | |
| | Skyshine | 0.00E+00 | | |
| | Ground | 7.53E-06 | | |
| | Total | 1.03E-05 | 25.0 | 0.00 |
| Organ Dose (CDE) | Thyroid | 3.13E-03 | 75.0 | 0.00 |
| | Gonads | 3.16E-03 | 25.0 | 0.01 |
| | Breast | 3.07E-03 | 25.0 | 0.01 |
| | Lung | 3.07E-03 | 25.0 | 0.01 |
| | Marrow | 3.46E-03 | 25.0 | 0.01 |
| | Bone | 7.18E-03 | 25.0 | 0.03 |
| | Remainder | 3.63E-03 | 25.0 | 0.01 |
| | CEDE | 3.43E-03 | | |
| TEDE | 3.44E-03 | 100.0 | 0.00 | |

RESULTS BASED UPON: ODCM ANNEX REVISION 1.3 MARCH 1996
 ODCM SOFTWARE VERSION 1.1 January 1995
 ODCM DATABASE VERSION 1.1 January 1995