

Millstone

REMODCM

Revision 22

SECTION I

RADIOLOGICAL EFFLUENT

MONITORING MANUAL (REMM)

**FOR THE
MILLSTONE NUCLEAR POWER STATION
UNIT NOs. 1, 2, & 3**

DOCKET NOs. 50-245, 50-336, 50-423

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND OFF-SITE DOSE CALCULATION MANUAL
(REMDCM)
PAGE CHANGE SUMMARY**

<u>Page</u>	<u>Rev</u>	<u>Date</u>
I.A-1	21	1/26/01
I.B-1	22	
I.C-1	22	
I.C-2	22	
I.C-3	22	
I.C-4	22	
I.C-5	22	
I.C-6	19	6/15/00
I.C-7	22	
I.C-8	22	
I.C-9	19	6/15/00
I.C-10	22	
I.C-11	22	
I.C-12	22	
I.C-13	18	1/03/00
I.C-14	18	1/03/00
I.C-15	18	1/03/00
I.D-1	22	
I.D-2	22	
I.D-3	22	
I.D-4	22	
I.D-5	21	1/26/01
I.D-6	22	
I.D-7	22	
I.D-8	21	1/26/01
I.D-9	20	1/25/01
I.D-10	22	
I.D-11	22	
I.D-12	21	1/26/01
I.D-13	21	1/26/01
I.E-1	22	
I.E-2	20	1/25/01
I.E-3	22	
I.E-4	22	
I.E-5	21	1/26/01
I.E-6	21	1/26/01
I.E-7	21	1/26/01
I.E-8	21	1/26/01
I.E-9	21	1/26/01
I.E-10	21	1/26/01
I.E-11	21	1/26/01
I.E-12	21	1/26/01
I.E-13	21	1/26/01
I.F-1	18	1/03/00
I.F-2	22	

<u>Page</u>	<u>Rev</u>	<u>Date</u>
II.A-1	20	1/25/01
II.B-1	22	
II.C-1	22	
II.C-2	22	
II.C-3	22	
II.C-4	22	
II.C-5	19	6/15/00
II.C-6	18	1/03/00
II.D-1	22	
II.D-2	22	
II.D-3	21	1/26/01
II.D-4	22	
II.D-5	22	
II.D-6	22	
II.D-7	22	
II.D-8	22	
II.D-9	21	1/26/01
II.D-10	21	1/26/01
II.D-11	22	
II.D-12	22	
II.D-13	21	1/26/01
II.D-14	22	
II.D-15	21	1/26/01
II.E-1	22	
II.E-2	22	
II.E-3	22	
II.E-4	22	
II.E-5	22	
II.E-6	22	
II.E-7	22	
II.E-8	22	
II.E-9	22	
II.F-1	22	
II.F-2	22	
II.F-3	22	
II.F-4	20	1/25/01
App II.A-1	22	
App II.A-2	22	

<u>Page</u>	<u>Rev</u>	<u>Date</u>
III.A-1	18	1/03/00
III.B-1	18	1/03/00
III.C-1	22	
III.C-2	22	
III.C-3	22	
III.C-4	22	
III.C-5	22	
III.C-6	22	
III.C-7	22	
III.C-8	22	
III.C-9	22	
III.C-10	22	
III.C-11	19	6/15/00
III.C-12	19	6/15/00
III.C-13	21	1/26/01
III.D-1	22	
III.D-2	22	
III.D-3	22	
III.D-4	18	1/03/00
III.D-5	19	6/15/00
III.D-6	18	1/03/00
III.E-1	22	
III.F-1	22	
III.F-2	22	
III.F-3	18	1/03/00
III.F-4	22	

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND OFFSITE DOSE CALCULATION MANUAL
(REMODCM)**

SECTION I: RADIOLOGICAL EFFLUENT MONITORING MANUAL (REMM)

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE NO.</u>
PAGE CHANGE SUMMARY.....	I-i
TABLE OF CONTENTS.....	I-ii
I.A. INTRODUCTION.....	I.A-1
I.B. RESPONSIBILITIES.....	I.B-1
I.C. LIQUID EFFLUENTS	
1. Liquid Effluents Sampling And Analysis Program.....	I.C-1
2. Liquid Radioactive Waste Treatment.....	I.C-11
3. Bases.....	I.C-12
I.D. GASEOUS EFFLUENTS	
1. Gaseous Effluents Sampling And Analysis Program.....	I.D-1
2. Gaseous Radioactive Waste Treatment.....	I.D-9
3. Bases.....	I.D-10
I.E. RADIOLOGICAL ENVIRONMENTAL MONITORING	
1. Sampling And Analysis.....	I.E-1
2. Land Use Census.....	I.E-12
3. Interlaboratory Comparison Program.....	I.E-13
4. Bases.....	I.E-13
I.F. REPORT CONTENT	
1. Annual Radiological Environmental Operating Report.....	I.F-1
2. Radioactive Effluent Release Report.....	I.F-2

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND OFFSITE DOSE CALCULATION MANUAL
(REMODCM)**

SECTION I: RADIOLOGICAL EFFLUENT MONITORING MANUAL (REMM)

**TABLE OF CONTENTS
(Cont'd)**

<u>Table No.</u>	<u>Table Name</u>	<u>Page</u>
I.C-1	Radioactive Liquid Waste Sampling and Analysis Program - Millstone Unit 1	I.C-2
I.C-2	Radioactive Liquid Waste Sampling and Analysis Program - Millstone Unit 2	I.C-5
I.C-3	Radioactive Liquid Waste Sampling and Analysis Program - Millstone Unit 3	I.C-8
I.D-1	Radioactive Gaseous Waste Sampling and Analysis Program - Millstone Unit 1	I.D-2
I.D-2	Radioactive Gaseous Waste Sampling and Analysis Program - Millstone Unit 2	I.D-4
I.D-3	Radioactive Gaseous Waste Sampling and Analysis Program - Millstone Unit 3	I.D-7
I.E-1	Millstone Radiological Environmental Monitoring Program	I.E-3
I.E-2	Environmental Monitoring Program - Sampling Locations	I.E-4
I.E-3	Reporting Levels for Radioactivity concentrations in Environmental Samples	I.E-9
I.E-4	Maximum Values for Lower Limits of Detection (LLD)	I.E-10

<u>Figure No.</u>	<u>Figure Name</u>	<u>Page</u>
I.C-1	RESERVED	I.C-13
I.C-2	Simplified Liquid Effluent Flow Diagram - Millstone Unit 2	I.C-14
I.C-3	Simplified Liquid Effluent Flow Diagram - Millstone Unit 3	I.C-15
I.D-1	Simplified Airborne Effluent Flow Diagram - Millstone Unit 1	I.D-11
I.D-2	Simplified Airborne Effluent Flow Diagram - Millstone Unit 2	I.D-12
I.D-3	Simplified Airborne Effluent Flow Diagram - Millstone Unit 3	I.D-13
I.E-1	Inner Air Particulate and Vegetation Monitoring Stations	I.E-6
I.E-2	Outer Terrestrial Monitoring Stations	I.E-7
I.E-3	Aquatic Sampling Stations	I.E-8

I.A. INTRODUCTION

The purpose of Section I of this manual is to provide the sampling and analysis programs which provide input to Section II for calculating liquid and gaseous effluent concentrations and offsite doses. Guidelines are provided for operating radioactive waste treatment systems in order that offsite doses are kept As-Low-As-Reasonably-Achievable (ALARA).

The *Radiological Environmental Monitoring Program* outlined within this manual provides confirmation that the measurable concentrations of radioactive material in the environment as a result of operations at the Millstone Site are not higher than expected.

In addition, this manual outlines the information required to be submitted to the NRC in both the *Annual Radiological Environmental Operating Report* and the *Radioactive Effluent Release Report*.

I.B. RESPONSIBILITIES

All changes to the Radiological Effluent Monitoring Manual (REMM) shall be reviewed and approved by the Site Operations Review Committee prior to implementation.

All changes and their rationale shall be documented in the *Radioactive Effluent Release Report*.

It shall be the responsibility of the Vice President and Senior Nuclear Executive - Millstone to ensure that this manual is used as required by the administrative controls of the *Technical Specifications*. The delegation of implementation responsibilities is delineated in the *Millstone Radiological Effluent Program Reference Manual (MP-13-REM-REF01)*.

I.C. LIQUID EFFLUENTS**1. Liquid Effluent Sampling and Analysis Program**

Radioactive liquid wastes shall be sampled and analyzed in accordance with the program specified in **Table I.C-1** for Millstone Unit No. 1, **Table I.C-2** for Millstone Unit No. 2, and **Table I.C-3** for Millstone Unit No. 3. The results of the radioactive analyses shall be input to the methodology of Section II to assure that the concentrations at the point of release are maintained within the limits of Radiological Effluent Controls (Section III D.1.a for Millstone Unit No. 1, Section IV.D.1.a for Millstone Unit No. 2, and Section V.D.1.a for Millstone Unit No. 3).

Table I.C-1

MILLSTONE UNIT 1

RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM

Liquid Release Source	Sample Type and Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Lower Limit of Detection (LLD)^A (μCi/ml)
TABLE RESERVED				

This page intentionally blank

|

This page intentionally blank

Table I.C-2
MILLSTONE UNIT 2
RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM

Liquid Release Source	Sample Type and Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Lower Limit of Detection (LLD) ^A (μCi/ml)	
A. Batch Release 1. Clean Waste Monitor Tank ^B , Aerated Waste Monitor Tank ^B and Steam Generator Bulk ^{B,D} * 2. Condensate Polishing Facility - Waste Neutralization Sump ^{B,E} * 3. RBCCW Sump ^M *	Grab Sample Prior to Each Batch Release	Prior to Each Batch Release	Principal Gamma Emitters ^C	5 x 10 ⁻⁷	
			I-131	1 x 10 ⁻⁶	
			Ce-144	5 x 10 ⁻⁶	
	Except for RBCCW Sump: For RBCCW Sump: Prior to aligning to Long Island Sound; then, daily grab sample ^I	Monthly Composite ^{F,G}	H-3	Dissolved and Entrained Gases ^K	1 x 10 ⁻⁵
				Gross alpha	1 x 10 ⁻⁷
				Sr-89, Sr-90	5 x 10 ⁻⁸
				Fe-55	1 x 10 ⁻⁶
B. Continuous Release 1. Steam Generator Blowdown ^H * 2. Service Water Effluent ^J * 3. Turbine Building Sumps ^L *	Daily Grab Sample ^I	Weekly Composite ^{F,G}	Principal Gamma Emitters ^C	5 x 10 ⁻⁷	
			I-131	1 x 10 ⁻⁶	
			Ce-144	5 x 10 ⁻⁶	
	Monthly Grab Sample	Monthly	Dissolved and Entrained Gases ^K	1 x 10 ⁻⁵	
	Weekly Grab or Composite	Monthly Composite ^{F,G}	H-3	Gross alpha	1 x 10 ⁻⁷
				Sr-89, Sr-90	5 x 10 ⁻⁸
				Fe-55	1 x 10 ⁻⁶
Weekly Composite				Quarterly Composite ^{F,G}	

* There is a Conditional Action Requirement associated with this notation.

TABLE I.C-2 (Cont'd.)**TABLE NOTATIONS****INFORMATIONAL NOTES:**

- A. The LLD is the smallest concentration of radioactive material in a sample that will be detected with 95% probability with 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$LLD = \frac{4.66 S_b}{E \cdot V \cdot 2.22 \times 10^6 \cdot Y \cdot \exp(-\lambda \Delta t)}$$

where:

LLD is the lower limit of detection as defined above (as μCi per unit mass or volume)

S_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (as counts per minute)

E is the counting efficiency (as counts per transformation)

V is the sample size (in units of mass or volume)

2.22×10^6 is the number of transformations per minute per microcurie

Y is the fractional radiochemical yield (when applicable)

λ is the radioactive decay constant for the particular radionuclide

Δt is the elapsed time between midpoint of sample collection and midpoint of counting time

It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement.

Analyses shall be performed in such a manner that the stated LLDs will be achieved under routine conditions. Occasionally background fluctuations, unavoidably small sample sizes, the presence of interfering nuclides, or other uncontrollable circumstances may render these LLDs unachievable. In such cases, the contributing factors will be identified and recorded on the analysis sheet for the particular sample.

- B. A batch release is the discharge of liquid wastes of a discrete volume from the tanks listed in this table. Prior to the sampling, each batch shall be isolated and at least two tank/sump volumes shall be recirculated or equivalent mixing provided. If the steam generator bulk can not be recirculated prior to batch discharge, samples will be obtained by representative compositing during discharge.
- C. The LLD will be $5 \times 10^{-7} \mu\text{Ci/ml}$. The principal gamma emitters for which this LLD applies are exclusively the following radionuclides: Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, and Ce-141. Ce-144 shall also be measured, but with an LLD of $5 \times 10^{-6} \mu\text{Ci/ml}$. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level. When unusual circumstances result in a priori LLDs higher than required, the reasons shall be documented in the *Radioactive Effluent Release Report*.

TABLE I.C-2 (Cont'd.)**TABLE NOTATIONS**

- F. For Batch Releases and Steam Generator Blowdown only, a composite sample is one in which the quantity of liquid sampled is proportional to the quantity of liquid waste discharged and in which the method of sampling employed results in a specimen which is representative of the liquids released.
- G. Prior to analysis, all samples taken for the composite shall be thoroughly mixed in order for the composite sample to be representative of the effluents released.
- I. Daily grab samples shall be taken at least five days per week. For service water, daily grabs shall include each train that is in-service.
- K. LLD applies exclusively to the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level. When unusual circumstances result in a priori LLDs higher than required, the reasons shall be documented in the *Radioactive Effluent Release Report*.

CONDITIONAL ACTION REQUIREMENTS

- D. For the Steam Generator Bulk:
IF the applicable batch gamma activity is not greater than 5×10^{-7} $\mu\text{Ci/ml}$,
THEN the sampling and analysis schedule for gross alpha, Sr-89, Sr-90, Fe-55 are not required.
- E. For the Condensate Polishing Facility (CPF) waste neutralization sump:
IF there is no detectable tritium in the steam generators,
THEN tritium sampling and analyses is not required.
IF the gross gamma activity in the grab sample taken prior to release does not exceed 5×10^{-7} $\mu\text{Ci/ml}$,
THEN the sampling and analysis schedule for gross alpha, Sr-89, Sr-90 and Fe-55 are not required.
- H. For the Steam Generator Blowdown:
IF the steam generator gross gamma activity does not exceed 5×10^{-7} $\mu\text{Ci/ml}$,
THEN the sampling and analysis schedule for all principal gamma, I-131, Ce-144, noble gases, gross alpha, Sr-89, Sr-90 and Fe-55 are not required.
- J. For the Service Water:
IF a weekly gamma analysis does not indicate a gamma activity greater than 5×10^{-7} $\mu\text{Ci/ml}$,
THEN the sampling and analysis schedule for gross alpha, Sr-89, Sr-90, Fe-55 are not required.
- L. For the Turbine Building Sump:
IF there is no detectable tritium in the steam generators,
THEN tritium sampling and analyses is not required.
IF the steam generator gross gamma activity does not exceed 5×10^{-7} $\mu\text{Ci/ml}$, **OR** sump is directed to radwaste treatment,
THEN the sampling and analysis schedule for all principal gamma, I-131, Ce-144, noble gases, gross alpha, Sr-89, Sr-90 and Fe-55 are not required.
IF the release pathway is directed to yard drains,
THEN the LLD for I-131 shall be 1.5×10^{-7} $\mu\text{Ci/ml}$ and for gross alpha 1×10^{-8} $\mu\text{Ci/ml}$.
- M. For the RBCCW Sump:
IF the RBCCW Sump is directed to radwaste treatment or is not aligned to Long Island Sound,
THEN sampling is not required.
IF the applicable batch gamma activity is not greater than 5×10^{-7} $\mu\text{Ci/ml}$,
THEN the sampling and analysis schedule for gross alpha, Sr-89, Sr-90, Fe-55 are not required.

Table I.C-3

**MILLSTONE UNIT 3
RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM**

Liquid Release Source	Sample Type and Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Lower Limit of Detection (LLD) ^A (μCi/ml)	
A. Batch Release^B 1. Condensate Polishing Facility - Waste Neutralization Sump ^{E*} 2. Waste Test Tanks Low Level Waste Drain Tank, Boron Test Tanks and Steam Generator Bulk ^{D*}	Grab Sample Prior to Each Batch Release	Prior to Each Batch Release	Principal Gamma Emitters ^C	5 x 10 ⁻⁷	
			I-131	1 x 10 ⁻⁶	
			Ce-144	5 x 10 ⁻⁶	
			Dissolved and Entrained Gases ^K	1 x 10 ⁻⁵	
			Monthly Composite ^{F,G}	H-3	1 x 10 ⁻⁵
			Quarterly Composite ^{F,G}	Gross alpha	1 x 10 ⁻⁷
				Sr-89, Sr-90 [*]	5 x 10 ⁻⁸
	Fe-55	1 x 10 ⁻⁶			
B. Continuous Release 1. Steam Generator Blowdown ^{H*} 2. Service Water Effluent ^{J*} 3. Turbine Building Sumps ^{L*}	Daily Grab Sample ^I	Weekly Composite ^{F,G}	Principal Gamma Emitters ^C	5 x 10 ⁻⁷	
			I-131 ^{L*}	1 x 10 ⁻⁶	
			Ce-144	5 x 10 ⁻⁶	
		Monthly Grab Sample	Monthly	Dissolved and Entrained Gases ^K	1 x 10 ⁻⁵
		Weekly Grab or Composite	Monthly Composite ^{F,G}	H-3	1 x 10 ⁻⁵
		Weekly Composite	Quarterly Composite ^{F,G}	Gross alpha	1 x 10 ⁻⁷
				Sr-89, Sr-90	5 x 10 ⁻⁸
				Fe-55	1 x 10 ⁻⁶

* There is a Conditional Action Requirement associated with this notation.

TABLE I.C-3 (Cont'd.)**TABLE NOTATIONS****INFORMATIONAL NOTES:**

- A. The LLD is the smallest concentration of radioactive material in a sample that will be detected with 95% probability with 5% probability of falsely concluding that a blank observation represents a "real" signal. For a particular measurement system (which may include radiochemical separation):

$$LLD = \frac{4.66 S_b}{E \cdot V \cdot 2.22 \times 10^6 \cdot Y \cdot \exp(-\lambda \Delta t)}$$

where:

LLD is the lower limit of detection as defined above (as μCi per unit mass or volume)

S_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (as counts per minute)

E is the counting efficiency (as counts per transformation)

V is the sample size (in units of mass or volume)

2.22×10^6 is the number of transformations per minute per microcurie

Y is the fractional radiochemical yield (when applicable)

λ is the radioactive decay constant for the particular radionuclide

Δt is the elapsed time between midpoint of sample collection and midpoint of counting time

It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement.

Analyses shall be performed in such a manner that the stated LLDs will be achieved under routine conditions. Occasionally background fluctuations, unavoidably small sample sizes, the presence of interfering nuclides, or other uncontrollable circumstances may render these LLDs unachievable. In such cases, the contributing factors will be identified and recorded on the analysis sheet for the particular sample.

- B. A batch release is the discharge of liquid wastes of a discrete volume from the tanks listed in this table. Prior to the sampling, each batch shall be isolated and at least two tank/sump volumes shall be recirculated or equivalent mixing provided. If the steam generator bulk can not be recirculated prior to batch discharge, samples will be obtained by representative compositing during discharge.
- C. The LLD will be $5 \times 10^{-7} \mu\text{Ci/ml}$. The principal gamma emitters for which this LLD applies are exclusively the following radionuclides: Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, and Ce-141. Ce-144 shall also be measured, but with an LLD of $5 \times 10^{-6} \mu\text{Ci/ml}$. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level. When unusual circumstances result in a a priori LLDs higher than required, the reasons shall be documented in the *Radioactive Effluent Release Report*.

TABLE I.C-3 (Cont'd.)TABLE NOTATIONS

- F. For Batch Releases and Steam Generator Blowdown only, a composite sample is one in which the quantity of liquid sampled is proportional to the quantity of liquid waste discharged and in which the method of sampling employed results in a specimen which is representative of the liquids released.
- G. Prior to analysis, all samples taken for the composite shall be thoroughly mixed in order for the composite sample to be representative of the effluents released.
- I. Daily grab samples shall be taken at least five days per week. For service water, daily grabs shall include each train that is in-service.
- K. LLD applies exclusively to the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138.
This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level. When unusual circumstances result in a priori LLDs higher than required, the reasons shall be documented in the *Radioactive Effluent Release Report*.

CONDITIONAL ACTION REQUIREMENTS

- D. For the Steam Generator Bulk:
IF the applicable batch gamma activity is not greater than 5×10^{-7} $\mu\text{Ci/ml}$,
THEN the sampling and analysis schedule for gross alpha, Sr-89, Sr-90 and Fe-55 are not required.
- E. For the Condensate Polishing Facility (CPF) waste neutralization sump:
IF there is no detectable tritium in the steam generators,
THEN tritium sampling and analysis is not required.

IF the gross gamma activity in the grab sample taken prior to release does not exceed 5×10^{-7} uCi/ml ,
THEN the sampling and analysis schedule for gross alpha, Sr-89, Sr-90 and Fe-55 are not required.
- H. For the Steam Generator Blowdown:
IF the steam generator gross gamma activity does not exceed 5×10^{-7} $\mu\text{Ci/ml}$,
THEN the sampling and analysis for all principal gamma, I-131, Ce-144, noble gases, gross alpha, Sr-89, Sr-90 and Fe-55 are not required.

Steam Generator Blowdown samples are not required when blowdown is being recovered.
- J. For Service Water:
IF a weekly gamma analysis does not indicate a gamma activity greater than 5×10^{-7} $\mu\text{Ci/ml}$,
THEN the sampling and analysis schedule for gross alpha, Sr-89, Sr-90 and Fe-55 are not required.
- L. For the Turbine Building Sump:
IF there is no detectable tritium in the steam generators,
THEN tritium sampling and analyses is not required.
IF the steam generator gross gamma activity does not exceed 5×10^{-7} $\mu\text{Ci/ml}$, **OR** sump is directed to radwaste treatment,
THEN the sampling and analysis schedule for all principal gamma, I-131, Ce-144, noble gases, gross alpha, Sr-89, Sr-90 and Fe-55 are not required.
IF the Turbine Building sump release is directed to yard drains,
THEN the LLD for I-131 shall be 1.5×10^{-7} $\mu\text{Ci/ml}$ and for gross alpha 1×10^{-8} $\mu\text{Ci/ml}$.

I.C. **LIQUID EFFLUENTS (Cont'd)**

2. **Liquid Radioactive Waste Treatment**

a. **Dose Criteria for Equipment Operability Applicable to All Millstone Units**

The following dose criteria shall be applied separately to each Millstone unit.

1. **IF** the radioactivity concentration criteria for the Unit 3 steam generator blowdown is exceeded with blowdown recovery not available to maintain releases to as low as reasonably achievable; or, **IF** any of the other radioactive waste processing equipment listed in Section b are not routinely operating, **THEN** doses due to liquid effluents from the applicable waste stream to unrestricted areas shall be projected at least once per 31 days in accordance with the methodology and parameters in Section II.C.5.
2. **IF** any of these dose projections exceeds 0.006 mrem to the total body or 0.02 mrem to any organ, **THEN** best efforts shall be made to return the inoperable equipment to service, or to limit discharges via the applicable waste stream.
3. **IF** an actual dose due to liquid effluents exceeds 0.06 mrem to the total body or 0.2 mrem to any organ, **AND** the dose from the applicable waste stream exceeds 10% of one of these limits, **THEN** prepare and submit to the Commission a Special Report within 30 days as specified in Section c.

b. **Required Equipment for Each Millstone Unit**

Best efforts shall be made to return the applicable liquid radioactive waste treatment system equipment specified below for each unit to service or to limit discharge via the applicable waste stream if the projected doses exceed any of the doses specified above.

1. Millstone Unit No. 1

Waste Stream	Processing Equipment
NONE	No equipment required

2. Millstone Unit No. 2

Waste Stream	Processing Equipment
Clean liquid	Deborating ion exchanger (T11) OR
	Purification ion exchanger (T10A or T10B) OR
	Equivalent ion exchanger
	Primary demineralizer (T22 A or B) OR
Aerated liquid	Equivalent demineralizer
	Secondary demineralizer (T23 A or B) OR
	Equivalent demineralizer

3. Millstone Unit No. 3

Waste Stream	Processing Equipment or Radioactivity Concentration
High level	Demineralizer filter (LWS-FLT3) and Demineralizer (LWS-DEMN2) OR Demineralizer (LWS-DEMN1) and Demineralizer filter (LWS-FLT1)
Boron recovery	Cesium ion exchanger (DEMN A or B) Boron evaporator (EV-1)
Low level	High level processing equipment
Steam generator blowdown	Blowdown recovery when total gamma activity exceeds 5E-7 µCi/ml or tritium activity exceeds 0.02 µCi/ml.

I.C.2 Liquid Radioactive Waste Treatment (Cont'd)

C. Report Requirement For All Three Millstone Units

If required by Section a(3), prepare and submit to the Commission a Special Report within 30 days with the following content:

- Explanation of why liquid radwaste was being discharged without treatment, identification of any inoperable equipment or subsystems, and the reason for the inoperability,
- Action(s) taken to restore the inoperable equipment to OPERABLE status, and
- Summary description of action(s) taken to prevent a recurrence.

3. Basis for Liquid Sampling, Analysis and Radioactive Treatment System Use

Paragraph (a)(2) of Part 50.36a provides that licensee will submit an annual report to the Commission which specifies the quantity of each of the principal radionuclides released to unrestricted areas in liquid effluents during the past 12 months of plant operation. The indicated liquid surveillance programs (as directed by surveillance requirements for Radiological Effluent Controls in Sections III.D.1.a, IV.D.1.a, and V.D.1.a) provides the means to quantify and report on liquid discharges from release pathways. As specified in Regulatory Guide 1.21, this program monitors all major and potentially significant paths for release of radioactive material in liquid effluents during normal reactor operations, including anticipated operational occurrences. There are many minor release pathways which are not routinely monitored. The Millstone Effluent Control Program includes, as needed, evaluations to determine if any release point should be added to the REMODCM surveillance program. This information also provides for the assessment of effluent concentrations and environmental dose impacts for the purpose of demonstration compliance with the effluent limits of 10 CFR 20, and dose objectives of 10 CFR 50, Appendix I. The required detection capabilities for radioactive materials in liquid waste samples are tabulated in terms of Lower Limits of Detection (LLDs) and are selected such that the detection of radioactivity in effluent releases will occur at levels below which effluent concentration limits and off-site dose objectives would be exceeded. The LLDs are listed in Table 4.11-1 of NUREG-1301 except for the LLD for Ce-144 which is contained in Footnote (3) of Table 4.11-1 of NUREG-1301.

The indicated liquid radwaste treatment equipment for each Unit have been determined, using the GALE code, to be capable to minimize radioactive liquid effluents such that the dose objectives of Appendix I can be met for expected routine (and anticipated operational occurrence) effluent releases. This equipment is maintained and routinely operated to treat appropriate liquid waste streams without regards to projected environmental doses.

If not already in use, the requirement that the appropriate portions of the liquid radioactive waste treatment system for each Unit be returned to service when the specified effluent doses are exceeded provides assurance that the release of radioactive materials in liquid effluents will be kept "as low as is reasonably achievable." This condition of equipment usage implements the requirements of 10 CFR 50.36a, General Design Criterion 60 of Appendix A to 10 CFR 50, and the design objective given in Section II.D of Appendix I to 10 CFR Part 50. The specified dose limits governing the required use of appropriate portions of the liquid radwaste treatment system were selected as a suitable fraction of the dose design objectives set forth in Section II.A of Appendix I, 10 CFR 50 for liquid effluents following the guidance given in NUREG-1301.

FIGURE RESERVED

FIGURE I.C-1




FIGURE I.C-2
SIMPLIFIED LIQUID EFFLUENT FLOW DIAGRAM
MILLSTONE UNIT TWO




FIGURE I.C-3
SIMPLIFIED LIQUID EFFLUENT FLOW DIAGRAM
MILLSTONE UNIT THREE

I.D. GASEOUS EFFLUENTS**1. Gaseous Effluent Sampling and Analysis Program**

Radioactive gaseous wastes shall be sampled and analyzed in accordance with the program specified in **Table I.D-1** for Millstone Unit No. 1, **Table I.D-2** for Millstone Unit No. 2, and **Table I.D-3** for Millstone Unit No. 3. The results of the radioactive analyses shall be input to the methodology of Section II to assure that offsite dose rates are maintained within the limits of Radiological Effluent Controls (Section III.D.2.a for Millstone Unit No. 1, Section IV.D.2.a for Millstone Unit No. 2, and Section V.D.2.a for Millstone Unit No. 3).

Table I.D-1**MILLSTONE UNIT 1****RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM**

Gaseous Release Point or Source	Sample Type and Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Lower Limit of Detection (LLD)^A (μCi/cc)
A. Spent Fuel Pool Island Vent	Monthly ^{D*} - Gaseous Grab Sample	Monthly	Kr-85	1×10^{-4}
			H-3	1×10^{-6}
	Continuous ^{B,E*} Particulate Sample	Twice per month	Principal Particulate Gamma Emitters ^C - (with half lives greater than 8 days)	1×10^{-11}
	Continuous ^{B,E*} Particulate Sample	Quarterly Composite	Sr-90 Gross alpha	1×10^{-11}
B. Balance of Plant Vent	Continuous ^{B,E*} Particulate Sample	Twice per month	Principal Particulate Gamma Emitters ^C - (with half lives greater than 8 days)	1×10^{-11}
		Quarterly Composite	Sr-90 Gross alpha	1×10^{-11}
	Grab sample of Reactor Bldg evaporator staging tank prior to processing	Prior to processing of each batch	H-3	1×10^{-5}

*There is a Conditional Action Requirement associated with this notation.

TABLE I.D-1 (Cont'd.)TABLE NOTATIONS

- A. The lower limit of detection (LLD) is defined in *Table Notations, Item a, of Tables C-1, C-2, or C-3.*
- B. The ratio of the sample flow rate to the sampled stream flow rate shall be known.
- C. For particulate samples, the LLD will be 1×10^{-11} $\mu\text{Ci/cc}$. The principal gamma emitters for which this LLD applies are exclusively the following radionuclides: Mn-54, Co-60, Zn-65, Cs-134, Cs-137, and Ce-144. The list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level for that nuclide. When unusual circumstances result in a priori LLDs higher than required, the reasons shall be documented in the *Radioactive Effluent Release Report*.

CONDITIONAL ACTION REQUIREMENTS:

- D. **IF** there is an unexplained increase of the SFPI Vent noble gas monitor of greater than a factor of ten, **OR** the monitor reads $8.8\text{E-}5$ uCi/cc or greater, **THEN** sampling and analysis shall also be performed within 24 hours.
- E. Continuous when exhaust fans are in operation.

Table I.D-2

**MILLSTONE UNIT 2
RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM**

Gaseous Release Point or Source	Sample Type and Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Lower Limit of Detection (LLD) ^A (μCi/cc)
A. Batch Release 1. Waste Gas Storage Tank ^H	Gaseous Grab Prior to Each Waste Gas Tank Discharge	Each Tank Discharge	Principal Gamma Emitters ^B	1 x 10 ⁻⁴
			H-3	1 x 10 ⁻⁶
B. Containment Releases 1. Containment Purge 2. Containment Venting	Gaseous Grab 1. Prior to Each Purge 2. Weekly for Venting ^{I*}	1. Prior to purge 2. Weekly for venting and prior to venting for Footnote I samples	Principal Gamma Emitters ^B	1 x 10 ⁻⁴
			H-3	1 x 10 ⁻⁶
	Particulate and Charcoal Grab Samples 1. Prior to Each Purge 2. Weekly for Containment Venting ^{I*}	1. Prior to purge 2. Weekly for venting and prior to venting for Footnote I samples	I-131 I-133	1 x 10 ⁻¹² 1 x 10 ⁻¹⁰
			Principal Particulate Gamma Emitters ^B - (I-131, others with half lives greater than 8 days)	1 x 10 ⁻¹¹
C. Continuous Release 1. Vent (RM8132B) 2. Millstone Stack (RM8169-1)	Monthly - Gaseous	Monthly ^{C*}	Principal Gamma Emitters ^B	1 x 10 ⁻⁴
	Grab Sample ^{C*}		H-3 ^{G*}	1 x 10 ⁻⁶
	Continuous Charcoal Sample ^{D,F*}	Weekly	I-131 I-133	1 x 10 ⁻¹² 1 x 10 ⁻¹⁰
	Continuous Particulate Sample ^{D,F*}	Weekly	Principal Particulate Gamma Emitters ^B - (I-131, others with half lives greater than 8 days)	1 x 10 ⁻¹¹
	Continuous Particulate Sample ^D	Quarterly Composite	Sr-89, Sr-90 Gross alpha	1 x 10 ⁻¹¹ 1 x 10 ⁻¹¹
	Continuous Noble Gas ^D	Continuous Monitor	Noble Gases - Gross Activity	1 x 10 ⁻⁶

*There is a Conditional Action Requirement associated with this notation.

TABLE I.D-2 (Cont'd.)**TABLE NOTATIONS****INFORMATIONAL NOTES:**

- A. The lower limit of detection (LLD) is defined in *Table Notations, Item a, of Tables C-1, C-2, or C-3.*
- B. For gaseous samples, the LLD will be 1×10^{-4} $\mu\text{Ci/cc}$ and for particulate samples, the LLD will be 1×10^{-11} $\mu\text{Ci/cc}$. The principal gamma emitters for which these LLDs apply are exclusively the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138 for gaseous emission and Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, I-131, Cs-134, Cs-137, Ce-141, and Ce-144 for particulate emissions. The list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level for that nuclide. When unusual circumstances result in a priori LLDs higher than required, the reasons shall be documented in the *Radioactive Effluent Release Report*.
- D. The ratio of the sample flow rate to the sampled stream flow rate shall be known.
- E. RESERVED
- H. Waste Gas Storage Tanks are normally released on a batch basis. However, for the purpose of tank maintenance, inspection, or reduction of oxygen concentration, a waste gas tank may be continuously purged with nitrogen provided the following conditions are met:
- (1) The previous batch of radioactive waste gas has been discharged to a final tank pressure of less than 5 PSIG.
 - (2) No radioactive gases have been added to the tank since the previous discharge.
 - (3) Valve lineups are verified to ensure that no radioactive waste gases will be added to the tank.
 - (4) After pressurizing the tank with nitrogen, a sample of the gas in the tank will be taken and analyzed for any residual gamma emitters and tritium prior to initiation of the nitrogen purge. The measured activity will be used to calculate the amount of activity released during the purge.

TABLE NOTATIONS

CONDITIONAL ACTION REQUIREMENTS:

- C. **IF** there is an unexplained increase of the Millstone Stack or Unit 2 Vent noble gas monitor of greater than 50%, after factoring out increases due to changes in THERMAL POWER levels, containment purges, or other explainable increases, **THEN** sampling and analysis shall also be performed within 24 hours.

- F. Samples shall be changed at least once per seven days and analyses shall be completed within 48 hours after changing.

For Unit 2 vent only:

IF reactor coolant Dose Equivalent I-131 samples, which are taken two to six hours following a THERMAL POWER change exceeding 15% of RATED THERMAL POWER in one hour, show an increase of greater than a factor of 5,

THEN special sampling and analysis of iodine and particulate filters shall also be performed. These filters shall be changed following such a five-fold increase in coolant activity and every 24 hours thereafter until the reactor coolant Dose Equivalent I-131 levels are less than a factor of 5 greater than the original coolant levels or until seven days have passed, whichever is shorter. Sample analyses shall be completed within 48 hours of changing. The LLDs may be increased by a factor of 10 for these samples.

- G. **IF** the refueling cavity is flooded and there is fuel in the cavity, **THEN** grab samples for tritium shall be taken weekly. The grab sample shall be taken from the Millstone Stack or vent where the containment ventilation is being discharged at the time of sampling.

- I. **IF**, compared to the radioactivity at the time of the weekly air sample, a Radiation Monitor RM8123 or RM8262 gas channel increases by 50% or a particulate channel increases by a factor of two, **THEN** a new containment air sample shall be taken.

Table I.D-3

MILLSTONE UNIT 3

RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM

Gaseous Release Source or Point	Sample Type and Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Lower Limit of Detection (LLD) ^A (μCi/cc)
A. Batch Release				
1. Containment Hogger Drawdown 2. Containment Purge	Gaseous, Particulate and Charcoal Grab Prior to Each Purge or Drawdown	Each Purge or Drawdown	Principal Gamma Emitters ^B	1 x 10 ⁻⁴
			I-131 I-133	1 x 10 ⁻¹² 1 x 10 ⁻¹⁰
			Principal Particulate Gamma Emitters ^B - (I-131, others with half lives greater than 8 days)	1 x 10 ⁻¹¹
			H-3	1 x 10 ⁻⁶
B. Continuous Release				
1. Unit 3 Ventilation Vent (HVR-RE10B)	Monthly - Gaseous Grab ^{c*}	Monthly ^{c*}	Principal Gamma Emitters ^B	1 x 10 ⁻⁴
			H-3 ^{G*}	1 x 10 ⁻⁶
2. Engineered Safeguards Building (HVQ-RE49)	Continuous Charcoal Sample ^{D,F*}	Weekly	I-131 I-133	1 x 10 ⁻¹² 1 x 10 ⁻¹⁰
3. Millstone Stack via SLCRS (HVR-RE19B)	Continuous Particulate Sample ^{D,F*}	Weekly	Principal Particulate Gamma Emitters ^B - (I-131, others with half lives greater than 8 days)	1 x 10 ⁻¹¹
	Continuous Particulate Sample ^D	Quarterly Composite	Sr-89, Sr-90 Gross alpha	1 x 10 ⁻¹¹ 1 x 10 ⁻¹¹
	Continuous Noble Gas ^D	Continuous Monitor	Noble Gases - Gross Activity	1 x 10 ⁻⁶

* There is a Conditional Action Requirement associated with this notation.

TABLE I.D-3 (Cont'd.)**TABLE NOTATIONS****INFORMATIONAL NOTES:**

- A. The lower limit of detection (LLD) is defined in *Table Notations, Item a*, of *Tables C-1, C-2, or C-3*.
- B. For gaseous samples, the LLD will be 1×10^{-4} $\mu\text{Ci/cc}$ and for particulate samples, the LLD will be 1×10^{-11} $\mu\text{Ci/cc}$. The principal gamma emitters for which these LLDs apply are exclusively the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138 for gaseous emission and Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, I-131, Cs-134, Cs-137, Ce-141, and Ce-144 for particulate emissions. The list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level for that nuclide. When unusual circumstances result in a priori LLDs higher than required, the reasons shall be documented in the *Radioactive Effluent Release Report*.
- D. The ratio of the sample flow rate to the sampled stream flow rate shall be known.
- E. RESERVED
- H. RESERVED

CONDITIONAL ACTION REQUIREMENTS

- C. **IF** there is an unexplained increase of the Unit 3 ventilation vent or SLCRS noble gas monitor of greater than 50%, after factoring out increases due to changes in THERMAL POWER levels, containment purges, or other explainable increases, **THEN** appropriate sampling and analysis shall also be performed within 24 hours.
- F. Samples shall be changed at least once per seven days and analyses shall be completed within 48 hours after changing.
- IF** reactor coolant Dose Equivalent I-131 samples (which are taken two to six hours following a THERMAL POWER change exceeding 15% of RATED THERMAL POWER in one hour per *Table 4.4-4* of the *Safety Technical Specifications*) show an increase of greater than a factor of 5, **THEN** special sampling and analysis of iodine and particulate filters shall also be performed. These filters shall be changed following such a five-fold increase in coolant activity and every 24 hours thereafter until the reactor coolant Dose Equivalent I-131 levels are less than a factor of 5 greater than the original coolant levels or until seven days have passed, whichever is shorter. Sample analyses shall be completed within 48 hours of changing the filters. The LLDs may be increased by a factor of 10 for these samples.
- G. **IF** the refueling cavity is flooded and there is fuel in the cavity, **THEN** grab samples for tritium shall be taken weekly from the ventilation vent.

I.D. GASEOUS EFFLUENTS (Cont'd)

2. Gaseous Radioactive Waste Treatment

a. Dose Criteria for Equipment Operability Applicable to All Millstone Units

The following dose criteria shall be applied separately to each Millstone unit.

1. **IF** any of the radioactive waste processing equipment listed in Section b are not routinely operating, **THEN** doses due to gaseous effluents from the untreated waste stream to unrestricted areas shall be projected at least once per 31 days in accordance with the methodology and parameters in Section II.D.4. For each waste stream, only those doses specified in Section II.D.4 need to be determined for compliance with this section.
2. **IF** any of these dose projections exceed 0.02 mrad for gamma radiation, 0.04 mrad for beta radiation or 0.03 mrem to any organ due to gaseous effluents, **THEN** best efforts shall be made to return the inoperable equipment to service.
3. **IF** actual doses exceed 0.2 mrad for gamma radiation, 0.4 mrad for beta radiation or 0.3 mrem to any organ **AND** the dose from a waste stream with equipment not continuously operating exceed 10% any of these limits, **THEN** prepare and submit to the Commission a report as specified in Section c.

b. Required Equipment for Each Millstone Unit

Best efforts shall be made to return the gaseous radioactive waste treatment system equipment specified below for each unit to service if the projected doses exceed any of doses specified above. For the Unit 2 gas decay tanks, the tanks shall be operated to allow enough decay time of radioactive gases to ensure that the Radiological Effluent Control dose limits are not exceeded.

1. Millstone Unit No. 1

Waste Stream	Processing Equipment
None specified	None required

2. Millstone Unit No. 2

Waste Stream	Processing Equipment
Gaseous Radwaste Treatment System	Five (5) gas decay tanks
	One waste gas compressor
Ventilation Exhaust Treatment System	Auxiliary building ventilation HEPA filter (L26 or L27)
	Containment purge HEPA filter (L25)
	Containment vent HEPA/charcoal filter (L29 A or B)

3. Millstone Unit No. 3

Waste Stream	Processing Equipment
Gaseous Radwaste Treatment System	Charcoal bed adsorbers
	One HEPA filter
Building Ventilation	Fuel building ventilation filter

c. Report Requirement For All Three Millstone Units

If required by Section I.D.2.a.3, prepare and submit to the Commission a Special Report within 30 days with the following content:

- Explanation of why gaseous radwaste was being discharged without treatment, identification of any inoperable equipment or subsystems, and the reason for the inoperability,
- Action(s) taken to restore the inoperable equipment to OPERABLE status, and
- Summary description of action(s) taken to prevent a recurrence.

I.D GASEOUS EFFLUENTS (Cont'd)**3. Basis for Gaseous Sampling, Analysis, and Radioactive Treatment System Use**

Paragraph (a)(2) of Part 50.36a provides that licensee will submit an annual report to the Commission which specifies the quantity of each of the principal radionuclides released to unrestricted areas in gaseous effluents during the past 12 months of plant operation. The indicated gaseous surveillance programs (as directed by surveillance requirements for Radiological Effluent Controls in Sections III.D.2.a, IV.D.2.a, and V.D.2.a) provides the means to quantify and report on radioactive materials released to the atmosphere. As specified in Regulatory Guide 1.21, this program monitors all major and potentially significant paths for release of radioactive material in gaseous effluents during normal reactor operations, including anticipated operational occurrences. There are many minor release pathways which are not routinely monitored. The Millstone Effluent Control Program includes, as needed, evaluations to determine if any release point should be added to the REMODCM surveillance program. This information also provides for the assessment of effluent dose rates and environmental dose impacts for the purpose of demonstration compliance with the effluent limits of 10 CFR 20, and dose objectives of 10 CFR 50, Appendix I. The required detection capabilities for radioactive materials in gaseous waste samples are tabulated in terms of lower limits of detection (LLDs) and are selected, based on NUREG-1301, such that the detection of radioactivity in releases will occur at levels below which effluent offsite dose objectives would be exceeded. The indicated gaseous radwaste treatment equipment for each Unit have been determined, using the GALE code, to be capable to minimize radioactive gaseous effluents such that the dose objectives of Appendix I can be met for expected routine (and anticipated operational occurrence) effluent releases. This equipment is maintained and routinely operated to treat appropriate gaseous waste streams without regards to projected environmental doses.

If not already in use, the requirement that the appropriate portions of the gaseous radioactive waste treatment system for each Unit be returned to service when the specified effluent doses are exceeded provides assurance that the release of radioactive materials in gaseous effluents will be kept "as low as is reasonably achievable." This condition of equipment usage implements the requirements of 10 CFR 50.36a, General Design Criterion 60 of Appendix A to 10 CFR 50, and the design objective given in Section II.D of Appendix I to 10 CFR Part 50. The specified dose limits governing the required use of appropriate portions of the gaseous radwaste treatment system were selected as a suitable fraction of the dose design objectives set forth in Section II.A of Appendix I, 10 CFR 50 for gaseous effluents following the guidance in NUREG-1301.




FIGURE I.D-1

SIMPLIFIED GASEOUS EFFLUENT FLOW DIAGRAM
MILLSTONE UNIT ONE




FIGURE I.D-2
SIMPLIFIED GASEOUS EFFLUENT FLOW DIAGRAM
MILLSTONE UNIT TWO




FIGURE I.D-3

SIMPLIFIED GASEOUS EFFLUENT FLOW DIAGRAM
MILLSTONE UNIT THREE

I.E. RADIOLOGICAL ENVIRONMENTAL MONITORING

1. Sampling and Analysis

The radiological sampling and analyses provide measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides which lead to the highest potential radiation exposures of individuals resulting from plant operation. This monitoring program thereby supplements the radiological effluent monitoring program by verifying that the measurable concentrations of radioactive materials and levels of radiation are not higher than expected on the basis of the effluent measurements and modeling of the environmental exposure pathways. Program changes may be made based on operational experience.

The sampling and analyses shall be conducted as specified in *Table I.E-1* for the locations shown *Table I.E-2*. Deviations are permitted from the required sampling schedule if specimens are unobtainable due to hazardous conditions, seasonal unavailability, malfunction of automatic sampling equipment or other legitimate reasons. If specimens are unobtainable due to sampling equipment malfunction, every effort shall be made to complete corrective action prior to the end of the next sampling period.

All deviations from the sampling schedule shall be documented in the *Annual Radiological Environmental Operating Report* pursuant to *Section I.F.1*. It is recognized that, at times, it may not be possible or practicable to continue to obtain samples of the media of choice (excluding milk) at the most desired location or time. In these instances suitable alternative media and locations may be chosen for the particular pathways in questions and appropriate substitutions made within 30 days in the radiological environmental monitoring program.

If milk samples are temporarily unavailable from any one or more of the milk sample locations required by *Table I.E-2*, a grass sample shall be substituted during the growing season (Apr. - Dec.) and analyzed for gamma isotopes and I-131 until milk is again available. Upon notification that milk samples will be unavailable for a prolonged period (>9 months) from any one or more of the milk sample locations required by *Table I.E-2*, a suitable replacement milk location shall be evaluated and appropriate changes made in the radiological environmental monitoring program. Reasonable attempts shall be made to sample the replacement milk location prior to the end of the next sampling period. Any of the above occurrences shall be documented in the *Annual Radiological Environmental Operating Report* which is submitted to the U. S. Nuclear Regulatory Commission prior to May 1 of each year.

Changes to sampling locations shall be identified in a revised *Table I.E-2* and, as necessary, *Figure(s) I.E-1* through *I.E-3*.

If the level of radioactivity in an environmental sampling medium at one or more of the locations specified in *Table I.E-2* exceeds the report levels of *Table I.E-3* when averaged over any calendar quarter, prepare and submit to the Commission within 30 days from the end of the affected calendar quarter, a Special Report which includes an evaluation of any release conditions, environmental factors or other aspects which caused the limits of *Table I.E-3* to be exceeded. When more than one of the radionuclides in *Table I.E-3* are detected in the sampling medium, this report shall be submitted if:

$$\frac{\text{concentration (1)}}{\text{reporting level (1)}} + \frac{\text{concentration (2)}}{\text{reporting level (2)}} + \dots \geq 1.0$$

I.E. RADIOLOGICAL ENVIRONMENTAL MONITORING (Cont'd)

When radionuclides other than those in *Table I.E-3* are detected and are the result of plant effluents, this report shall be submitted if the potential annual dose to an individual is equal to or greater than the appropriate calendar year limit of the *Radiological Effluent Controls (Sections III.D.1.b, III.D.2.b, or III.D.2.c for Unit 1; Sections IV.E.1b, IV.E.2.b, or IV.E.2.c for Unit 2; and Sections V.E.1.b, V.E.2.b, or V.E.2.c for Unit 3)*. This report is not required if the measured level of radioactivity was not the result of plant effluents, however, in such an event, the condition shall be reported and described in the *Annual Radiological Environmental Operating Report*.

The detection capabilities required by *Table I.E-4* are state-of-the-art for routine environmental measurements in industrial laboratories. It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement. All analyses shall be performed in such a manner that the stated LLDs will be achieved under routine conditions. Occasionally background fluctuations, unavoidably small sample sizes, the presence of interfering nuclides, or other uncontrollable circumstances may render these LLDs unachievable. In such cases, the contributing factors will be identified and described in the *Annual Radiological Environmental Operating Report*.

TABLE I.E-1**MILLSTONE RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM**

Exposure Pathway and/or Sample	Number of Locations	Sampling and Collection Frequency	Type and Frequency of Analysis
1. Gamma Dose - Environmental TLD	36 ^(a)	Quarterly	Gamma Dose - Quarterly
2. Airborne Particulate	8	Continuous sampler - weekly filter change	Gross Beta - Weekly Gamma Spectrum - Quarterly on composite (by location), and on individual sample if gross beta is greater than 10 times the mean of the weekly control station's gross beta results
3. Airborne Iodine	8	Continuous sampler - weekly canister change	I-131 - Weekly
4. Vegetation	5	One sample near middle and one near end of growing season	Gamma Isotopic on each sample
5. Milk	3	Semimonthly when animals are on pasture; monthly at other times.	Gamma Isotopic and I-131 on each sample; Sr-89 and Sr-90 on Quarterly Composite
5a. Pasture Grass	3	Sample as necessary to substitute for unavailable milk	Gamma Isotopic and I-131
6. Sea Water	2	Continuous sampler with a monthly collection at indicator location. Quarterly at control location - Composite of 6 weekly grab samples	Gamma Isotopic and Tritium on each sample.
7. Bottom Sediment	5	Semiannual	Gamma Isotopic on each sample
7a. Soil	3	Quarterly	Gamma Isotopic on each sample
8. Fin Fish-Flounder and one other type of edible fin fish (edible portion)	2	Quarterly	Gamma Isotopic on each sample
9. Mussels (edible portion)	2	Quarterly	Gamma Isotopic on each sample
10. Oysters (edible portion)	4	Quarterly	Gamma Isotopic on each sample
11. Clams (edible portion)	2	Quarterly	Gamma Isotopic on each sample
12. Lobsters (edible portion)	2	Quarterly	Gamma Isotopic on each sample

(a) Two or more TLDs or TLD with two or more elements per location.

TABLE I.E-2
ENVIRONMENTAL MONITORING PROGRAM

Sampling Locations

The following lists the environmental sampling locations and the types of samples obtained at each location. Sampling locations are also shown on Figures I.E-1, I.E-2, and I.E-3:

Location			
Number*	Name	Direction & Distance from Release Point**	Sample Types
1-I	On-Site - Old Millstone Road	0.6 Mi, NNW	TLD, Air Particulate, Iodine, Vegetation
2-I	On-Site - Weather Shack	0.3 Mi, S	TLD, Air Particulate, Iodine
3-I	On-Site - Bird Sanctuary	0.3 Mi, NE	TLD, Air Particulate, Iodine, Soil
4-I	On-Site - Albacore Drive	1.0 Mi, N	TLD, Air Particulate, Iodine, Soil
5-I	MP3 Discharge	0.1 Mi, SSE	TLD
6-I	Quarry Discharge	0.3 Mi, SSE	TLD
7-I	Environmental Lab Dock	0.3 Mi, SE	TLD
8-I	Environmental Lab	0.3 Mi, SE	TLD
9-I	Bay Point Beach	0.4 Mi, W	TLD
10-I	Pleasure Beach	1.2 Mi, E	TLD, Air Particulate, Iodine, Vegetation
11-I	New London Country Club	1.6 Mi, ENE	TLD, Air Particulate, Iodine
12-C	Fisher's Island, NY	8.0 Mi, ESE	TLD
13-C	Mystic, CT	11.5 Mi, ENE	TLD
14-C	Ledyard, CT	12.0 Mi, NE	TLD, Soil
15-C	Norwich, CT	14.0 Mi, N	TLD, Air Particulate, Iodine
16-C	Old Lyme, CT	8.8 Mi, W	TLD
17-I	Site Boundary	0.5 Mi, NE	Vegetation
21-I	Goat Location No. 1	2.0 Mi., N	Milk
22-I	Goat Location No. 2	5.2 Mi, NNE	Milk
24-C	Goat Location No. 3	29 Mi, NNW	Milk
25-I	Fruits & Vegetables	Within 10 Miles	Vegetation
26-C	Fruits & Vegetables	Beyond 10 Miles	Vegetation
27-I	Niantic	1.7 Mi, WNW	TLD, Air Particulate, Iodine
28-I	Two Tree Island	0.8 Mi, SSE	Mussels
29-I	West Jordan Cove	0.4 Mi, NNE	Clams
30-I	Niantic Shoals	1.5 Mi, NNW	Mussels
31-I	Niantic Shoals	1.8 Mi, NW	Bottom Sediment, Oysters
32-I	Vicinity of Discharge		Bottom Sediment, Oysters, Lobster, Fish, Seawater
33-I	Seaside Point	1.8 Mi, ESE	Bottom Sediment
34-I	Thames River Yacht Club	4.0 Mi, ENE	Bottom Sediment
35-I	Niantic Bay	0.3 Mi, WNW	Lobster, Fish
36-I	Black Point	3.0 Mi, WSW	Oysters
37-C	Giant's Neck	3.5 Mi, WSW	Bottom Sediment, Oysters, Seawater
38-I	Waterford Shellfish Bed No. 1	1.0 Mi, NW	Clams

* I = Indicator; C = Control

** = The release points are the Millstone Stack for terrestrial locations and the end of the quarry for aquatic location.

TABLE I.E-2 (cont.)
ENVIRONMENTAL MONITORING PROGRAM
Sampling Locations

Location			
Number*	Name	Direction & Distance from Release Point**	Sample Types
41-I	Myrock Avenue	3.2 Mi, ENE	TLD
42-I	Billow Road	2.4 Mi, WSW	TLD
43-I	Black Point	2.6 Mi, SW	TLD
44-I	Old Schoolhouse	0.1 Mi, NNE	TLD
45-I	North Access Point	0.5 Mi, NNW	TLD
46-I	Old Lyme - Hillcrest Ave.	4.6 Mi, WSW	TLD
47-I	East Lyme - W. Main St.	4.5 Mi, W	TLD
48-I	East Lyme - Corey Rd.	3.4 Mi, WNW	TLD
49-I	East Lyme - Society Rd.	3.6 Mi, NW	TLD
50-I	East Lyme - Manwaring Rd.	2.1 Mi, W	TLD
51-I	East Lyme - Smith Ave.	1.5 Mi, NW	TLD
52-I	Waterford - River Rd.	1.1 Mi, NNW	TLD
53-I	Waterford - Rt. 156 & Gardiners Wood Rd.	1.4 Mi, NNE	TLD
55-I	Waterford - Magonk Point	1.8 Mi, ESE	TLD
56-I	New London - Mott Ave.	3.7 Mi, E	TLD
57-I	New London - Ocean Ave.	3.6 Mi, ENE	TLD
59-I	Waterford - Miner Ave.	3.4 Mi, NNE	TLD
60-I	Waterford - Parkway South	4.0 Mi, N	TLD
61-I	Waterford - Boston Post Rd.	4.3 Mi, NNW	TLD

* I = Indicator; C = Control.

** = The release points are the Millstone Stack for terrestrial locations and the end of the quarry for aquatic location.

NOTE: Environmental TLDs also function as accident TLDs in support of the Millstone Emergency Plan. The 36 listed locations for TLDs are the number of environmental TLDs required by Table I.E-1. There are additional TLDs deployed in the environment not listed in this table, including TLDs needed to comply with the Millstone Emergency Plan.




FIGURE I.E-1

INNER AIR PARTICULATE AND VEGETATION MONITORING STATIONS




FIGURE I.E-2

OUTER TERRESTRIAL MONITORING STATIONS




FIGURE I.E-3

AQUATIC SAMPLING STATIONS

TABLE I.E-3**REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS
IN ENVIRONMENTAL SAMPLES**

Analysis	Water (pCi/l)	Airborne Particulate or Gases (pCi/m ³)	Fish (pCi/g, wet)	Shellfish ^(c) (pCi/g, wet)	Milk (pCi/l)	Vegetables (pCi/g, wet)
H-3	20,000 ^(a)					
Mn-54	1,000		30	140		
Fe-59	400		10	60		
Co-58	1,000		30	130		
Co-60	300		10	50		
Zn-65	300		20	80		
Zr-95	400					
Nb-95	400					
Ag-110m			8	30		
I-131	20 ^(b)	0.9	0.2	1	3	0.1
Cs-134	30	10	1	5	60	1
Cs-137	50	20	2	8	70	2
Ba-140	200				300	
La-140	200				300	

- (a) 20,000 pCi/l for drinking water samples. (This is 40 CFR Part 141 value.) For non-drinking water pathways (i.e., seawater), a value of 30,000 pCi/l may be used.
- (b) Reporting level for I-131 applies to non-drinking water pathways (i.e., seawater). If drinking water pathways are sampled, a value of 2 pCi/l is used.
- (c) For on-site samples, these values can be multiplied by 3 to account for the near field dilution factor.

TABLE I.E-4*MAXIMUM VALUES FOR LOWER LIMITS OF DETECTION (LLD)^a*

Analysis	Water (pCi/l)	Airborne Particulate or Gas (pCi/m ³)	Fish, Shellfish (pCi/kg, wet)	Milk (pCi/l)	Food Products (pCi/kg, wet)	Sediment (pCi/kg, dry)
gross beta		1 x 10 ⁻²				
H-3	2000 ^d					
Mn-54	15		130			
Fe-59	30		260			
Co-58, 60	15		130			
Zn-65	30		260			
Zr-95	30					
Nb-95	15					
I-131	15 ^c	7 x 10 ⁻²		1	60 ^b	
Cs-134	15	5 x 10 ⁻²	130	15	60	150
Cs-137	18	6 x 10 ⁻²	150	18	80	180
Ba-140	60 ^c			70		
La-140	15 ^c			25		

TABLE I.E-4 (Cont'd)**TABLE NOTATIONS**

- a. The LLD is the smallest concentration of radioactive material in a sample that will be detected with 95% probability with 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$LLD = \frac{4.66 S_b}{E \cdot V \cdot 2.22 \cdot Y \cdot \exp(-\lambda \Delta t)}$$

where:

LLD is the lower limit of detection as defined above (as pCi per unit mass or volume)

S_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (as counts per minute)

E is the counting efficiency (as counts per transformation)

V is the sample size (in units of mass or volume)

2.22 is the number of transformations per minute per picocurie

Y is the fractional radiochemical yield (when applicable)

λ is the radioactive decay constant for the particular radionuclide

Δt is the elapsed time between midpoint of sample collection (or end of the sample collection period) and time of counting.

It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement.

Analyses shall be performed in such a manner that the stated LLDs will be achieved under routine conditions. Occasionally background fluctuations, unavoidably small sample sizes, the presence of interfering nuclides, or other uncontrollable circumstances may render these LLDs unachievable. In such cases, the contributing factors will be identified in the Annual Radiological Environmental Operating Report.

- b. LLD for leafy vegetables.
- c. From end of sample period.
- d. If no drinking water pathway exists (i.e., seawater), a value of 3,000 pCi/l may be used.

I.E. RADIOLOGICAL ENVIRONMENTAL MONITORING (Cont'd)**2. Land Use Census**

The land use census ensures that changes in the use of unrestricted areas are identified and that modifications to the monitoring program are made if required by the results of this census. This census satisfies the requirements of *Section IV.B.3 of Appendix I to 10 CFR Part 50*. The land use census shall be maintained and shall identify the location of the nearest resident, nearest garden*, and milk animals in each of the 16 meteorological sectors within a distance of five miles.

The validity of the land use census shall be verified within the last half of every year by either a door-to-door survey, aerial survey, consulting local agriculture authorities, or any combination of these methods.

With a land use census identifying a location(s) which yields a calculated dose or dose commitment greater than the doses currently being calculated in the off-site dose models, make the appropriate changes in the sample locations used.

With a land use census identifying a location(s) which has a higher D/Q than a current indicator location the following shall apply:

- (1) If the D/Q is at least 20% greater than the previously highest D/Q, replace one of the present sample locations with the new one within 30 days if milk is available.
- (2) If the D/Q is not 20% greater than the previously highest D/Q, consider direction, distance, availability of milk, and D/Q in deciding whether to replace one of the existing sample locations. If applicable, replacement shall be within 30 days. If no replacement is made, sufficient justification shall be given in the annual report.

Sample location changes shall be noted in the *Annual Radiological Environmental Operating Report*.

*Broad leaf vegetation (a composite of at least 3 different kinds of vegetation) may be sampled at the site boundary in each of 2 different direction sectors with high D/Qs in lieu of a garden census.

I.E. RADIOLOGICAL ENVIRONMENTAL MONITORING (Cont'd)**3. Interlaboratory Comparison Program**

The Interlaboratory Comparison Program is provided to ensure that independent checks on the precision and accuracy of the measurements of radioactive material in environmental sample matrices are performed as part of a quality assurance program for environmental monitoring in order to demonstrate that the results are reasonably valid.

Analyses shall be performed on radioactive materials supplied as part of an Interlaboratory Comparison Program. A summary of the results obtained as part of the above required Interlaboratory Comparison Program shall be included in the Annual Radiological Environmental Operating Report.

With analyses not being performed as required above, report the corrective actions taken to prevent a recurrence to the Commission in the Annual Radiological Environmental Operating Report.

4. Bases for the Radiological Environmental Monitoring Program

Federal regulations (10 CFR Parts 20 and 50) require that radiological environmental monitoring programs be established to provide data on measurable levels of radiation and radioactive materials in the site environs. In addition, Appendix I to 10 CFR Part 50 requires that the relationship between quantities of radioactive material released in effluents during normal operation, including anticipated operational occurrences, and the resultant radiation doses to individuals from principal pathways of exposure be evaluated. The Millstone Environmental Radiological Monitoring Program (REMP) has been established to verify the effectiveness of in-plant measures used for controlling the release of radioactive materials from the plant, as well as provide for the comparison of measurable concentrations of radioactive materials found in the environment with expected levels based on effluent measurements and the modeling of the environmental exposure pathways.

The REMP detailed in Table I.E-1 provides measurements of radioactive materials or exposures in the environment along all principal exposure pathways to man that could be impacted by plant effluents. These include direct radiation exposure, inhalation exposure, and ingestion of food products (both aquatic and land grown). In addition, intermediate media such as vegetation and bottom sediments are included as potential early indicators of radioactive material buildup. The selections of sample locations include areas subject to plant effluents that would be expected to exhibit early indication of any buildup of plant related radioactive materials.

The required detection capabilities for environmental sample analyses are tabulated in terms of lower limits of detection (LLDs). Except for Ba-140 and La-140 in milk, the required LLDs are from NUREGs-1301 and 1302. The NUREGs specify an LLD of 15 pCi/l for the parent-daughter combination of Ba-La-140. An LLD of 25 pCi/l is specified for the daughter La-140 and 70 pCi/l for the parent Ba-140.

Annual reports of environmental radiation monitoring summaries are filed with the NRC in accordance with the requirements of 10 CFR Part 50.36b and the guidance contained in *Regulatory Guide 4.8, "Environmental Technical Specifications for Nuclear Power Plant,"* and *NUREG-0472 (NUREG-0473) Revision 3, "Standard Radiological Effluent Technical Specifications for Pressurized Water Reactors (Boiling Water Reactors)."*

I.F. REPORT CONTENT**1. Annual Radiological Environmental Operating Report**

The *Annual Radiological Environmental Operating Report* shall include summaries, interpretations, and statistical evaluation of the results of the radiological environmental surveillance activities for the report period, including a comparison with previous environmental surveillance reports and an assessment of the observed impacts of the plant operation on the environment. The report shall also include the results of the land use census required by *Section I.E.2* of this manual. If levels of radioactivity are detected that result in calculated doses greater than 10CFR50 Appendix I Guidelines, the report shall provide an analysis of the cause and a planned course of action to alleviate the cause.

The report shall include a summary table of all radiological environmental samples which shall include the following information for each pathway sampled and each type of analysis:

1. Total number of analyses performed at indicator locations.
2. Total number of analyses performed at control locations.
3. Lower limit of detection (LLD).
4. Mean and range of all indicator locations together.
5. Mean and range of all control locations together.
6. Name, distance and direction from discharge, mean and range for the location with the highest annual mean (indicator or control).
7. Number of nonroutine reported measurements as defined in these specifications.

In the event that some results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted in the next annual report.

This report shall include a comparison of dose assessments of the measured environmental results of the calculated effluent results to confirm the relative accuracy or conservatism of effluent monitoring dose calculations.

The report shall also include a map of sampling locations keyed to a table giving distances and directions from the discharge; the report shall also include a summary of the Interlaboratory Comparison Data required by *Section I.E.3* of this manual.

2. Radioactive Effluent Release Report

The *Radioactive Effluent Release Report (RERR)* shall include quarterly quantities of and an annual summary of radioactive liquid and gaseous effluents released from the unit in the *Regulatory Guide 1.21 (Rev. 1, June 1974)* format. Radiation dose assessments for these effluents shall be provided in accordance with 10 CFR 50.36a and the *Radiological Effluent Controls*. An annual assessment of the radiation doses from the site to the most likely exposed REAL MEMBER OF THE PUBLIC shall be included to demonstrate conformance with 40 CFR 190. Gaseous pathway doses shall use meteorological conditions concurrent with the time of radioactive gaseous effluent releases. Doses shall be calculated in accordance with the *Offsite Dose Calculation Manual*. The licensee shall maintain an annual summary of the hourly meteorological data (i.e., wind speed, wind direction and atmospheric stability) either in the form of an hour-by-hour listing on a magnetic medium or in the form of a joint frequency distribution. The licensee has the option of submitting this annual meteorological summary with the RERR or retaining it and providing it to the NRC upon request. The RERR shall be submitted prior to May 1 of each year for the period covering the previous calendar year.

The RERR shall include a summary of each type of solid radioactive waste shipped offsite for burial or final disposal during the report period and shall include the following information for each type:

- type of waste (e.g., spent resin, compacted dry waste, irradiated components, etc.)
- solidification agent (e.g., cement)
- total curies
- total volume and typical container volumes
- principal radionuclides (those greater than 10% of total activity)
- types of containers used (e.g., LSA, Type A, etc.)

The RERR shall include a list of all abnormal releases of radioactive gaseous and liquid effluents (i.e., all unplanned or uncontrolled radioactivity releases, including reportable quantities) from the site to unrestricted areas. See the REMODCM Technical Information Document (MP13-REM-REF02) for guidance on classifying releases as normal or abnormal. The following information shall be included for each abnormal release:

- total number of and curie content of releases (liquid and gas)
- a description of the event and equipment involved
- cause(s) for the abnormal release
- actions taken to prevent recurrence
- consequences of the abnormal release

Changes to the *RADIOLOGICAL EFFLUENT MONITORING* and *OFFSITE DOSE CALCULATION MANUAL (REMODCM)* shall be submitted to the NRC as appropriate, as a part of or concurrent with the RERR for the period in which the changes were made.

SECTION II

OFFSITE DOSE

CALCULATION MANUAL (ODCM)

**FOR THE
MILLSTONE NUCLEAR POWER STATION
UNIT NOs. 1, 2, & 3**

DOCKET NOs. 50-245, 50-336, 50-423

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND OFFSITE DOSE CALCULATION MANUAL
(REMODCM)**

SECTION II: OFFSITE DOSE CALCULATION MANUAL (ODCM)

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE NO</u>
TABLE OF CONTENTS	II-i
II.A. INTRODUCTION	II.A-1
II.B. RESPONSIBILITIES	II.B-1
II.C. LIQUID DOSE CALCULATIONS	II.C-1
1. Whole Body Dose from Liquid Effluents.....	II.C-1
a. Method 1 (Applicable to Units 1, 2, and 3).....	II.C-1
b. Method 2 (Applicable to Units 1, 2, and 3).....	II.C-2
2. Maximum Organ Dose from Liquid Effluents	II.C-2
a. Method 1 (Applicable to Units 1, 2, and 3).....	II.C-2
b. Method 2 (Applicable to Units 1, 2, and 3).....	II.C-2
3. Estimation of Annual Whole Body Dose (Applicable All Units).....	II.C-3
4. Estimation of Annual Maximum Organ Dose (Applicable All Units)	II.C-3
5. Monthly Dose Projections	II.C-4
a. Whole Body and Maximum Organ (Applicable Unit 1 Only).....	II.C-4
b. Whole Body and Maximum Organ (Applicable Units 2 and 3).....	II.C-5
6. Quarterly Dose Calculations for Radioactive Effluent Release Report	II.C-5
7. Bases Whole Body and Maximum Organ Liquid Doses	II.C-6
II.D. GASEOUS DOSE CALCULATIONS	II.D-1
1. Site Release Rate Limits (“Instantaneous”).....	II.D-1
a. Method 1 for Noble Gases Release Rate Limits	II.D-1
b. Method 1 for Release Rate Limit - I-131, I-133, H-3 and Particulates with Half Lives Greater than 8 Days.....	II.D-1
c. Method 2	II.D-2
2. 10CFR50 Appendix I - Noble Gas Limits	II.D-3
a. Method 1 Air Dose (Applicable to Units 1, 2, and 3)	II.D-3
b. Method 2 Air Dose (Applicable to Units 1, 2, and 3)	II.D-4
c. Estimation of Annual Air Dose Limit Due to Noble Gases (Applicable to Units 1, 2, and 3).....	II.D-4
3. 10CFR50 Appendix I - Iodine and Particulate Doses.....	II.D-5
a. Critical Organ Doses (Applicable to Unit 1 releases)	II.D-5
b. Critical Organ Doses (Applicable to Unit 2 or Unit 3 Releases to the Millstone Stack).....	II.D-5
c. Critical Organ Doses (Applicable to Units 2 and Unit 3 vent releases)	II.D-8
d. Estimation of Annual Critical Organ Dose Due to Iodines, Tritium and Particulates (Applicable to Units 1, 2, and 3).....	II.D-11

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND OFFSITE DOSE CALCULATION MANUAL
(REMODCM)**

SECTION II: OFFSITE DOSE CALCULATION MANUAL (ODCM)

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE NO</u>
4. Gaseous Effluent Monthly Dose Projections.....	II.D-12
a. Unit 1 Projection Method.....	II.D-12
b. Unit 2 Projection Method.....	II.D-13
c. Unit 3 Projection Method.....	II.D-14
5. Quarterly Dose Calculations for Radioactive Effluent Release Report	II.D-15
6. Compliance with 40CFR190	II.D-16
7. Bases for Gaseous Pathway Doses	II.D-16
II.E. LIQUID MONITOR SETPOINT CALCULATIONS.....	II.E-1
1. RESERVED.....	II.E-1
2. RESERVED.....	II.E-2
3. Unit 2 Clean Liquid Radwaste Effluent Line - RM9049.....	II.E-2
4. Unit 2 Aerated Liquid Radwaste Effluent Line and Condensate Polishing Facility Waste Neutralization Sump Effluent Line - RM9116 & CND245	II.E-4
5. a. Unit 2 Steam Generator Blowdown - RM4262.....	II.E-4
b. Unit 2 Steam Generator Blowdown Effluent Concentration Limit	II.E-5
6. Unit 2 Condenser Air Ejector - RM5099.....	II.E-5
7. a. Unit 2 Reactor Building Closed Cooling Water - RM6038	II.E-5
b. Unit 2 Service Water and Turbine Building Sump Effluent Concentration Limit	II.E-5
8. Unit 3 Liquid Waste Monitor - LWS-RE70	II.E-6
9. Unit 3 Regenerant Evaporator Effluent Line - LWC-RE65	II.E-7
10. Unit 3 Waste Neutralization Sump Effluent Line - CND-RE07.....	II.E-7
11. a. Unit 3 Steam Generator Blowdown - SSR-RE08.....	II.E-8
b. Unit 3 Steam Generator Blowdown Effluent Concentration Limit.....	II.E-8
12. a. Unit 3 Turbine Building Floor Drains Effluent Line - DAS-RE50.....	II.E-9
b. Unit 3 Service Water and Turbine Building Sump Effluent Concentration Limit	II.E-9
13. Bases for Liquid Monitor Setpoints.....	II.E-9

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND OFFSITE DOSE CALCULATION MANUAL
(REMODCM)**

SECTION II: OFFSITE DOSE CALCULATION MANUAL (ODCM)

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE NO</u>
II.F. GASEOUS - MONITOR SETPOINT CALCULATIONS	II.F-1
1. Unit 1 Spent Fuel Pool Island Vent - RM-SFPI-02	II.F-1
2. Section reserved.....	II.F-1
3. Unit 2 Wide Range Gas Monitor (WRGM) - RM8169	II.F-2
4. Unit 3 SLCRS - HVR-RE19B	II.F-2
5. Unit 2 Vent Noble Gas Monitor - RM8132B	II.F-2
6. Unit 2 Waste Gas Decay Tank Monitor - RM9095	II.F-3
7. Unit 3 Vent Noble Gas Monitor - HVR-RE10B.....	II.F-3
8. Unit 3 Engineering Safeguards Building Monitor HVQ-RE49	II.F-3
9. Bases for Gaseous Monitor Setpoints	II.F-4

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND OFFSITE DOSE CALCULATION MANUAL
(REMODCM)**

SECTION II: OFFSITE DOSE CALCULATION MANUAL (ODCM)

TABLE OF CONTENTS (Cont'd)

APPENDICES

APPENDIX II.A	REMODCM Methodology Cross-References
---------------	--------------------------------------

II.A. INTRODUCTION

The purpose of the Off-Site Dose Calculation Manual (Section II of the REMODCM) is to provide the parameters and methods to be used in calculating offsite doses and effluent monitor setpoints at the Millstone Nuclear Power Station. Included are methods for determining maximum individual whole body and organ doses due to liquid and gaseous effluents to assure compliance with the regulatory dose limitations in 10 CFR Part 50, Appendix I. Also included are methods for performing dose projections to assure compliance with the liquid and gaseous treatment system operability sections of the *Radiological Effluent Monitoring Manual (REMM - Section I of the REMODCM)*. The manual also includes the methods used for determining quarterly and annual doses for inclusion in the *Radioactive Effluent Release Report*.

The bases for selected site-specific factors used in the dose calculation methodology are provided in Reference Manual *MP-13-REM-REF02, REMODCM Technical Information*.

Another section of this manual discusses the methods to be used in determining effluent monitor alarm/trip setpoints to be used to ensure compliance with the instantaneous release rate limits in *Sections III.D.2.a, IV.E.2.a, and V.E.2.a*.

This manual includes the methods to be used in performance of the surveillance requirements in the Radiological Effluent Controls of Sections III, IV, and V. Appendix A, Tables App.A-1 and App.A-2 provide a cross-reference of effluent requirements and applicable methodologies contained in the REMODCM.

Most of the calculations in this manual have several methods given for the calculation of the same parameter. These methods are arranged in order of simplicity and conservatism, Method 1 being the easiest and most conservative. As long as releases remain low, one should be able to use Method 1 as a simple estimate of the dose. If release calculations approach the limit, however, more detailed yet less conservative calculations may be used. At any time a more detailed calculation may be used in lieu of a simple calculation.

This manual is written common to all three units since some release pathways are shared and there are also site release limits involved. These facts make it impossible to completely separate the three units.

II.B. RESPONSIBILITIES

All changes to the Off-Site Dose Calculation Manual (ODCM) shall be reviewed and approved by the Site Operations Review Committee prior to implementation.

All changes and their rationale shall be documented in the *Radioactive Effluent Release Report*.

It shall be the responsibility of the Vice President and Senior Nuclear Executive - Millstone to ensure that this manual is used as required by the administrative controls of the *Technical Specifications*. The delegation of implementation responsibilities is delineated in the Millstone Radiological Effluent Program Reference Manual (MP-13-REM-REF01).

II.C. LIQUID DOSE CALCULATIONS

The determination of potential doses from liquid effluents to the maximum exposed member of the public is divided into two methods. Method 1 is a simplified calculation approach that is used as an operational tool to ensure that effluent releases as they occur are not likely to cause quarterly and annual offsite dose limits to be exceeded. Effluent doses are calculated at least once every 31 days. Method 2 is a more detailed computational calculation using accepted computer models to demonstrate actual regulatory dose compliance. Method 2 is used whenever the Method 1 estimation begins to approach a regulatory limit, and for preparation of the *Radioactive Effluent Release Report* which includes the quarterly and annual dose impacts for all effluents recorded discharged to the environment during the year of record.

1. Whole Body Dose from Liquid Effluents

Radiological Effluent Controls (Sections III, IV, and V) limit the whole body dose to an individual member of the public to 1.5 mrem per calendar quarter and 3 mrem per year from liquid effluents released from each unit. (See Appendix A, Tables App.A-1 and App.A-2 for cross-reference effluent control requirements and applicable sections in the REMODCM which are used to determine compliance). In addition, installed portions of liquid radwaste treatment system are required to be operated to reduce radioactive materials in liquid effluents when the projected whole body dose over 31 days from applicable waste streams exceeds 0.006 mrem. This part of the REMODCM provides the calculation methodology for determining the whole body dose from radioactive materials released into liquid pathways of exposure associated with routine discharges. This includes the liquid pathways which contribute to the 25 mrem annual total dose limit (40 CFR190) to any real individual member of the public from all effluent sources (liquids, gases, and direct).

a. Method 1 (Applicable to Units 1, 2, and 3)

For Unit 1: No dose; Unit 1 is not currently releasing radioactivity in liquid effluents. |

For Units 2 and 3: |

$$D_w = 0.2 C_F + 5.6 \times 10^{-7} C_H$$

Where:

D_w = The estimated whole body dose to a potentially maximum exposed individual (in mrem) due to fission and activation products released in liquid effluents during a specified time period.

C_F = total gross curies of fission and activation products, excluding tritium and dissolved noble gases, released during the period of interest.

C_H = total curies of tritium released during the period of interest.

If D_w , within a calendar quarter is greater than 0.5 mrem, go to Method 2.

II.C. LIQUID DOSE CALCULATIONS (Cont'd)

b. Method 2 (Applicable to Units 1, 2, and 3)

If the calculated dose using Method 1 is greater than 0.5 mrem within a calendar quarter, or if a more accurate determination is desired, use the NRC computer code LADTAP II, or a code which uses the methodology given in Regulatory Guide 1.109, to calculate the liquid whole body doses. Method 2 (LADTAP II) is also used in the performance of dose calculations for the *Radioactive Effluent Release Report*. The use of this code is given in Engineering Procedure RAB B-11, *Liquid Dose Calculations - LADTAPII*. Additional information on LADTAPII is contained in the REMODCM Technical Information Manual (MP-13-REM-REF02).

2. Maximum Organ Dose from Liquid Effluents

Radiological Effluent Controls (Sections III, IV, and V) limit the maximum organ dose to an individual member of the public to 5 mrem per calendar quarter and 10 mrem per year from liquid effluents released from each unit. (See Appendix A, Tables App.A-1 and App.A-2 for cross-reference effluent control requirements and applicable sections in the REMODCM which are used to determine compliance). In addition, installed portions of liquid radwaste treatment system are required to be operated to reduce radioactive materials in liquid effluents when the projected maximum organ dose over 31 days from applicable waste streams exceeds 0.02 mrem. This part of the REMODCM provides the calculation methodology for determining the maximum organ dose from radioactive materials released into liquid pathways of exposure associated with routine discharges. This includes the liquid pathways which contribute to the 25 mrem annual organ (except 75 mrem thyroid) dose limit (40 CFR190) to any real individual member of the public from all effluent sources (liquids, gases, and direct).

a. Method 1 (Applicable to Units 1, 2, and 3)

For Unit 1: No dose; Unit 1 is not currently releasing radioactivity in liquid effluents.

For Units 2 and 3:

$$D_o = 1.5 C_F$$

Where:

D_o = The estimated maximum organ dose to the potentially maximum exposed individual (in mrem) due to fission and activation products released in liquid effluents during a specified time period.

C_F = total gross curies of fission and activation products, excluding tritium and dissolved noble gases, released during the period of interest - same as *Section II.C.1.a*.

If D_o , within a calendar quarter is greater than 2 mrem, go to *Method 2*.

b. Method 2 (Applicable to Units 1, 2, and 3)

If the calculated dose using Method 1 is greater than 2 mrem, or if a more accurate determination is desired, use the NRC computer code LADTAP II, or a code which uses the methodology given in Regulatory Guide 1.109, to calculate the liquid maximum organ doses. Method 2 (LADTAP II) is also used in the performance of dose calculations for the *Radioactive Effluent Release Report*. The use of this code and the input parameters are given in Engineering Procedure RAB B-11, *Liquid Dose Calculations - LADTAP II*. Additional information on LADTAPII is contained in the REMODCM Technical Information Manual (MP-13-REM-REF02).

H.C. LIQUID DOSE CALCULATIONS (Cont'd)**3. Estimation of Annual Whole Body Dose (Applicable to All Units)**

An estimation of annual (year-to-date) whole body dose (D_{YW}) from liquid effluents shall be made every month to determine compliance with the annual dose limits for each Unit which releases any radioactivity in liquid effluents. Annual doses will be determined as follows:

$$D_{YW} = \Sigma D_w$$

where the sum of the doses include the whole body dose contribution from all effluent releases for each Unit recorded to-date. For estimation of the Total Dose requirements of 40CFR190, the effluent releases from all three Units combined are used.

The following shall be used as D_w :

- (1) If the detailed quarterly dose calculations required per *Section II.C.6* for the *Radioactive Effluent Release Report* are completed for any calendar quarter, use that result.
- (2) If the detailed calculations are not complete for a particular quarter, use the results as determined in *Section II.C.1*.
- (3) If the annual dose estimate, D_{YW} , is greater than 3 mrem and any D_w determined as in *Section II.C.1* was not calculated using *Method 2* (i.e., LADTAP II computer code or a Regulatory Guide 1.109 code), recalculate D_w using *Method 2* if this could reduce D_{YW} to less than 3 mrem.

4. Estimation of Annual Maximum Organ Dose (Applicable to All Units)

An estimation of annual (year-to-date) maximum organ dose (D_{YO}) from liquid effluents shall be made every month to determine compliance with the annual dose limits for each Unit which releases any radioactivity in liquid effluents. Annual doses will be determined as follows:

$$D_{YO} = \Sigma D_o$$

where the sum of the doses include the maximum organ dose contribution from all effluent releases for each Unit recorded to-date. For estimation of the Total Dose requirements of 40CFR190, the effluent releases from all three Units combined are used.

The following guidelines shall be used:

- (1) If the detailed quarterly dose calculations required per *Section II.C.6* for the *Radioactive Effluent Release Report* are completed for any calendar quarter, use that result.
- (2) If the detailed calculations are not complete for a particular quarter, use the results as determined in *Section II.C.2*.
- (3) If different organs are the maximum for different quarters, they may be summed together and D_{YO} can be recorded as a less than value as long as the value is less than 10 mrem.
- (4) If D_{YO} is greater than 10 mrem and any value used in its determination was calculated as in *Section II.C.2*, but not with *Method 2* (i.e., LADTAP II computer code or a Regulatory Guide 1.109 code), recalculate that value using *Method 2* if this could reduce D_{YO} to less than 10 mrem.

II.C. LIQUID DOSE CALCULATIONS (Cont'd)**5. Monthly Dose Projections**

Section I.C.2.a of the REMM requires that certain portions of the liquid radwaste treatment equipment be used to reduce radioactive liquid effluents when the projected doses for each Unit (made at least once per 31 days) exceeds 0.006 mrem whole body or 0.02 mrem to any organ. The following methods are applied in the estimation of monthly dose projections:

a. Whole Body and Maximum Organ (Applicable to Unit 1 Only)

Dose projection not required; Unit 1 is not currently releasing radioactivity in liquid effluents. |

II.C. LIQUID DOSE CALCULATIONS (Cont'd)

b. Whole Body and Maximum Organ (Applicable to Units 2 and 3)

The projected monthly whole body dose (Units 2 or 3) is determined from:

$$D_{MW}^E = D'_{MW} [(1 - F_1) R_1 R_4 F_2 + F_1 R_2 R_3]$$

The monthly projected maximum organ dose (Units 2 or 3) is determined from:

$$D_{MO}^E = D'_{MO} [(1 - F_1) R_1 R_4 F_2 + F_1 R_2 R_3]$$

Where:

D'_{MW} = the whole body dose from the last typical* previously completed month as calculated per the methods in *Section II.C.1.*

D'_{MO} = the maximum organ dose from the last typical* previously completed month as calculated per the methods in *Section II.C.2.*

*Note: See notes in Section II.C.5.a.

R_1 = the ratio of the total estimated volume of liquid batches to be released in the present month to the volume released in the past month.

R_2 = the ratio of estimated volume of steam generator blowdown to be released in present month to the volume released in the past month.

F_1 = the fraction of curies released last month coming from steam generator blowdown calculated as:

$$\frac{\text{curies from blowdown}}{\text{curies from blowdown} + \text{curies from batch tanks}}$$

R_3 = the ratio of estimated secondary coolant activity for the present month to that for the past month.

R_4 = the ratio of estimated primary coolant activity for the present month to that for the past month.

F_2 = the factor to be applied to the estimated ratio of final curies released if there are expected differences in treatment of liquid waste for the present month as opposed to the past month (e.g., bypass of filters or demineralizers). NUREG-0017 or past experience shall be used to determine the effect of each form of treatment which will vary. $F_2 = 1$ if there are no expected differences.

6. Quarterly Dose Calculations for Radioactive Effluent Release Report

Detailed quarterly dose calculations required for the *Radioactive Effluent Release Report* shall be done using the NRC computer code LADTAP II, or a code which uses the methodology given in Regulatory Guide 1.109. The use of this code, and the input parameters are given in *Engineering Procedure, RAB B-11, Liquid Dose Calculations - LADTAP II*. Additional information on LADTAPII is contained in the REMODCM Technical Information Manual (MP-13-REM-REF02).

II.C. LIQUID DOSE CALCULATIONS (Cont'd)**7. Bases for Liquid Pathway Dose Calculations**

The dose calculation methodology and parameters used in Section II of the REMODCM implement the requirements in Section III.A of Appendix I (10CFR50) which states that conformance with the dose objectives of Appendix I be shown by calculational procedures based on models and data, such that the actual exposure of a member of the public through appropriate pathways is unlikely to be substantially underestimated. The dose estimations calculated by both Method 1 and Method 2 are based on the liquid models presented in Regulatory Guide 1.109, Rev.1; "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10CFR Part 50, Appendix I". These equations are implemented via the use of the NRC sponsored computer code LADTAP II. Input parameter values typically used in the dose models are listed in *Reference Manual, "REMODCM Technical Information Document (MP-13-REM-REF02)*. This same methodology is used in the determination of compliance with the 40CFR190 total dose standard for the liquid pathways.

The conversion constants in the Method 1 equations are based on the maximum observed comparison of historical effluent releases for each unit and corresponding whole body or critical organ doses to a maximum individual. The dose conversion factors are calculated based on the ratio of the observed highest dose (whole body and organ) and the curies of fission and activation products released during the period. This ratio results in the Method 1 equation conversion factor in mrem/Ci released. This same approach was repeated separately for tritium (as a different radionuclide class) discharged in liquids wastes. Reference Manual MP-13-REM-REF02 describes the derivation of the Method 1 constants and list the historical whole body and maximum organ doses calculated for each unit operation.

II.D. GASEOUS DOSE CALCULATIONS

The determination of potential release rates and doses from radioactive gaseous effluents to the maximum off-site receptor are divided into two methods. Method 1 provides simplified operational tools to ensure that effluent releases are not likely to cause quarterly and annual off-site dose or dose rate limits to be exceeded. Effluent doses are calculated at least once every 31 days. Method 2 provides for a more detailed computational calculation using accepted computer models to demonstrate actual regulatory compliance. Method 2 is used whenever the Method 1 estimation approaches a regulatory limit, and for preparation of the Radioactive Effluent Release Report which includes the quarterly and annual dose impacts for all effluents recorded discharged to the atmosphere during the year of record.

1. Site Release Rate Limits (“Instantaneous”)

Radiological Effluent Controls (Sections III, IV, and V) for each unit require that the instantaneous off-site dose rates from noble gases released to the atmosphere be limited such that they do not exceed 500 mrem/year at any time to the whole body or 3000 mrem/year to the skin at any time from the external cloud. For iodine-131, 133, tritium, and particulates (half-lives > 8 days), the inhalation pathway critical organ dose rate from all units shall not exceed 1500 mrem/year at any time. These limits apply to the combination of releases from all three Units on the site, and are directly related to the radioactivity release rates measured for each Unit. By limiting gaseous release rates for both classes of radionuclides (i.e., noble gases; and iodines, tritium, and particulates) to within values which correlate to the above dose rate limits, assurance is provided that the Radiological Effluent Controls dose rate limits are not exceeded.

a. Method 1 for Noble Gas Release Rate Limits

The instantaneous noble gas release rate limit from the site shall be:

$$Q_{1V}/90,000 + Q_{2S}/560,000 + Q_{2V}/290,000 + Q_{3S}/560,000 + Q_{3V}/290,000 \leq 1$$

Where:

- Q_{1V} = Noble gas release rate from Spent Fuel Pool Island Vent (μCi/sec)
- Q_{2S} = Noble gas release rate from MP2 to Millstone Stack (μCi/sec)
- Q_{2V} = Noble gas release rate from MP2 Vent (μCi/sec)
- Q_{3S} = Noble gas release rate from MP3 to Millstone Stack (μCi/sec)
- Q_{3V} = Noble gas release rate from MP3 Vent (μCi/sec)

As long as the above is less than or equal to 1, the doses will be less than or equal to 500 mrem to the total body and less than 3000 mrem to the skin. The limiting factor for the Unit 1 SFPI vent of 90,000 is based on the skin dose limit of 3,000 mrem/year, while all the other factors are based on the whole body dose limit of 500 mrem/year.

b. Method 1 Release Rate Limit - I-131, I-133, H-3 and Particulates Half Lives Greater Than 8 Days

With releases satisfying the following limit conditions, the dose rate to the maximum organ will be less than 1500 mrem/year from the inhalation pathway:

- (1) The site release rate limit of I-131, I-133, and tritium (where the thyroid is the critical organ for these radionuclides) shall be:

$$DR_{thy1} + DR_{thy2} + DR_{thy3} \leq 1$$

Where the contribution from each Unit is calculated from:

Unit 1: $DR_{thy1} = 9.36 \times 10^{-6} Q_{H1V}$

Unit 2: $DR_{thy2} = 5.1 \times 10^{-2} {}^{131}Q_{I2V} + 2.38 \times 10^{-3} {}^{131}Q_{I2S} + 1.25 \times 10^{-2} {}^{133}Q_{I2V} + 5.75 \times 10^{-4} {}^{133}Q_{I2S} + 4.2 \times 10^{-6} Q_{H2V} + 1.9 \times 10^{-7} Q_{H2S}$

Unit 3: $DR_{thy3} = 5.1 \times 10^{-2} {}^{131}Q_{I3V} + 2.38 \times 10^{-3} {}^{131}Q_{I3S} + 1.25 \times 10^{-2} {}^{133}Q_{I3V} + 5.75 \times 10^{-4} {}^{133}Q_{I3S} + 4.2 \times 10^{-6} Q_{H3V} + 1.9 \times 10^{-7} Q_{H3S}$

- (2) The site release rate limit of particulates with half-lives greater than 8 days and tritium (where the critical organ is a composite of target organs for a mix of radionuclides) shall be:

$$DR_{org1} + DR_{org2} + DR_{org3} \leq 1$$

Where the contribution from each Unit is calculated from:

Unit 1: $DR_{org1} = 1.05 \times 10^{-1} [Q_{P1V} + Q_{P1B}] + 9.36 \times 10^{-6} Q_{H1V}$

Unit 2: $DR_{org2} = 2.38 \times 10^{-3} Q_{P2S} + 5.1 \times 10^{-2} Q_{P2V} + 1.9 \times 10^{-7} Q_{H2S} + 4.2 \times 10^{-6} Q_{H2V}$

Unit 3: $DR_{org3} = 2.38 \times 10^{-3} Q_{P3S} + 5.1 \times 10^{-2} Q_{P3V} + 1.9 \times 10^{-7} Q_{H3S} + 4.2 \times 10^{-6} Q_{H3V}$

Each of the release rate quantities in the above equations are defined as:

${}^{131}Q_{I2V}$ = Release rate of I-131 from MP2 Vent ($\mu\text{Ci}/\text{sec}$)*

${}^{131}Q_{I2S}$ = Release rate of I-131 from MP2 to Millstone Stack ($\mu\text{Ci}/\text{sec}$)

${}^{133}Q_{I2V}$ = Release rate of I-133 from MP2 Vent ($\mu\text{Ci}/\text{sec}$)*

${}^{133}Q_{I2S}$ = Release rate of I-133 from MP2 to Millstone Stack ($\mu\text{Ci}/\text{sec}$)

${}^{131}Q_{I3V}$ = Release rate of I-131 from MP3 Vents (Normal and ESF) ($\mu\text{Ci}/\text{sec}$)*

${}^{131}Q_{I3S}$ = Release rate of I-131 from MP3 to Millstone Stack ($\mu\text{Ci}/\text{sec}$)

${}^{133}Q_{I3V}$ = Release rate of I-133 from MP3 Vents (Normal and ESF) ($\mu\text{Ci}/\text{sec}$)*

${}^{133}Q_{I3S}$ = Release rate of I-133 from MP3 to Millstone Stack ($\mu\text{Ci}/\text{sec}$)

Q_{H1V} = Release rate of tritium from the Spent Fuel Pool Island and Balance of Plant Vents ($\mu\text{Ci}/\text{sec}$)

Q_{H2V} = Release rate of tritium from MP2 Vent ($\mu\text{Ci}/\text{sec}$)*

Q_{H2S} = Release rate of tritium from MP2 to Millstone Stack ($\mu\text{Ci}/\text{sec}$)

Q_{H3V} = Release rate of tritium from MP3 Vents (Normal and ESF) ($\mu\text{Ci}/\text{sec}$)*

Q_{H3S} = Release rate of tritium from MP3 to Millstone Stack ($\mu\text{Ci}/\text{sec}$)

Q_{P1V} = Release rate of total particulates with half-lives greater than 8 days from the Spent Fuel Pool Island Vent ($\mu\text{Ci}/\text{sec}$)

Q_{P1B} = Release rate of total particulates with half-lives greater than 8 days from the Balance of Plant Vent ($\mu\text{Ci}/\text{sec}$)

Q_{P2V} = Release rate of total particulates with half-lives greater than 8 days from the MP2 Vent ($\mu\text{Ci}/\text{sec}$)

Q_{P2S} = Release rate of total particulates with half-lives greater than 8 days from MP2 to Millstone Stack ($\mu\text{Ci}/\text{sec}$)

Q_{P3V} = Release rate of total particulates with half-lives greater than 8 days from the MP3 Vents (Normal and ESF) ($\mu\text{Ci}/\text{sec}$)

Q_{P3S} = Release rate of total particulates with half-lives greater than 8 days from MP3 to Millstone Stack ($\mu\text{Ci}/\text{sec}$)

* includes releases via the steam generator blowdown tank vent.

c. **Method 2**

The above Method 1 equations assume a conservative nuclide mix. If necessary, utilize the GASPAR, or a code which uses the methodology given in Regulatory Guide 1.109, code to estimate the dose rate from either noble gases or iodines, tritium, and particulates with half-lives greater than 8 days. The use of the code is described in Engineering Procedure *RAB-B12, Gaseous Dose Calculations - GASPAR*. Additional information on GASPAR is contained in the REMODCM Technical Information Manual (MP-13-REM-REF02).

2. **10 CFR50 Appendix I - Noble Gas Limits**

Radiological Effluent Controls (Sections III, IV, and V) limit the off-site air dose from noble gases released in gaseous effluents to 5 mrad gamma and 10 mrad beta for a calendar quarter (10 and 20 mrad gamma and beta, respectively, per calendar year). Effluent dose calculations are calculated at least once every 31 days. In addition, installed portions of the gaseous radwaste treatment system are required to be operated to reduce radioactive materials in gaseous effluents when the projected doses over 31 days from the applicable waste stream exceed 0.02 mrad air gamma or 0.04 mrad air beta. (See Appendix A, Tables App.A-1 and App.A-2 for a cross reference of effluent control requirements and applicable sections of the REMODCM which are used to determine compliance.) This part of the REMODCM provides the calculation methodology for determining air doses from noble gases.

a. **Method 1 Air Dose* (Applicable to Units 1, 2, and 3)**

$$\begin{aligned} \text{For Unit 1:} \quad D_{G1} &= 3.3 \times 10^{-6} C_{N1V}^* \\ D_{B1} &= 1.49 \times 10^{-3} C_{N1V}^* \end{aligned}$$

$$\begin{aligned} \text{For Unit 2:} \quad D_{G2} &= 6.3 \times 10^{-4} C_{N2V} + 1.81 \times 10^{-4} C_{N2S}^* \\ D_{B2} &= 1.7 \times 10^{-3} C_{N2V} + 1.81 \times 10^{-6} C_{N2S}^* \end{aligned}$$

$$\begin{aligned} \text{For Unit 3:} \quad D_{G3} &= 6.3 \times 10^{-4} C_{N3V} + 1.81 \times 10^{-4} C_{N3S}^* \\ D_{B3} &= 1.7 \times 10^{-3} C_{N3V} + 1.81 \times 10^{-6} C_{N3S}^* \end{aligned}$$

If D_{G1} , D_{G2} , or D_{G3} are greater than 1.6 mrad or D_{B1} , D_{B2} , or D_{B3} are greater than 3.3 mrad within a calendar quarter, go to Method 2 below.

Where:

- D_{G1} = The gamma air dose from Unit 1 for the period of interest (mrad).
- D_{B1} = The beta air dose from Unit 1 for the period of interest (mrad).
- D_{G2} = The gamma air dose from Unit 2 for the period of interest (mrad).
- D_{B2} = The beta air dose from Unit 2 for the period of interest (mrad).
- D_{G3} = The gamma air dose from Unit 3 for the period of interest (mrad).
- D_{B3} = The beta air dose from Unit 3 for the period of interest (mrad).

C_{N1V} = The total curies of noble gas released from Spent Fuel Pool Island Vent during the period of interest.

C_{N2V} = The total curies of noble gas released from Unit 2 Vent during the period of interest. Include containment releases to Unit 2 Vent

C_{N2S} = The total curies of noble gas released from Unit 2 to Millstone Stack during the period of interest.

C_{N3V} = The total curies of noble gas released from Unit 3 vents during the period of interest. Include containment releases to Unit 3 Vent and ESF Building Vent.

C_{N3S} = The total curies of noble gas released from Unit 3 to Millstone Stack during the period of interest.

* See the *REMODCM Technical Information Document (MP-13-REM-REF02)*, Section 4.2, for the derivation of air dose Method 1 factors.

b. Method 2 Air Dose (Applicable to Units 1, 2, and 3)

Use the GASPAR computer code, or a code which uses the methodology given in Regulatory Guide 1.109, to determine the critical site boundary air doses.

For the Special Location, enter the following worst case quarterly average meteorology based on the Unit 2 vent eight-year history for 1980 to 1987:

$$\begin{aligned} X/Q &= 8.1 \times 10^{-6} \text{ sec/m}^3 \\ D/Q &= 1.5 \times 10^{-7} \text{ m}^{-2} \end{aligned}$$

(See the *REMOCM Technical Information Document MP-12-REM-REF02*, Attachment 5)

If the calculated air dose exceeds one half the quarterly Radiological Effluent Control limit, use meteorology concurrent with time of release.

c. Estimation of Annual Air Dose Limit Due to Noble Gases (Applicable to Units 1, 2, and 3)

An estimation of annual (year-to-date) beta and gamma air doses (D_{YB} and D_{YG} , respectively) from noble gases released from Units 1, 2 and 3 shall be made every month to determine compliance with the annual dose limits for each Unit. Annual air doses will be determined as follows:

<u>Unit 1</u>	<u>Unit 2</u>	<u>Unit 3</u>
$D_{YG1} = \Sigma D_{G1}$	$D_{YG2} = \Sigma D_{G2}$	$D_{YG3} = \Sigma D_{G3}$
$D_{YB1} = \Sigma D_{B1}$	$D_{YB2} = \Sigma D_{B2}$	$D_{YB3} = \Sigma D_{B3}$

where the sums are over the first quarter (i.e., summation of the all release periods within the quarter) through the present calendar quarter doses.

Where: D_{YG1} , D_{YG2} , D_{YG3} , D_{YB1} , D_{YB2} and D_{YB3} = gamma air dose and beta air dose for the calendar year for Unit 1, 2, or 3.

The following shall be used as the quarterly doses:

- (1) If the detailed quarterly dose calculations required per *Section II.D.5* for the *Radioactive Effluent Release Report* are complete for any calendar quarter, use those results.
- (2) If the detailed calculations are not complete for a particular quarter, use the results as determined above in *Sections II.D.2.a* or *II.D.2.b*.

If D_{YG1} , D_{YG2} or D_{YG3} are greater than 10 mrad or D_{YB1} , D_{YB2} or D_{YB3} are greater than 20 mrad and any corresponding quarterly dose was not calculated using Method 2 (*Section II. D.2.b*), recalculate the quarterly dose using meteorology concurrent with time of release.

3. **10 CFR50 Appendix I - Iodine and Particulate Doses**

Radiological Effluent Controls (Section III, IV, and V) limit the off-site dose to a critical organ from radioiodines, tritium, and particulates with half-lives greater than 8 days released in gaseous effluents to 7.5 mrem for a calendar quarter (15 mrem per calendar year). Effluent dose calculations are performed at least once every 31 days. In addition, installed portions of the gaseous radwaste treatment system are required to be operated to reduce radioactive materials in gaseous effluents when the projected doses over 31 days from the applicable waste stream exceed 0.03 mrem. (See Appendix A, Tables App.A-1 and App.A-2 for a cross reference of effluent control requirements and applicable sections of the REMODCM which are used to determine compliance.) This part of the REMODCM provides the calculation methodology for determining critical organ doses from atmospheric releases of iodines, tritium and particulates.

a. **Critical Organ Doses (Applicable to Millstone Stack and Unit 1 releases)**

(1) **Method 1 - Millstone Stack and Unit 1 Releases**

Calculate organ doses for D_{TS} and D_{OS} :

$$\text{For Unit 2 or 3: } D_{TS} = 947 {}_{131}C_{IS} + 8.77 {}_{133}C_{IS} + 1.58 \times 10^{-4} C_{HS}$$

$$D_{OS} = 328 C_{PS} + 1.58 \times 10^{-4} C_{HS}$$

Sum critical organ doses from stack with critical organ doses from vent in Section b(1) below:

$$\text{For Unit 1: } D_{TS} = 1.97 \times 10^{-3} C_{HV}$$

$$D_{OS} = 94.8[C_{PV} + C_{PB}] + 1.97 \times 10^{-3} C_{HV}$$

If either dose is greater than 2.5 mrem within a calendar quarter go to Method 2a below

Where: D_{TS} = The thyroid dose for the period of release of gaseous effluents.

D_{OS} = The dose to the maximum organ other than the thyroid for the period of gaseous effluent release.

${}_{131}C_{IS}$ = The total curies of I-131 released in gaseous effluents from Unit 2 or 3 to Millstone Stack during the period of interest.

${}_{133}C_{IS}$ = The total curies of I-133 released in gaseous effluents from Unit 2 or 3 to Millstone Stack during the period of interest.

C_{PS} = The total curies of particulates with half-lives greater than 8 days released in gaseous effluents from Millstone Stack during the period of interest.

C_{PV} = The total curies of particulates with half-lives greater than 8 days released in gaseous effluents from the SFPI vent during the period of interest.

C_{PB} = The total curies of particulates with half-lives greater than 8 days released in gaseous effluents from the BOP vent during the period of interest.

C_{HS} = The total curies of tritium released in gaseous effluents from Millstone Stack during period of interest.

C_{HV} = The total curies of tritium released in gaseous effluents from the SFPI and BOP vents during period of interest.

II.D. GASEOUS DOSE CALCULATIONS (Cont'd)

(2) Method 2a - Millstone Stack and Unit 1 Releases

Use the GASPAR code, or a code which uses the methodology given in Regulatory Guide 1.109, to determine the maximum organ dose. For the Special Location, enter the following worst case quarterly average meteorology as taken from the *REMOTCM Technical Information Document (MP-12-REM-REF02), Attachment 5*:

$$X/Q = 6.1 \times 10^{-8} \text{ sec/ m}^3$$

$$D/Q = 5.9 \times 10^{-9} \text{ m}^{-2} \text{ (Milk and Vegetation) and/or}$$

$$D/Q = 1.4 \times 10^{-9} \text{ m}^{-2} \text{ (If 1983-1987 D/Q data is acceptable for existing milk locations. If not, see guidance in the REMOTCM Technical Information Document (MP-12-REM-REF02), Section 4.2.)}$$

Use the Inhalation, Milk and Vegetation pathways (if applicable) in totaling the dose.

If the maximum organ dose is greater than 3.8 mrem within a calendar quarter go to *Method 2b*.

For Unit 2 or 3:

Sum critical organ doses from stack with critical organ doses from vent in Section b(2) below.

(3) Method 2b - Millstone Stack and Unit 1 Releases

Use the GASPAR code, or a code which uses the methodology given in Regulatory Guide 1.109, with actual locations, real-time meteorology and the pathways which actually exist at the time at those locations. Sum critical organ doses from stack with critical organ doses from vent in Section c(5) below.

b. Critical Organ Doses (Applicable to Units 2 and 3 vent releases)

(1) Method 1 - Unit 2 and Unit 3 releases

For Unit 2 and Unit 3, separately, calculate organ doses D_T and D_O :

$$D_{TV} = 3.1 \times 10^3 {}_{131}C_{IV} + 29.53 {}_{133}C_{IV} + 2.6 \times 10^{-3} C_{HV}$$

$$D_{OV} = 1.1 \times 10^3 C_{PV} + 2.6 \times 10^{-3} C_{HV}$$

Sum with organ doses for releases from the stack from Section a(1):

$$D_T = D_{TS} + D_{TV}$$

$$D_O = D_{OS} + D_{OV}$$

If either dose is greater than 2.5 mrem within a calendar quarter go to Section a(2) and recalculate any organ dose greater than 2.5 mrem for releases from the stack and go to Section b(2) below and recalculate any organ dose greater than 2.5 mrem for releases from the vent, where:

D_T = The total thyroid dose for the period of gaseous effluents releases.

D_O = The total dose to the maximum organ other than the thyroid for the period of gaseous effluent releases.

D_{TV} = The thyroid dose for the period of gaseous effluents releases from the vent.

D_{OV} = The dose to the maximum organ other than the thyroid for the period of gaseous effluent releases from the vent.

${}_{131}C_{IV}$ = The total curies of I-131 in gaseous effluents from Unit 2 other than to the Millstone Stack (Unit 2 Vent, containment releases to vent, and Steam Generator Blowdown Tank Vent*) or from Unit 3 other than to the Millstone Stack (Unit 3 Vent, ESF Building Vent, containment releases to vent, Steam Generator Blowdown Tank Vent*, and Containment Drawdown using the hogger**) during the period of interest.

- $^{133}\text{C}_{\text{IV}}$ = The total curies of I-133 in gaseous effluents from Unit 2 other than to the Millstone Stack (Unit 2 Vent, containment releases to vent, and Steam Generator Blowdown Tank Vent*) or from Unit 3 other than to the Millstone Stack (Unit 3 Vent, ESF Building Vent, containment releases to vent, Steam Generator Blowdown Tank Vent*, and Containment Drawdown using the hogger **) during the period of interest.
- C_{PS} = The total curies of particulates with half-lives greater than eight days released in gaseous effluents from Unit 2 other than to the Millstone Stack (Unit 2 Vent and containment releases to vent) or from Unit 3 other than to the Millstone Stack (Unit 3 Vent, ESF Building Vent, containment releases to vent, and Containment Drawdown using the hogger **) during the period of interest.
- C_{HV} = The total curies of tritium released in gaseous effluents from Unit 2 other than to the Millstone Stack (Unit 2 Vent and containment releases to vent or from Unit 3 other than to the Millstone Stack (Unit 3 Vent, ESF Building Vent, containment releases to vent, and Containment Drawdown using the hogger **) during the period of interest.

- * Results from SAI studies in 1982 and 1983 and guidance provided in the R. A. Crandall / E. R. Brezinski memo to E. J. Mroczka, Millstone Unit 2 Steam Generator Blowdown Tank Releases, NE-83-RA-879, June 15, 1983, indicate that the steam generator blowdown tank vent releases can be estimated by use of a factor of 1/6,000 (a DF of 2000 and a partitioning factor of 1/3). Although Unit 3 normally recycles blowdown, periodically blowdown is released for short periods of time. These releases should be similar to Unit 2 and until studies can be performed at Unit 3 the same calculation should be performed. Based upon the above, the formula to be used is:

$$\text{S/G blowdown concentration} \times \text{S/G blowdown flow rate} \times 1/6000 \times \text{time} = \text{integrated activity}$$

- ** This pathway does not have a effluent monitor.

(2) Method 2a - Unit 2 and Unit 3 releases

Use the GASPAR code, or a code which uses the methodology given in Regulatory Guide 1.109, to determine the maximum organ dose. For the Special Location, enter the following worst case quarterly average meteorology as taken from the *REMDCM Technical Information Document (MP-12-REM-REF02), Attachment 5*:

$$\text{X/Q} = 8.1 \times 10^{-6} \text{ sec/ m}^3$$

$$\text{D/Q} = 1.5 \times 10^{-7} \text{ m}^{-2} \text{ (Milk and Vegetation) and/or}$$

$$\text{D/Q} = 6.1 \times 10^{-9} \text{ m}^{-2}$$

(If 1983-1987 D/Q data is acceptable for existing milk locations. If not, see guidance in the *REMDCM Technical Information Document (MP-12-REM-REF02), Section 4.2.*)

As shown in the *REMDCM Technical Information Document (MP-12-REM-REF02), Attachments 4 and 5*, the same meteorology can be used for both continuous and batch releases. Therefore, the program need only be run once using the total curies from all releases from Unit 2 or 3 releases.

Use the Inhalation, Milk and Vegetation pathways (if applicable) in totaling the dose.

Sum organ doses for releases from the stack from Section a(2). The maximum organ dose is the greater of D_{T} or D_{O} . If it is greater than 2.5 mrem within a calendar quarter, go to Section a(2) and recalculate any organ dose greater than 2.5 mrem for releases from the stack and go to Section b(3) below and recalculate any organ dose greater than 2.5 mrem for releases from the vent

II.D. GASEOUS DOSE CALCULATIONS (Cont'd)

(3) Method 2b - Unit 2 and Unit 3 releases

Use the GASPAR code, or a code which uses the methodology given in Regulatory Guide 1.109, with the actual locations, real-time meteorology and the pathways which actually exist at the time at these locations. For Unit 2, the code shall be run separately for steam generator blowdown tank vents and ventilation releases, containment purges and waste gas tank releases. For Unit 3, the code shall be run separately for ventilation, process gas, containment vacuum system, aerated ventilation and containment purges.

c. Estimation of Annual Critical Organ Doses Due to Iodines, Tritium and Particulates (Applicable to Units 1, 2, and 3)

An estimation of annual (year-to-date) critical organ doses (D_{YT} and D_{YO} for thyroid and maximum organ other than thyroid, respectively) from radioiodine, tritium and particulates with half-lives greater than 8 days released from Units 1, 2 and 3 shall be made every month to determine compliance with the annual dose limits for each Unit. Annual critical organ doses will be determined as follows:

<u>Unit 1</u>	<u>Unit 2</u>	<u>Unit 3</u>
$D_{YT1} = \sum D_{T1}$	$D_{YT2} = \sum D_{T2}$	$D_{YT3} = \sum D_{T3}$
$D_{YO1} = \sum D_{O1}$	$D_{YO2} = \sum D_{O2}$	$D_{YO3} = \sum D_{O3}$

where the sums are over the first quarter (i.e., summation of the all release periods within the quarter) through the present calendar quarter doses.

Where:

D_{YT1} , D_{YT2} , D_{YT3} , D_{YO1} , D_{YO2} and D_{YO3} = thyroid (T) dose and maximum organ (O) dose (other than the thyroid) for the calendar year for Unit 1, 2, or 3.

The following guidelines shall be used for D_T and D_O :

- (1) If the detailed quarterly dose calculations required per *Section II.D.5* for the *Radioactive Effluent Release Report* are complete for any calendar quarter, use those results.
- (2) If the detailed calculations are not complete for a particular quarter, use the results as determined above in *Section II.D.3.a* or *II.D.3.b*.
- (3) If D_{YT} and/or D_{YO} are greater than 15 mrem and quarterly dose was not calculated using *Method 1c* of *Section II.D.3.a* or *II.D.3.b*, recalculate the quarterly dose using *Method 1c*.
- (4) If different organs are the maximum organ for different quarters, they can be summed together and D_{YO} recorded as a less-than value as long as the value is less than 15 mrem. If it is not, the sum for each organ involved shall be determined.

II.D. GASEOUS DOSE CALCULATIONS (Cont'd)**4. Gaseous Effluent Monthly Dose Projections**

Section I.D.2.a of the REMM requires that certain portions of the gaseous radwaste treatment equipment be returned to service to reduce radioactive gaseous effluents when the projected doses for each Unit (made at least once per 31 days) exceed 0.02 mrad gamma air, 0.04 mrad beta air, or 0.03 mrem to any organ from gaseous effluents. The following methods are applied in the estimation of monthly dose projections.

a. Unit 1 Projection Method

None required.

II.D. GASEOUS DOSE CALCULATIONS (Cont'd)**b. Unit 2 Projection Method****(1) Due to Gaseous Radwaste Treatment System (Unit 2)**

Determine the beta and gamma monthly air dose projection from noble gases from the following:

$$D_{MG}^E \text{ (mrad)} = 1.81 \times 10^{-4} C_N^E$$

$$D_{MB}^E \text{ (mrad)} = 1.81 \times 10^{-6} C_N^E$$

Where:

- C_N^E = the number of curies of noble gas estimated to be released from the waste gas storage tanks during the next month.
- D_{MG}^E = the estimated monthly gamma air dose.
- D_{MB}^E = the estimated monthly beta air dose.

(The dose conversion factor is from the *REM ODCM Technical Information Document (MP-12-REM-REF02)*, Section 4.2, for the Millstone Stack releases since the Unit 2 waste gas tanks are discharged via the Millstone Stack. This factor is conservative because the isotopic mix assumed for the dose conversion factor consists of shorter-lived noble gases which have higher dose conversion factors than the typical mix from Unit 2 waste gas tank discharges.)

(2) Due to Steam Generator Blowdown Tank Vent (Unit 2)**i. Method 1**

Determine D_{MO}^E which is the estimated monthly dose to the maximum organ from the following:

$$D_{MO}^E = 1/3 R_1 \times D_T$$

For the last quarter of operation, determine D_T as determined per Section II.D.3.b.

Where:

- R_1 = the expected ratio of secondary coolant iodine level for the coming month as compared with the average level during the quarter used in determining D_T above.

ii. Method 2

If necessary, estimate the curies expected to be released for the next month and applicable method for dose calculation from Section II.D.3.b.

II.D. GASEOUS DOSE CALCULATIONS (Cont'd)**(3) Due to Ventilation Releases (Unit 2)****

If portions of the ventilation treatment system are expected to be out of service during the month, determine the monthly maximum organ dose projection (D_{MO}^E) from the following:

i. Method 1

Determine D_{MO}^E which is the estimated monthly dose to the maximum organ from the following:

$$D_{MO}^E = 1/3 R_1 (1.01 - R_2) (R_3 + 0.01) D_0$$

For the last quarter of operation, determine D_0 as determined per *Section II.D.3-b.*

R_1 = the expected reduction factor for the HEPA filter. Typically this should be 100 (*see NUREG-0016 or 0017 for additional guidance*).

R_2 = the fraction of the time which the equipment was inoperable during the last quarter.

R_3 = the fraction of the time which the equipment is expected to be inoperable during the next month.

ii. Method 2

If necessary, estimate the curies expected to be released for the next month and applicable method for dose calculation from *Section II.D.3.b.*

** Since dose projections are only required if the treatment specified in *Section I.D* of the Radiological Effluent Monitoring Manual are not operating, the monthly gamma and beta air dose projections are not required for ventilation releases.

c. Unit 3 Projection Method**(1) Due to Radioactive Gaseous Waste System (Unit 3)**

Determine the beta and gamma monthly air dose projection from noble gases from the following:

$$D_{MG}^E \text{ (mrad)} = 1.81 \times 10^{-4} C_N^E$$

$$D_{MB}^E \text{ (mrad)} = 1.81 \times 10^{-6} C_N^E$$

Where:

C_N^E = the number of curies of noble gas estimated to be released from the reactor plant gaseous vents (the activity from this pathway increases when the process waste gas system is out of service.) during the next month.

D_{MG}^E = the estimated monthly gamma air dose.

D_{MB}^E = the estimated monthly beta air dose.

(The dose conversion factor is from the *REM ODCM Technical Information Document (MP-12-REM-REF02)*, *Section 4.2*, for the Millstone Stack releases since the Unit 3 reactor plant gaseous vents are discharged via the Millstone Stack.)

II.D. GASEOUS DOSE CALCULATIONS (Cont'd)

(2) Due to Steam Generator Blowdown Tank Vent (Unit 3)

i. Method 1

Determine D_{MO}^E which is the estimated monthly dose to the maximum organ.

$$D_{MO}^E = 1/3 R_1 \times D_T$$

For the last quarter of operation, determine D_T as determined per *Section II.D.3.b*.

Where: R_1 = the expected ratio of secondary coolant iodine level for the coming month as compared with the average level during the quarter used in the determining D_T above.

ii. Method 2

If necessary, estimate the curies expected to be released for the next month and applicable method for dose calculation from *Section II.D.3.b*.

(3) Due to Ventilation Releases (Unit 3)**

If portions of the ventilation treatment system are expected to be out of service during the month, determine the monthly maximum organ dose projection (D_{MO}^E) from the following:

i. Method 1

Determine D_{MO}^E which is the estimated monthly dose to the maximum organ.

$$D_{MO}^E = 1/3 R_1 (1.01 - R_2) (R_3 + 0.01) D_O$$

For the last quarter of operation, determine D_O as determined per *Section II.D.3.b*.

Where: R_1 = the expected reduction factor for the HEPA filter. Typically this should be 100 (*see NUREG-0016 or 0017 for additional guidance*).

R_2 = the fraction of the time which the equipment was inoperable during the last quarter.

R_3 = the fraction of the time which the equipment is estimated to be inoperable during the next month.

ii. Method 2

If necessary, estimate the curies expected to be released for the next month and applicable method for dose calculation from *Section II.D.3.b*.

** Since dose projections are only required if the treatment specified in *Section I.D* of the Radiological Effluent Monitoring Manual are not operating, the monthly gamma and beta air dose projections are not required for ventilation releases.

II.D. GASEOUS DOSE CALCULATIONS (Cont'd)**5. Quarterly Dose Calculations for Radioactive Effluent Release Report**

Detailed quarterly gaseous dose calculations required for the *Radioactive Effluent Release Report* shall be done using the computer code GASPAR, or a code which use the methodology given in Regulatory Guide 1.109.

6. Compliance with 40CFR190

The following sources shall be considered in determining the total dose to a real individual from uranium fuel cycle sources:

- a. **Gaseous Releases** from Units 1, 2, and 3.
- b. **Liquid Releases** from Units 1, 2, and 3.
- c. **Direct and Scattered Radiation** from Radioactive Material on Site.
- d. Since all other uranium fuel cycle sources are greater than 5 miles away, they need not be considered.

The Radiological Effluent Controls in Sections III.E (Unit 1), IV.E (Unit 2), and V.E (Unit 3) contain specific requirements for ensuring compliance with 40CFR190 based on gaseous and liquid doses (sources a and b).

Doses to source c are controlled by design and operations to ensure the off-site dose from each radwaste storage facility is less than one mrem per year. Potential doses from each facility are evaluated in Radiological Environmental Reviews (RER's) where total off-site doses from all sources are considered to ensure compliance with 40CFR190.

II.D. GASEOUS DOSE CALCULATIONS (Cont'd)

7. Bases for Gaseous Pathway Dose Calculations

The dose calculation methodology and parameters used in Section II of the REMODCM implement the requirements in Section III.A of Appendix I (10CFR50) which states that conformance with the ALARA dose objectives of Appendix I be shown by calculational procedures based on models and data, such that the actual exposure of a member of the public through appropriate pathways is unlikely to be substantially underestimated. Operational flexibility is provided by controlling the instantaneous release rate of noble gas (as well as iodines and particulate activity) such the maximum off-site dose rates are less than the equivalent of 500 mrem/year to the whole body, 3000 mrem/year to the skin from noble gases, or 1500 mrem/year to a critical organ from the inhalation of iodines, tritium and particulates. The dose rate limits are based on the 10CFR20 (pre-1991) annual dose limits, but applied as an instantaneous limit to assure that the actual dose over a year will be well below these numbers.

The equivalent instantaneous release rate limits for Millstone Stack were determined using the EPA AIREM code. For Units 2 & 3, these doses were calculated using the NRC GASPAR code. The AIREM code calculates cloud gamma doses using dose tables from a model that considers the finite extent of the cloud in the vertical direction. Beta doses are calculated assuming semi-infinite cloud concentrations, which are based upon a standard sector averaged diffusion equation. The GASPAR code implements the models of NRC Regulatory Guide 1.109, Rev. 1, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10CFR Part 50, Appendix I." Input parameter values typically used in the dose models are listed in the Station Reference Manual, "*REMODCM Technical Information Document (MP-13-REM-REF02)*". This same methodology is used in the determination of compliance with the 40CFR190 total dose standard for the gaseous pathways.

In the determination of compliance with the dose and dose rate limits, maximum individual dose calculations are performed at the nearest land site boundary with maximum decayed X/Q, and at the nearest vegetable garden (assumed to be nearest residence) and cow and goat farms with maximum D/Qs. The conversion constants in the Method 1 equations for maximum air doses, organ and whole body doses, and dose rates are based on the maximum observed comparison of historical effluent releases and corresponding calculated maximum doses. The dose conversion factors are calculated based on the ratio of the observed highest dose and the curies of fission and activation products released during the period. This ratio results in the Method 1 equation conversion factor in mrem/Ci released. Reference Manual MP-13-REM-REF02 describes the derivation of the Method 1 constants and list the historical maximum doses calculated for the maximum organ.

II.E. LIQUID MONITOR SETPOINTS

- 1. RESERVED**

|

II.E. LIQUID MONITOR SETPOINTS (Cont'd)

2. **RESERVED**

3. **Unit 2 Clean Liquid Radwaste Effluent Line - RM9049 and Aerated Liquid Radwaste Effluent Line - RM9116**

The setpoint on the Unit 2 clean and aerated liquid waste effluent lines depend on dilution water flow, radwaste discharge flow, the isotopic composition of the liquid, the background count rate of the monitor and the efficiency of the monitor. Due to the variability of these parameters, an alarm/trip setpoint will be determined prior to the release of each batch. The following method will be used:

From the tank isotopic analysis and the MPC values for each identified nuclide (including noble gases*) determine the required reduction factor, i.e.:

For Nuclides Other Than Noble Gases:

$$R_1 = \text{Required Reduction Factor} = \frac{1}{\Sigma \{ \mu\text{Ci/ml of nuclide } i / \text{MPC of nuclide } i \}}$$

For Noble Gases*:

$$R_2 = \text{Required Reduction Factor} = \frac{1}{\Sigma \{ \mu\text{Ci/ml of noble gases} / 2 \times 10^{-4} \mu\text{Ci/ml} \}}$$

$$= 2 \times 10^{-4} / \Sigma (\mu\text{Ci/ml}) \text{ noble gases}$$

* In lieu of determining the required reduction factor for noble gases, conservatism is allowed. For example, calculate the maximum concentration of noble gases that can be discharged from any tank.

Assuming:

Maximum discharge rate = 350 gpm

Normal Minimum dilution flow = 200,000 gpm (2 circulating pumps, less than rated due to biotic fouling)

$$\text{Maximum Noble Gas Concentration} \times \frac{350 \text{ gpm}}{200,000 \text{ gpm}} = 2 \times 10^{-4} \mu\text{Ci} / \text{ml}$$

Therefore,

II.E. LIQUID MONITOR SETPOINTS (Cont'd)

Determine the allowable discharge flow (F) in gpm:

$$F = 0.1 \times R \times D$$

Where:

D = The existing dilution flow (D): (Note: D = # circulating water pumps x 100,000 gpm + # service water pumps x 4,000 gpm)

Note that discharging at this flow rate would yield a discharge concentration corresponding to 10% of the Radiological Effluent Control Limit due to the safety factor of 0.1.

With this condition on discharge flow rate met, the monitor setpoint can be calculated:

$$R_{\text{set}} = 2 \times AC \times Ca \text{ (See Note 1 below.)}$$

Where:

R_{set} = The setpoint of the monitor (cps).
 AC = The total radwaste effluent concentration ($\mu\text{Ci/ml}$) in the tank.
 Ca = The current calibration factor for the effluent line monitor.
 2 = The multiple of expected count rate on the monitor based on the radioactivity concentration in the tank.

This value or that corresponding to $1.7 \times 10^{-4} \mu\text{Ci/ml}$ (Note 2 below), whichever is greater, plus background is the trip setpoint. For the latter setpoint, independent valve verification shall be performed and minimum dilution flow in Note 2 shall be verified and if necessary, appropriately adjusted.

Note 1: If discharging at the allowable discharge rate (F) as determined in above, this setpoint would correspond to 20% of the Radiological Effluent Control limit.

Note 2: This value is based upon worst case conditions, assuming maximum discharge flow (350 gpm), normal minimum dilution water flow (200,000 gpm for MP2) and an assumed worst case mix of nuclides (3×10^{-7} - I-131 MPC). This will assure that low level releases are not terminated due to small fluctuations in activity. However, to verify that the correct tank is being discharged when using this value, independent valve verification shall be performed. This value may be adjusted (increased or decreased) by factors to account for the actual discharge flow and actual dilution flow; however, controls shall be established to ensure that the allowable discharge flow is not exceeded and the dilution flow is maintained.

II.E. LIQUID MONITOR SETPOINTS (Cont'd)

4. Condensate Polishing Facility Waste Neutralization Sump Effluent Line - CND245

When the grab sample prior to release required by Table I.C-2 is greater than 5×10^{-7} uCi/ml, the setpoint shall be determined as for the Clean and Aerated Liquid Monitors in Section II.E.3 except the CPF monitor has the capability to readout in CPM or μ Ci/ml. If the grab sample is less than 5×10^{-7} uCi/ml, use a setpoint of the lower of two times background or the value as specified in II.E.3.

5a. Unit 2 Steam Generator Blowdown - RM4262

Assumptions used in determining the Alarm setpoint for this monitor are:

- a. Total S.G. blowdown flow rate = 700 gpm.
- b. Normal minimum possible circulating water dilution flow during periods of blowdown = 200,000 gpm (2 circulating water pumps) = 200,000 gpm.
- c. The release rate limit is conservatively set at 10% of the *10CFR Part 20* limit for I-131 ($0.1 \times 3 \times 10^{-7} \mu$ Ci/ml = $3 \times 10^{-8} \mu$ Ci/ml)*
- d. Background can be added after above calculations are performed.

Therefore, the alarm setpoint corresponds to a concentration of:

$$\text{Alarm } (\mu\text{Ci/ml}) = \frac{200,000}{700} \times 3 \times 10^{-8} + \text{background}^{**} = 8.5 \times 10^{-6} \mu\text{Ci/ml} + \text{background}$$

The latest monitor calibration curve shall be used to determine the alarm setpoint in cpm corresponding to $8.5 \times 10^{-6} \mu$ Ci/ml.

This setpoint may be adjusted (increased or decreased) through proper administrative controls if the steam generator blowdown rate is maintained other than 700 gpm and/or other than 2 circulating water pumps are available. The adjustment would correspond to the ratio of flows to those assumed above or:

$$\text{Alarm } (\mu\text{Ci/ml}) = 8.5 \times 10^{-6} \mu\text{Ci/ml} \times \frac{\text{circulating \& service water flow (gpm)}}{200,000} \times \frac{700}{\text{S/G blowdown (gpm)}} +$$

$$\text{Background} = 3 \times 10^{-8} \mu\text{Ci/ml} \times \frac{\text{circulating \& service water flow (gpm)}}{\text{total S/G blowdown (gpm)}} + \text{Background}$$

Note: The Steam Generator Blowdown alarm criteria is in practice based on setpoints required to detect allowable levels of primary to secondary leakage. This alarm criteria is typically more restrictive than that required to meet discharge limits. This fact shall be verified, however, whenever the alarm setpoint is recalculated.

* In lieu of using the I-131 MPC value, the identified MPC values for unrestricted area may be used.

** Background of monitor at monitor location (i.e., indication provided by system monitor with no activity present in the monitored system).

II.E. LIQUID MONITOR SETPOINTS (Cont'd)**5b. Unit 2 Steam Generator Blowdown Effluent Concentration Limitation**

The results of analysis of blowdown samples required by Table I.C-2 of Section I of the REMODCM shall be used to ensure that blowdown effluent releases do not exceed the concentration limits in 10CFR20, Appendix B (version prior to January 1, 1994).

6. Unit 2 Condenser Air Ejector - RM5099

N/A since this monitor is no longer a final liquid effluent monitor.

7a. Unit 2 Reactor Building Closed Cooling Water RM6038

The purpose of the Reactor Building Closed Cooling Water (RBCCW) radiation monitor is to give warning of abnormal radioactivity in the RBCCW system and to prevent releases to the Service Water system which, upon release to the environment, would exceed allowable limits in 10CFR20. According to Calculation RERM-02665-R2, radioactivity in RBCCW water which causes a monitor response of greater than the setpoint prescribed below could exceed 10CFR20 limits upon release to the Service Water system.

SETPOINT DURING POWER OPERATIONS:

To give adequate warning of abnormal radioactivity, the setpoint shall be two times the radiation monitor background reading, provided that the background reading does not exceed 2,000 cpm. The monitor background reading shall be the normal monitor reading. If the monitor background reading exceeds 2,000 cpm, the setpoint shall be set at the background reading plus 2,000 cpm and provisions shall be made to adjust the setpoint if the background decreases.

SETPOINT DURING SHUTDOWN:

1. During outages not exceeding three months the setpoint shall be two times the radiation monitor background reading, provided that the background reading does not exceed 415 cpm. If the monitor background reading exceeds 415 cpm, the setpoint shall be set at the background reading plus 415 cpm and provisions shall be made to adjust the setpoint if the background decreases.
2. During extended outages exceeding three months, but not exceeding three years, the setpoint shall be two times the radiation monitor background reading, provided that the background reading does not exceed 80 cpm. If the monitor background reading exceeds 80 cpm, the setpoint shall be set at the background reading plus 80 cpm and provisions shall be made to adjust the setpoint if the background decreases.

PROVISIONS FOR ALTERNATE DILUTION FLOWS:

These setpoints are based on a dilution flow of 4,000 gpm from one service water train. If additional dilution flow is credited, the setpoint may be adjusted proportionately. For example, the addition of a circulating water pump dilution flow of 100,000 gpm would allow the setpoint to be increased by a factor of 25.

7b. Unit 2 Service Water and Turbine Building Sump Effluent Concentration Limitation

Results of analyses of service water and turbine building sump samples taken in accordance with Table I.C-2 of Section I of the REMODCM shall be used to limit radioactivity concentrations in the service water and turbine building sump effluents to less than the limits in 10CFR20, Appendix B (version prior to January 1, 1994).

II.E. LIQUID MONITOR SETPOINTS (Cont'd)

8. Unit 3 Liquid Waste Monitor - LWS-RE70

The setpoints on the Unit 3 liquid waste monitor depend on dilution water flow, radwaste discharge flow, the isotopic composition of the liquid, the background count rate of the monitor and the efficiency of the monitor. Due to the variability of these parameters, the alert and alarm setpoints will be determined prior to the release of each batch. The following method will be used:

From the tank isotopic analysis and the MPC values for each identified nuclide (including noble gases*) determine the required reduction factor, i.e.:

For Nuclides Other Than Noble Gases*:

$$R_1 = \text{Required Reduction Factor} = 1 / \sum \frac{\mu\text{Ci/ml of nuclide } i}{\text{MPC of nuclide } i}$$

For Noble Gases:*

$$R_2 = \text{Required Reduction Factor} = 1 / \sum \frac{\mu\text{Ci/ml of noble gases}}{2 \times 10^{-4} \mu\text{Ci/ml}}$$

$$= 2 \times 10^{-4} / \sum \mu\text{Ci/ml of noble gases}$$

$$R = \text{the smaller of } R_1 \text{ or } R_2$$

* In lieu of determining the required reduction factor for noble gases, conservatism is allowed. For example, calculate the maximum concentration of noble gases that can be discharged from any tank.

Assuming:

Maximum discharge rate = 150 gpm

Normal Minimum dilution flow = 300,000 gpm (2 circulating pumps)

$$\text{Maximum "Allowable" Concentration} \times \frac{150 \text{ gpm}}{300,000 \text{ gpm}} = 2 \times 10^{-4} \mu\text{Ci/ml}$$

Therefore,

$$\text{Maximum "allowable" concentration} = 0.4 \mu\text{Ci/ml}$$

Determine the allowable discharge flow (F)

$$F = 0.1 \times R \times D$$

Where:

D = The existing dilution flow (D): (Note: D = # circulating water pumps x 150,000 gpm + # service water pumps x 15,000 gpm)

Note that discharging at this flow rate would yield a discharge concentration corresponding to 10% of the Radiological Effluent Control Limit due to the safety factor of 0.1.

II.E. LIQUID MONITOR SETPOINTS (Cont'd)

With this condition on discharge flow rate met, the monitor setpoint can be calculated:

$$R_{\text{set}} = 2 \times AC \times Ca \text{ (see Note 1)}$$

Where:

- R_{set} = The setpoint of the monitor (cps).
- AC = The total radwaste effluent concentration ($\mu\text{Ci/ml}$) in the tank.
- Ca = The current calibration factor for the effluent line monitor.
- 2 = The multiple of expected count rate on the monitor based on the radioactivity concentration in the tank.

This value, or that corresponding to $2 \times 10^{-4} \mu\text{Ci/ml}$ (Note 2 below), whichever is greater, plus background is the trip setpoint. For the latter setpoint, independent valve verification shall be performed and minimum dilution flow in Note 2 shall be verified and if necessary, appropriately adjusted.

Note 1: If discharging at the allowable discharge rate (F) as determined above, this Alarm setpoint would yield a discharge concentration corresponding to 20% of the Radiological Effluent Control limit.

Note 2: This value is based upon worst case conditions, assuming maximum discharge flow (150 gpm), minimum dilution water flow (2 circulating pumps = 300,000 gpm), and an assumed mix of nuclides as specified for an unidentified liquid release in *10CFR20* ($1 \times 10^{-7} \mu\text{Ci/ml}$). This will assure that low level releases are not terminated due to small fluctuations in activity. However, to verify that the correct tank is being discharged when using this value, independent valve verification shall be performed. This value may be adjusted (increased or decreased) by factors to account for the actual discharge flow and actual dilution flow; however, controls shall be established to ensure that the allowable discharge flow is not exceeded and the dilution flow is maintained.

9. **Unit 3 Regenerant Evaporator Effluent Line - LWC-RE65**

The MP3 Regenerant Evaporator has been removed from service with DCR M3-97-041. Therefore a radiation monitor alarm is not needed.

10. **Unit 3 Waste Neutralization Sump Effluent Line - CND-RE07**

Same as *Section II.E.8*. Note that for this monitor, even though grab samples may not be required, setpoints still have to be utilized. In such cases, the default shall be the lower of: two times background or the value as specified in *II.E.8*.

II.E. LIQUID MONITOR SETPOINTS (Cont'd)**11a. Unit 3 Steam Generator Blowdown - SSR-RE08**

The alarm setpoint for this monitor assumes:

- Steam generator blowdown rate of 400 gpm (maximum blowdown total including weekly cleaning of generators - per ERC 25212-ER-99-0133).
- The release rate limit is conservatively set at 10% of the 10CFR Part 20 limit (0.1 times the I-131 MPC* for unrestricted areas which equals $0.1 \times 3 \times 10^{-7} \mu\text{Ci/ml}$).
- Minimum possible circulating and service water dilution flow during periods of blowdown = 300,000 gpm (2 circulating water pumps) + 30,000 gpm (2 service water pumps) = 330,000 gpm.
- Background can be added after above calculations are performed.

Therefore, the alarm setpoint corresponds to a concentration of:

$$\text{Alarm } (\mu\text{Ci/ml}) = \frac{330,000}{400} \times 3 \times 10^{-8} + \text{background} = 2.47 \times 10^{-5} \mu\text{Ci/ml} + \text{background}$$

This setpoint may be increased through proper administrative controls if the steam generator blowdown rate is maintained less than 400 gpm and/or more than 2 circulating and 2 service water pumps are available. The amount of the increase would correspond to the ratio of flows to those assumed above or:

$$\text{Alarm } (\mu\text{Ci/ml}) = 2.47 \times 10^{-5} \mu\text{Ci/ml} \times \frac{\text{circulating \& service water flow (gpm)}}{330,000} \times \frac{400}{\text{S/G blowdown (gpm)}} +$$

$$\text{Background} = 3 \times 10^{-8} \mu\text{Ci/ml} \times \frac{\text{circulating \& service water flow (gpm)}}{\text{total S/G blowdown (gpm)}} + \text{Background}$$

Note: The Steam Generator Blowdown alarm criteria is in practice based on setpoints required to detect allowable levels of primary to secondary leakage. This alarm criteria is typically more restrictive than that required to meet discharge limits. This fact shall be verified, however, whenever the alarm setpoint is recalculated.

- * In lieu of using the I-131 MPC value, the identified MPC values for unrestricted area may be used.

11b. Unit 3 Steam Generator Blowdown Effluent Concentration Limitation

The results of analysis of blowdown samples required by Table I.C-3 of Section I of the REMODCM shall be used to ensure that blowdown effluent releases do not exceed the concentration limits in 10CFR20, Appendix B (version prior to January 1, 1994).

II.E. LIQUID MONITOR SETPOINTS (Cont'd)

12a. Unit 3 Turbine Building Floor Drains Effluent Line - DAS-RE50

The alarm setpoint for this monitor assumes:

- a. Drinking water is not a real pathway at this site. Therefore, the NRC code, LADTAP or other Regulatory Guide 1.109 code, is used to calculate the dose to the maximum individual.
- b. The average annual discharge flow is 1.11×10^{-2} ft³/sec (process flow during sump pump operation is 50 gpm and pump normally operates less than 10% of the time for a conservative average flow of 5 gpm). There is no continuous additional dilution, therefore, there is no dilution prior to discharge.
- c. Near field dilution factor = 13,000.
Far field dilution factor = 32,000.
(Reference: Millstone 3 FSAR, Section 2.4.13)
- d. Isotopic concentrations were taken from the Millstone 3 FSAR, Table 11.2-4 (See column under Turbine Building).
- e. Each concentration above was multiplied by the total annual flow (9.95×10^9 cm³, conservatively assuming 5 gpm continuous as discussed in item b).
- f. The maximum individual organ dose is set equal to 1% of 75 mrem (40CFR190 limit). The limiting individual is the child; maximum organ is the thyroid. This value is approximately one quarter of the value

The setpoint corresponding to 0.75 mrem to the child's thyroid is 3.8×10^{-5} uCi/ml.

12b. Unit 3 Service Water and Turbine Building Sump Effluent Concentration Limitation

Results of analyses of service water and turbine building sump samples taken in accordance with Table I.C-3 of Section I of the REMODCM shall be used to limit radioactivity concentrations in the service water and turbine building sump effluents to less than the limits in 10CFR20, Appendix B (version prior to January 1, 1994).

13. Bases for Liquid Monitor Setpoints

Liquid effluent monitors are provided on discharge pathways to control, as applicable, the release of radioactive materials in liquid effluents during actual or potential releases of liquid waste to the environment. The alarm / trip setpoints are calculated to ensure that the alarm / trip function of the monitor will occur prior to exceeding the limits of 10 CFR Part 20 (Appendix B, Table II, Column 2), which applies to the release of radioactive materials from all units on the site. This limitation also provides additional assurance that the levels of radioactive materials in bodies of water in Unrestricted Areas will result in exposures within the Section II.A design objectives of Appendix I to 10 CFR Part 50 to a member of the public.

In application, the typical approach is to determine the expected concentration in a radioactive release path and set the allowable discharge rate past the monitor such the existing dilution flow will limit the effluent release concentration to 10% of the MPC limit for the mix. The setpoint is then selected to be only 2 times the expected concentration, or 20% of the MPC limit. As a result, considerable margin is included in the selection of the setpoint for the monitor to account for unexpected changes in the discharge concentration or the contribution from other potential release pathways occurring at the same time as the planned effluent release. For those monitors on systems that are not expected to be contaminated, the alarm point is usually selected to be two times the ambient background to give notice that normal conditions may have changed and should be evaluated.

II.F. GASEOUS MONITOR SETPOINTS**1. Unit 1 Spent Fuel Pool Island Monitor - RM-SFPI-02**

The instantaneous release rate limit from the site shall be set in accordance with the conditions given in Section II.D.1.a in order to satisfy *Radiological Effluent Controls III.C.2 and III.D.2.1*.

The alarm setpoint shall be set at or below the monitor reading in $\mu\text{Ci}/\text{cc}$ corresponding to 29,000 $\mu\text{Ci}/\text{sec}$ assuming a maximum ventilation flow of 36,000 CFM. The corresponding monitor reading is $1.71\text{E-}3$ uCi/cc .

The release rate value of 29,000 $\mu\text{Ci}/\text{sec}$ assumes that 7% of the site limit for skin dose of 3000 mrem per year is assigned to the Unit 1 Spent Fuel Pool Island vent. If effluent conditions from the Unit 1 Spent Fuel Pool Island vent approach 29,000 uCi/sec , measures shall be taken to ensure that the sum of the allowed individual unit noble gas release rates do not exceed the site skin dose limit.

2. Unit 2 Wide Range Gas Monitor (WRGM) - RM8169

The instantaneous release rate limit from the site shall be set in accordance with the conditions given in Section II.D.1.a in order to satisfy Units 2 Radiological Effluent Controls IV.C.2 and IV.D.2.1.

The alarm setpoint shall be set at or below the monitor reading in uCi/cc corresponding to 74,000 $\mu\text{Ci}/\text{sec}$ assuming a maximum ventilation flow of 12,000 CFM. The corresponding monitor reading is $1.31\text{E-}2$ uCi/cc .

The release rate value of 74,000 $\mu\text{Ci}/\text{sec}$ assumes that 13% of the site limit is assigned to Unit 2 releases to the Millstone Stack. If effluent conditions from Unit 2 to the Millstone Stack approach 74,000 uCi/sec , measures shall be taken to ensure that the sum of the allowed individual unit noble gas release rates do not exceed the site limit as dictated in Section II.D.1.a, and described in the *REM ODCM Technical Information Document (MP-12-REM-REF02), Section 4.2*.

II.F. GASEOUS MONITOR SETPOINTS (Cont'd)**3. RESERVED****4. Unit 3 SLCRS - HVR-RE19B**

The instantaneous release rate limit from the site shall be set in accordance with the conditions given in Section II.D.1.a in order to satisfy Unit 3 Radiological Effluent Controls V.C.2 and V.D.2.1.

The alarm setpoint shall be set at or below the monitor reading in uCi/cc corresponding to 74,000 $\mu\text{Ci}/\text{sec}$ assuming a maximum ventilation flow of 12,000 CFM. The corresponding monitor reading is $1.31\text{E}-2$ uCi/cc.

The release rate value of 74,000 $\mu\text{Ci}/\text{sec}$ assumes that 13% of the site limit is assigned to Unit 3 releases to the Millstone Stack. If effluent conditions from Unit 3 to the Millstone Stack approach 74,000 uCi/sec, measures shall be taken to ensure that the sum of the allowed individual unit noble gas release rates do not exceed the site limit as dictated in Section II.D.1.a, and described in the *REM ODCM Technical Information Document (MP-12-REM-REF02), Section 4.2.*

5. Unit 2 Vent - Noble Gas Monitor - RM8132B

The instantaneous release rate limit from the site shall be set in accordance with the conditions given in Section II.D.1.a in order to satisfy Radiological Effluent Controls in Sections IV.C.2 and IV.D.2.a. The alarm setpoint shall be set at or below the "cpm" corresponding to 95,000 $\mu\text{Ci}/\text{sec}$ from the MP2 vent noble gas monitor calibration curve. The calibration curve (given as $\mu\text{Ci}/\text{sec}$ per cpm) is determined by assuming the maximum possible ventilation flow for various fan combinations. Curves for three different fan combinations are normally given.

The release rate value of 95,000 $\mu\text{Ci}/\text{sec}$ assumes that 33% of the site limit is assigned to the MP2 vent. If effluent conditions from the MP2 vent approach the alarm setpoint, it may be increased if the Site Stack or MP3 vent setpoints are also changed to ensure that the sum of the allowed individual unit noble gas release rates do not exceed the site limit as dictated in Section II.D.1.a, and described in the *REM ODCM Technical Information Document (MP-12-REM-REF02), Section 4.2.*

II.F. GASEOUS MONITOR SETPOINTS (Cont'd)**6. Unit 2 Waste Gas Decay Tank Monitor RM9095**

Administratively all waste gas decay tank releases are via the Millstone Stack. Unit 2 has a release rate limit to the Millstone Stack of 74,000 $\mu\text{Ci}/\text{sec}$ (see the *REMODCM Technical Information Document (MP-12-REM-REF02)*, Section 4.2 for bases).

Batch releases of waste gas shall be limited to less than 10% of the Unit 2 releases to the Millstone Stack release rate limits. Therefore, the waste gas decay tank monitor setpoint should be set not to exceed 7,400 uCi/sec .

The MP2 waste gas decay tank monitor (given $\mu\text{Ci}/\text{cc}$ per cpm) calibration curve and the tank discharge rate is used to assure that the concentration of gaseous activity being released from a waste gas decay tank does not cause the setpoint of 7,400 uCi/sec to be exceeded.

7. Unit 3 Vent Noble Gas Monitor - HVR-RE10B

The instantaneous release rate limit from the site shall be set in accordance with the conditions given in Section II.D.1.a in order to satisfy Radiological Effluent Controls in Sections V.C.2 and V.D.2.a.

The alarm setpoint shall be set at or below a value of 9.5×10^{-4} $\mu\text{Ci}/\text{cc}$ for the MP3 vent.

The release rate value of 9.5×10^{-4} $\mu\text{Ci}/\text{cc}$ assumes that 33% of the site limit is assigned to the MP3 vent. This value corresponds to a release rate of 95,000 $\mu\text{Ci}/\text{sec}$ and a maximum ventilation flow rate of 210,000 CFM (per memo from G. C. Knight to R. A. Crandall, MP-3-1885, July 19, 1989). If effluent conditions from the MP3 vent approach the alarm setpoint, it may be increased if the Site Stack or MP2 vent setpoints are also changed to ensure that the sum of the allowed individual unit noble gas release rates do not exceed the site limit as dictated in Section II.D.1.a, and described in the *REMODCM Technical Information Document (MP-12-REM-REF02)*, Section 4.2.

8. Unit 3 Engineering Safeguards Building Monitor - HVQ-RE49

Assuming releases less than 10% of the MP3 FSAR design releases of noble gases (*Table 11.3-11*, 1.4×10^4 Ci/year which is equal to 450 $\mu\text{Ci}/\text{sec}$) assures that less than 1% of the above instantaneous release rate is added by this intermittent pathway ($450/290,000 = 0.16\%$). Assuming a flow rate of 6,500 CFM (3.05×10^6 cc/sec) for this pathway translates this limit to:

$$0.1 \times 450 / 3.05 \times 10^6 = 1.5 \times 10^{-5} \mu\text{Ci}/\text{cc}$$

The Alarm setpoint shall be set at or below this value.

II.F. GASEOUS MONITOR SETPOINTS (Cont'd)**9. Bases for Gaseous Monitor Setpoints**

Gaseous effluent monitors are provided on atmospheric release pathways to control, as applicable, the release of radioactive materials in gaseous effluents to the environment. The alarm / trip setpoints are calculated to ensure that the alarm / trip function of the monitor will occur prior to exceeding the dose rate limits required by the *Technical Specifications (Units 2 and 3)* or *Radiological Effluent Controls (Sections III, IV, and V)* requirements for each unit. Monitor setpoint selection is based on a conservative set of conditions for each release pathway (as discussed above for each monitor pathway) such that the dose rate at any time at and beyond the site boundary from all gaseous effluents from all units on the site will be within the numerical values of the annual dose limits of 10 CFR Part 20 (the version prior to January 1, 1994) in Unrestricted Areas. Since the Radiological Effluent Controls are constructed such that the numerical values of the annual dose limits of 10 CFR Part 20 be applied on an instantaneous basis (i.e., no time averaging over the year), and the integrated dose objectives of 10 CFR 50, Appendix I provide for corrective actions to reduce effluents if the ALARA dose values are exceeded, assurance is obtained that compliance with the revised annual dose limits of 10 CFR 20.1301 (100 mrem total effective dose equivalent to a member of the public) will also be met. The use of the stated instantaneous release rate values, which equate to the site dose rate limits, also provides operational flexibility to accommodate short periods of higher than normal effluent releases that may occur during plant operations.

APPENDIX II.A**REMODCM METHODOLOGY CROSS-REFERENCES**

Radiological effluent controls (Sections III, IV, and V) identify the requirements for monitoring and limiting liquid and gaseous effluents releases from the site such the resulting dose impacts to members of the public are kept to "As Low As Reasonably Achievable" (ALARA). The demonstration of compliance with the dose limits is by calculational models that are implemented by Section II of the REMODCM.

Table App. II.A-1 provides a cross-reference guide between liquid and gaseous effluent release limits and those sections of the REMODCM, which are used to determine compliance. It also shows the administrative Technical Specifications which reference the REMODCM for operation of radioactive waste processing equipment. This table also provides a quick outline of the applicable limits or dose objectives and the required actions if those limits are exceeded. Details of the effluent control requirements and the implementing sections of the REMODCM should be reviewed directly for a full explanation of the requirements.

TABLE App. II.A-1

MILLSTONE EFFLUENT REQUIREMENTS AND METHODOLOGY CROSS REFERENCE

Radiological Effluent Controls and Technical Specifications	REM ODCM Methodology Section	Applicable Limit or Objective	Exposure Period	Required Action
IV/V.E.1.a Liquid Effluent Concentration	Tables I.C-2 and I.C-3	10CFR20, App. B, Table II, Column 2, and 2×10^{-4} $\mu\text{Ci/mL}$ for dissolved noble gases*	Instantaneous	Restore concentration to within limits within 15 minutes.
IV/V.E.1.b Dose-Liquids	II.C.1 II.C.2	≤ 1.5 mrem T.B. ≤ 5 mrem Organ	Calendar Quarter**	30-day report if exceeded. Relative accuracy or conservatism of the calculations shall be confirmed by performance of the REMP in Section I.
	II.C.3 II.C.4	≤ 3 mrem T.B. ≤ 10 mrem Organ	Calendar Year	
T.S. 6.16 (Unit 2) T.S. 6.14 (Unit 3) Liquid Radwaste Treatment	I.C.2 II.C.5	≤ 0.06 mrem T.B. ≤ 0.2 mrem Organ	Projected for 31 days (if system not in use)	Return to operation Liquid Waste Treatment System.
III.D.2.a IV/V.D.2.a Gaseous Effluents Dose Rate	Tables I.D-1, I.D-2, and I.D-3	≤ 500 mrem/yr T.B. from noble gases*	Instantaneous	Restore release rates to within specifications within 15 minutes.
	II.D.1.a	≤ 3000 mrem/yr skin from noble gases*		
	II.D.1.b	≤ 1500 mrem/yr organ from particulates with $T_{1/2} > 8\text{d.}$, I-131, I-133 and tritium*		
III.D.2.b IV/V.D.2.b Dose Noble Gases	II.D.2	≤ 5 mrad gamma air ≤ 10 mrad beta air	Calendar Quarter**	30-day report if exceeded.
		≤ 10 mrad gamma air ≤ 20 mrad beta air	Calendar Year	
III.D.2.c IV/V.D.2.c Dose I-131, I-133, Particulates, H-3	II.D.3	≤ 7.5 mrem organ ≤ 15 mrem organ	Calendar Quarter** Calendar Year	30-day report if exceeded. Relative accuracy or conservatism of the calculations shall be confirmed by performance of the REMP in Section I.
T.S. 5.6.4 (Unit 1) T.S. 6.14 (Unit 2) T.S. 6.16 (Unit 3) Gaseous Radwaste Treatment	I.D.2 II.D.4	> 0.02 mrad gamma air > 0.04 mrad beta air > 0.03 mrem organ	Projected for 31 Days (if system not in use)	Return to operation Gaseous Radwaste Treatment System.
III.E IV/V.F Total Dose	II.D.6	≤ 25 mrem T.B.* ≤ 25 mrem organ* ≤ 75 mrem thyroid*	12 Consecutive Months**	30-day report if Unit 1 Effluent Control III.D.1.2, III.D.2.2, or III.D.2.3 or Units 2/3 Effluent Control IV/V.E.1.2, IV/V.E.2.2, or IV/V.E.2.3 are exceeded by a factor of 2. Restore dose to public to within the applicable EPA limit(s) or obtain a variance.

NOTE: T.B. means total or whole body.

* Applies to the entire site (Units 1, 2, and 3) discharges combined.

**Cumulative dose contributions calculated once per 31 days.

SECTION III

MILLSTONE UNIT 1

RADIOLOGICAL EFFLUENT

CONTROLS

DOCKET NO. 50-245

Revision 22
October 1, 2001

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND
OFFSITE DOSE CALCULATION MANUAL (REMODOCM)**

SECTION III: MILLSTONE UNIT ONE RADIOLOGICAL EFFLUENT CONTROLS

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE NO.</u>
TABLE OF CONTENTS	III-i
III.A. INTRODUCTION	III.A-1
III.B. DEFINITIONS	III.B-1
III.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION	
1. Radioactive Liquid Effluent Monitoring Instrumentation	III.C-1
2. Radioactive Gaseous Effluent Monitoring Instrumentation	III.C-6
3. Section reserved	III.C-11
4. Section reserved	III.C-12
III.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS	
1. Radioactive Liquid Effluents	III.D-1
a. Radioactive Liquid Effluents Concentrations	III.D-1
b. Radioactive Liquid Effluents Doses	III.D-2
2. Radioactive Gaseous Effluents	III.D-3
a. Radioactive Gaseous Effluents Dose Rate	III.D-3
b. Radioactive Gaseous Effluents Noble Gas Dose	III.D-4
c. Radioactive Gaseous Effluents	
- Doses from Radionuclides Other Than Noble Gas Doses	III.D-5
III.E. TOTAL RADIOLOGICAL DOSE FROM STATION OPERATIONS	III.E-1
III.F. BASES	III.F-1

***MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND
OFFSITE DOSE CALCULATION MANUAL (REMODOCM)***

SECTION III: MILLSTONE UNIT ONE RADIOLOGICAL EFFLUENT CONTROLS

TABLE OF CONTENTS (Cont'd)

<u>Table Number</u>	<u>Table Name</u>	<u>Page</u>
III.C-1	Radioactive Liquid Effluent Monitoring Instrumentation	III.C-2
III.C-2	Radioactive Liquid Effluent Monitoring Instrumentation Surveillance Requirements	III.C-4
III.C-3	Radioactive Gaseous Effluent Monitoring Instrumentation	III.C-7
III.C-4	Radioactive Gaseous Effluent Monitoring Instrumentation Surveillance Requirements	III.C-9

<u>Figure Number</u>	<u>Figure Name</u>	<u>Page</u>
III.D-1	Site boundary	III.D-6

III.A. INTRODUCTION

The purpose of this section is to provide the following for Millstone Unit One:

- a. the effluent radiation monitor controls and surveillance requirements,
- b. the effluent radioactivity concentration and dose controls and surveillance requirements, and
- c. the bases for the controls and surveillance requirements.

Definitions of certain terms are provided as an aid for implementation of the controls and requirements.

Some surveillance requirements refer to specific sub-sections in Sections I and II as part of their required actions.

III.B. DEFINITIONS

The defined terms of this sub-section appear in capitalized type and are applicable throughout Section III.

- B.1 ACTION - that part of a Control that prescribes remedial measures required under designated conditions.
- B.2 INSTRUMENT CALIBRATION - the adjustment, as necessary, of the instrument output such that it responds within the necessary range and accuracy to know values of the parameter that the instrument monitors. The INSTRUMENT CALIBRATION shall encompass those components, such as sensors, displays, and trip functions, required to perform the specified safety function(s). The INSTRUMENT CALIBRATION shall include the INSTRUMENT FUNCTIONAL TEST and may be performed by means of any series of sequential, overlapping, or total channel steps so that the entire channel is calibrated.
- B.3 INSTRUMENT FUNCTIONAL TEST - the injection of a simulated or actual signal into the channel as close to the sensor as practicable to verify that the instrument is OPERABLE, including all components in the channel, such as alarms, interlocks, displays, and trip functions, required to perform the specified safety function(s). The INSTRUMENT FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total channel steps so that the entire channel is tested.
- B.4 INSTRUMENT CHECK - the qualitative determination of operability by observation of behavior during operation. This determination shall include, where possible, comparison of the instrument with other independent instruments measuring the same variable.
- B.5 OPERABLE - An instrument shall be OPERABLE when it is capable of performing its specified functions(s). Implicit in this definition shall be the assumption that all necessary attendant instrumentation, controls, normal and emergency electrical power sources, cooling or seal water, lubrication or other auxiliary equipment that are required for the instrument to perform its functions(s) are also capable of performing their related support function(s).
- B.6 REAL MEMBER OF THE PUBLIC - an individual, not occupationally associated with the Millstone site, who is exposed to existing dose pathways at one particular location. This does not include employees of the utility or utilities which own a Millstone plant and utility contractors and vendors. Also excluded are persons who enter the Millstone site to service equipment or to make deliveries. This does include persons who use portions of the Millstone site for recreational, occupational, or other purposes not associated with any of the Millstone plants.
- B.7 SITE BOUNDARY - that line beyond which the land is not owned, leased, or otherwise controlled by the licensee.
- B.8 SOURCE CHECK - the qualitative assessment of channel response when the channel is exposed to radiation.
- B.9 RADIOACTIVE WASTE TREATMENT SYSTEMS - Radioactive Waste Treatment Systems are those liquid, gaseous, and solid waste systems which are required to maintain control over radioactive materials in order to meet the controls set forth in this section.

III.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION

1. Radioactive Liquid Effluent Monitoring Instrumentation

CONTROLS

No controls required; Unit 1 is not currently releasing radioactivity in liquid effluents.

APPLICABILITY

NA

ACTION: NA

SURVEILLANCE REQUIREMENTS

None required.

|

This page intentionally blank

This page intentionally blank

This page intentionally blank

This page intentionally blank

III.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION (Cont'd)**2. Radioactive Gaseous Effluent Monitoring Instrumentation****CONTROLS**

The radioactive gaseous effluent monitoring instrumentation channels shown in Table III.C-3 shall be OPERABLE with applicable alarm setpoints set to ensure that the limits of Control III.D.2.a are not exceeded. The setpoints shall be determined in accordance with methods and parameters described in Sections II.F.3 and II.F.4.

Applicability: As shown in Table III.C-3.

Action:

- a. With a radioactive gaseous effluent monitoring instrumentation channel alarm setpoint less conservative than required by the above Control, without delay suspend the release of radioactive gaseous effluents monitored by the affected channel, or declare the channel inoperable, or change the setpoint so it is acceptably conservative.
- b. With the number of channels less than the minimum channels operable requirements, take the action shown in Table III.C-3. Exert best efforts to restore the inoperable monitor to OPERABLE status within 30 days and, if unsuccessful, explain in the next Radiological Effluent Release Report why the inoperability was not corrected in a timely manner. Release need not be terminated after 30 days provided the specified actions are continued.

SURVEILLANCE REQUIREMENT

Each radioactive gaseous effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the INSTRUMENT CHECK, INSTRUMENT CALIBRATION, INSTRUMENT FUNCTIONAL TEST, and SOURCE CHECK operations at the frequencies shown in Table III.C-4.

TABLE III.C-3

RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

<u>Instrument</u>	<u>Minimum # Operable</u>	<u>Alarm Setpoints</u>	<u>Applicability</u>	<u>Action</u>
1. Spent Fuel Pool Island Vent				
(a) Noble Gas Activity Monitor	1	Yes	*	A
(b) Particulate Sampler	1	No	*	B
(c) Vent Flow Rate Monitor	1	No	*	C
(d) Sampler Flow Rate Monitor	1	Yes	*	D
2. Balance of Plant Vent				
(a) Particulate Sampler	1	No	*	B

* Channels are OPERABLE and in service on a continuous, uninterrupted basis when exhaust fans are operating, except that outages are permitted, within the time frame of the specified ACTION statement, for the purpose of maintenance and performance of required test, checks and calibrations.

TABLE III.C-3 (Continued)

ACTION STATEMENTSAction A

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and that grab samples are taken once per week, or daily when fuel is being moved, and these samples are analyzed for gross activity within 24 hours.

Action B

With the number of samplers OPERABLE less than required by the Minimum number OPERABLE requirement, effluent releases via this pathway may continue provided that the best efforts are made to repair the instrument and that a 24 hour sample is collected with auxiliary sampling equipment once every seven (7) days, or anytime significant generation of airborne radioactivity is expected, and analyzed for principal gamma emitters with half lives greater than 8 days within 24 hours after the end of the sampling period.

Action C

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and a default flow rate of 36,000 cfm will be recorded daily.

Action D

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and that the flow rate is estimated once during the Chemistry compensatory sampling time period.

Table III.C-4

RADIOACTIVE GASEOUS EFFLUENT MONITORING
INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>Instrument</u>	<u>Instrument Check</u>	<u>Instrument Calibration</u>	<u>Instrument Functional Test</u>	<u>Source Check</u>
1. Spent Fuel Pool Island Vent				
(a) Noble Gas Activity Monitor	D(3)	T(6)	Q(7)	M
(b) Particulate Sampler	TM	NA	NA	NA
(c) Vent Flow Rate Monitor	D	T	NA	NA
(d) Sampler Flow Rate Monitor	D	T	NA	NA
2. Balance of Plant Vent				
(a) Particulate Sampler	TM	NA	NA	NA

D = Daily
W = Weekly
TM = Twice per month
M = Monthly
Q = Once every 3 months
T = Once every two years
NA = Not Applicable

Table III.C-4 (Continued)

TABLE NOTATION

- (1) RESERVED
- (2) RESERVED

- (3) Instrument check daily only when there exist releases via this pathway.
- (4) RESERVED
- (5) RESERVED
- (6) Calibration shall include the use of a known source whose strength is determined by a detector which has been calibrated to an NIST source. These sources shall be in a known reproducible geometry.
- (7) The INSTRUMENT FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exist:
 - 1. Instrument indicates measured levels above the alarm/trip setpoint.
 - 2. Instrument indicates a downscale failure.

III.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION (Cont'd)

3. Section reserved

III.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION (Cont'd)

4. Section reserved

III.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION (Cont'd)

THIS PAGE BLANK

III.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS

1. Radioactive Liquid Effluents

a. Radioactive Liquid Effluents Concentrations

CONTROLS

No controls required; Unit 1 is not currently releasing radioactivity in liquid effluents.

APPLICABILITY: NA

ACTION: NA

SURVEILLANCE REQUIREMENT

None required.

III.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS (Cont'd)

1. Radioactive Liquid Effluents (Cont'd)

b. Radioactive Liquid Effluents Doses

CONTROLS

No controls required; Unit 1 is not currently releasing radioactivity in liquid effluents

APPLICABILITY: NA

ACTION: NA

SURVEILANCE REQUIREMENTS

None required.

III.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS**2. Radioactive Gaseous Effluents****a. Radioactive Gaseous Effluents Dose Rate****CONTROLS**

The dose rate, at any time, offsite (see Figure III.D-1) due to radioactive materials released in gaseous effluents from the site shall be limited to the following values:

- a. The dose rate limit for noble gases shall be less than or equal to 500 mrem/yr to the total body and less than or equal to 3000 mrem/yr to the skin; and,
- b. The dose rate limit for Tritium and for all radioactive materials in particulate form with half lives greater than 8 days shall be less than or equal to 1500 mrem/yr to any organ.

APPLICABILITY: At all times.

ACTION:

With the dose rate(s) exceeding the above limits, decrease the release rate to comply with the limit(s) given in Control III.D.2.a within 15 minutes.

SURVEILLANCE REQUIREMENTS

1. The instantaneous release rate corresponding to the above dose rate shall be determined in accordance with the methodology of Section II.
2. The instantaneous release rate shall be monitored in accordance with the requirements of Section III.C.2.
3. Sampling and analysis shall be performed in accordance with Section I to assure that the limits of Control III.D.2.a are met.

III.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS (Cont'd)**2. Radioactive Gaseous Effluents (Cont'd)****b. Radioactive Gaseous Effluents Noble Gas Dose****CONTROLS**

The air dose offsite (see Figure III.D-1) due to noble gases released in gaseous effluents from Unit 1 shall be limited to the following:

- a. During any calendar quarter, to less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation;
- b. During any calendar year to less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.

APPLICABILITY: At all times.

ACTION:

With the calculated air dose from radioactive noble gases in gaseous effluents exceeding any of the above limits prepare and submit to the Commission within 30 days a Special Report which identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce the releases of radioactive noble gases in gaseous effluents during the remainder of the current calendar quarter and the calendar year so that the cumulative dose during the calendar year is within 10 mrad for gamma radiation and 20 mrad for beta radiation.

SURVEILLANCE REQUIREMENTS

1. **Dose Calculations** - Cumulative dose contributions for the current calendar quarter and current calendar year shall be determined in accordance with Section II once every 31 days.
2. Relative accuracy or conservatism of the calculations shall be confirmed by performance of the Radiological Environmental Monitoring Program as detailed in Section I.

III.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS (Cont'd)**2. Radioactive Gaseous Effluents (Cont'd)****c. Gaseous Effluents - Dose from Radionuclides Other than Noble Gas****CONTROLS**

The dose to any REAL MEMBER OF THE PUBLIC from Tritium and radioactive materials in particulate form with half lives greater than 8 days in gaseous effluents released offsite from Unit 1 (see Figure III.D-1) shall be limited to the following:

- a. During any calendar quarter to less than or equal to 7.5 mrem [to any organ];
- b. During any calendar year to less than or equal to 15 mrem [to any organ].

APPLICABILITY: At all times.

ACTION:

With the calculated dose from the release of Tritium and radioactive materials in particulate form exceeding any of the above limits prepare and submit to the Commission within 30 days a Special Report which identifies the cause(s) for exceeding the limit and defines the corrective actions to be taken to reduce the releases during the remainder of the current calendar quarter and during the remainder of the calendar year so that the cumulative dose or dose commitment to any REAL MEMBER OF THE PUBLIC from such releases during the calendar year is within 15 mrem to any organ.

SURVEILLANCE REQUIREMENTS

1. **Dose Calculations** - Cumulative dose contributions for the current calendar quarter and current calendar year shall be determined in accordance with Section II once every 31 days.
2. Relative accuracy or conservatism of the calculations shall be confirmed by performance of the Radiological Environmental Monitoring Program as detailed in Section I.




Figure III.D-1

III.E. TOTAL RADIOLOGICAL DOSE FROM STATION OPERATIONS

CONTROLS

The annual dose or dose commitment to any REAL MEMBER OF THE PUBLIC from the Millstone Site is limited to less than or equal to 25 mrem to the total body or any organ (except the thyroid, which is limited to less than or equal to 75 mrem).

APPLICABILITY: At all times.

ACTION:

With the calculated dose from the release of radioactive materials in liquid or gaseous effluents exceeding twice the limits of Controls III.D.1.b, III.D.2.b, or III.D.2.c prepare and submit a Special Report to the Commission within 30 days and limit the subsequent releases such that the dose commitment from the site to any REAL MEMBER OF THE PUBLIC from the Millstone Site is limited to less than or equal to 25 mrem to the total body or any organ (except thyroid, which is limited to less than or equal to 75 mrem) over 12 consecutive months. This Special Report shall include an analysis which demonstrates that radiation exposures from the site to any REAL MEMBER OF THE PUBLIC from the Millstone Site (including all effluent pathways and direct radiation) are less than the 40 CFR Part 190 Standard.

If the estimated doses exceed the above limits, the Special Report shall include a request for a variance in accordance with the provisions of 40 CFR Part 190. Submittal of the report is considered a timely request, and a variance is granted until staff action on the request is complete.

SURVEILLANCE REQUIREMENTS

Cumulative dose contributions from liquid and gaseous effluents and direct radiation from the Millstone Site shall be determined in accordance with Section II once per 31 days.

III.F. BASES

Section III.C.1 - Radioactive Liquid Effluent Monitoring Instrumentation

No controls required; Unit 1 is not currently releasing radioactivity in liquid effluents

Section III.C.2 - Radioactive Gaseous Effluent Monitoring Instrumentation

The Spent Fuel Pool Island Vent is the only gaseous pathway currently requiring radiation monitoring for Unit 1.

Section III.D.1.a - Radioactive Liquid Effluents Concentrations

No controls required; Unit 1 is not currently releasing radioactivity in liquid effluents

Section III.D.1.b - Radioactive Liquid Effluents Doses

No controls required; Unit 1 is not currently releasing radioactivity in liquid effluents

Section III.D.2.a - Radioactive Gaseous Effluents Dose Rate

This control is provided to ensure that the dose rate at anytime from gaseous effluents from all units on the site will be within the annual dose limits of 10 CFR Part 20 for all areas offsite. The annual dose limits are the doses associated with the concentrations of 10 CFR Part 20, Appendix B, Table II. These limits provide reasonable assurance that radioactive material discharged in gaseous effluents will not result in the exposure of an individual offsite to annual average concentrations exceeding the limits specified in Appendix B, Table II of 10 CFR Part 20 (10 CFR 20.106(b)). For individuals who may, at times, be within the site boundary, the occupancy of that individual will be sufficiently low to compensate for any increase in the atmospheric diffusion factor above that for the site boundary. The specified release rate limits restrict, at all times, the corresponding gamma and beta dose rates above background to an individual at or beyond the site boundary to less than or equal to 500 mrem/year to the total body or to less than or equal to 3000 mrem/year to the skin. These release rate limits also restrict, at all times, the corresponding thyroid dose rate above background to an infant via the cow-milk-infant pathway to less than or equal to 1500 mrem/year for the nearest cow to the plant.

Section III.D.2.b - Radioactive Gaseous Effluents Noble Gas Dose

This control is provided to implement the requirements of Sections II.B., III.A and IV.A of Appendix I, 10 CFR Part 50. The control implements the guides set forth in Section II.B of Appendix I. The action statements provide the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in gaseous effluents will be kept "as low as is reasonably achievable." The Surveillance Requirements implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of an individual through the appropriate pathways is unlikely to be substantially underestimated. The dose calculations established in the ODCM for calculating the doses due to the actual release rates of radioactive noble gases in gaseous effluents will be consistent with the methodology provided in Regulatory Guide 1.109, "Calculational of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," Revision 1, July 1977.

The ODCM equations provided for determining the air doses at the site boundary were based upon utilizing successively more realistic dose calculational methodologies. More realistic dose calculational methods are used whenever simplified calculations indicate a dose approaching a substantial portion of the regulatory limits. The methods used are, in order, previously determined air dose per released activity ratio, historical meteorological data and actual radionuclide mix released, or real time meteorology and actual radionuclides released.

Section III.D.2.c - Radioactive Gaseous Effluents, Particulates, and Gas Other Than Noble Gas Doses

These controls are provided to implement the requirements of Sections II.C, III.A and IV.A of Appendix I, 10 CFR Part 50. The controls are the guides set forth in Section II.C of Appendix I. The action statements provide the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive materials in gaseous effluents will be kept "as low as is reasonably achievable." The ODCM calculational methods specified in the surveillance requirements implement the requirements in Section III.A of Appendix I that conformance with the guides for Appendix I be shown by calculational procedures based on models and data such that the actual exposure of an individual through appropriate pathways is unlikely to be substantially underestimated. The ODCM calculational methods for calculating the doses due to the actual release rates of the subject materials will be consistent with the methodology provided in Regulatory Guide 1.109, "Calculating of Annual Dose to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision I, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," Revision I, July 1977. These equations provide for determining the doses based upon either conservative atmospheric dispersion and an assumed critical nuclide mix or using real time meteorology and specific nuclides released. The release rate specifications for radioactive material in particulate form and radionuclides other than noble gases are dependent on the existing radionuclide pathways to man. The pathways which are examined in the development of these calculations are: 1) individual inhalation of airborne radionuclides, 2) deposition of radionuclides onto green leafy vegetation with subsequent consumption by man, (3) deposition onto grassy areas where milk animals and meat producing animals graze with consumption of the milk and meat by man, and 4) deposition on the ground with subsequent exposure of man.

Section III.E - Total Radiological Dose from Station Operations

This control is provided to meet the reporting requirements of 40 CFR Part 190. For the purpose of the Special Report, it may be assumed that the dose commitment to any REAL MEMBER OF THE PUBLIC from other fuel cycle sources is negligible, with the exception that dose contributions from other nuclear fuel cycle facilities at the same site or within a radius of 5 miles must be considered.

SECTION IV

MILLSTONE UNIT 2

RADIOLOGICAL EFFLUENT

CONTROLS

DOCKET NO. 50-336

Revision 22
October 1, 2001

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND
OFFSITE DOSE CALCULATION MANUAL (REMODCM)**

SECTION IV: MILLSTONE UNIT TWO RADIOLOGICAL EFFLUENT CONTROLS

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE NO.</u>
TABLE OF CONTENTS	IV-i
IV.A. INTRODUCTION	IV.A-1
IV.B. DEFINITIONS	IV.B-1
IV.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION	
1. Radioactive Liquid Effluent Monitoring Instrumentation	IV.C-1
2. Radioactive Gaseous Effluent Monitoring Instrumentation	IV.C-7
IV.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS	
1. Radioactive Liquid Effluents	IV.D-1
a. Radioactive Liquid Effluents Concentrations	IV.D-1
b. Radioactive Liquid Effluents Doses	IV.D-2
2. Radioactive Gaseous Effluents	IV.D-3
a. Radioactive Gaseous Effluents Dose Rate	IV.D-3
b. Radioactive Gaseous Effluents Noble Gas Dose	IV.D-4
c. Radioactive Gaseous Effluents	IV.D-5
- Doses from Radionuclides Other Than Noble Gas	
IV.E. TOTAL RADIOLOGICAL DOSE FROM STATION OPERATIONS	IV.E-1
IV.F. BASES	IV.F-1

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND
OFFSITE DOSE CALCULATION MANUAL (REMDCM)**

SECTION IV: MILLSTONE UNIT TWO RADIOLOGICAL EFFLUENT CONTROLS

TABLE OF CONTENTS (Cont'd)

<u>Table Number</u>	<u>Table Name</u>	<u>Page</u>
IV.C-1	Radioactive Liquid Effluent Monitoring Instrumentation	IV.C-2
IV.C-2	Radioactive Liquid Effluent Monitoring Instrumentation Surveillance Requirements	IV.C-5
IV.C-3	Radioactive Gaseous Effluent Monitoring Instrumentation	IV.C-8
IV.C-4	Radioactive Gaseous Effluent Monitoring Instrumentation Surveillance Requirements	IV.C-10
<u>Figure Number</u>	<u>Figure Name</u>	<u>Page</u>
IV.D-1	Site boundary	IV.D-6

IV.A. INTRODUCTION

The purpose of this section is to provide the following for Millstone Unit Two:

- a. the effluent radiation monitor controls and surveillance requirements,
- b. the effluent radioactivity concentration and dose controls and surveillance requirements, and
- c. the bases for the controls and surveillance requirements.

Definitions of certain terms are provided as an aid for implementation of the controls and requirements.

Some surveillance requirements refer to specific sub-sections in Sections I and II as part of their required actions.

IV.B DEFINITIONS

The defined terms of this sub-section appear in capitalized type and are applicable throughout Section IV.

B.1 ACTION

ACTION shall be those additional requirements specified as corollary statements to each principal control and shall be part of the control.

B.2 OPERABLE - OPERABILITY

An instrument shall be **OPERABLE** or have **OPERABILITY** when it is capable of performing its specified function(s) and when all necessary attendant instrumentation, controls, normal and emergency electrical power sources, or other auxiliary equipment that are required for the instrument to perform its function(s) are also capable of performing their related support function(s).

B.3 CHANNEL CALIBRATION

A **CHANNEL CALIBRATION** shall be the adjustment, as necessary, of the channel output such that it responds within the necessary range and accuracy to known values of the parameter which the channel monitors. The **CHANNEL CALIBRATION** shall encompass the entire channel including the sensors and alarm and/or trip functions, and shall include the **CHANNEL FUNCTIONAL TEST**. The **CHANNEL CALIBRATION** may be performed by any series of sequential, overlapping, or total channel steps such that the entire channel is calibrated.

B.4 CHANNEL CHECK

A **CHANNEL CHECK** shall be the qualitative assessment of channel behavior during operation by observation. This determination shall include, where possible, comparison of the channel indication and/or status with other indications and/or status derived from independent instrument channels measuring the same parameter.

B.5 CHANNEL FUNCTIONAL TEST

A **CHANNEL FUNCTIONAL TEST** shall be the injection of a simulated signal into the channel as close to the primary sensor as practicable to verify **OPERABILITY** including alarm and/or trip functions.

B.6 SOURCE CHECK

A **SOURCE CHECK** shall be the qualitative assessment of channel response when the channel sensor is exposed to radiation.

B.7 MEMBER(S) OF THE PUBLIC

MEMBER(S) OF THE PUBLIC shall include all persons who are not occupationally associated with the plant. This category does not include employees of the utility, its contractors or its vendors. Also excluded from this category are persons who enter the site to service equipment or to make deliveries. This category does include persons who use portions of the site for recreational, occupational, or other purposes not associated with the plant.

The term "**REAL MEMBER OF THE PUBLIC**" means an individual who is exposed to existing dose pathways at one particular location.

B.8 MODE

Refers to Mode of Operation as defined in Safety Technical Specifications.

B.9 SITE BOUNDARY

The SITE BOUNDARY shall be that line beyond which the land is not owned, leased, or otherwise controlled by the licensee.

B.10 UNRESTRICTED AREA

An UNRESTRICTED AREA shall be any area at or beyond the site boundary to which access is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials or any area within the site boundary used for residential quarters or industrial, commercial, institutional and/or recreational purposes.

B.11 DOSE EQUIVALENT I-131

DOSE EQUIVALENT I-131 shall be that concentration of I-131 (microCurie/gram) which alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factors used for this calculation shall be those listed in Regulatory Guide 1.109 Rev. 1, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluent for the Purpose of Evaluating Compliance with 10 CFR Part 50 Appendix I.

IV.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION**1. Radioactive Liquid Effluent Monitoring Instrumentation****LIMITING CONDITIONS OF OPERATIONS**

The radioactive liquid effluent monitoring instrumentation channels shown in Table IV.C-1 shall be OPERABLE with applicable alarm/trip setpoints set to ensure that the limits of Specification IV.D.1.a are not exceeded. The setpoints shall be determined in accordance with methods and parameters described in Section II.

APPLICABILITY

As shown in Table IV.C-1

ACTION:

- a. With a radioactive liquid effluent monitoring instrumentation channel alarm/trip setpoint less conservative than required by the above Specification, without delay suspend the release of radioactive liquid effluents monitored by the affected channel, or declare the channel inoperable, or change the setpoint so it is acceptably conservative.
- b. With the number of channels less than the minimum channels OPERABLE requirement, take the action shown in Table IV.C-1. Exert best efforts to restore the inoperable monitor to OPERABLE status within 30 days and, if unsuccessful, explain in the next Radioactive Effluent Release Report why the inoperability was not corrected in a timely manner. Releases need not be terminated after 30 days provided the specified actions are continued.

SURVEILLANCE REQUIREMENTS

Each radioactive liquid effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION, and CHANNEL FUNCTIONAL TEST operations at the frequencies shown in Table IV.C-2.

TABLE IV.C-1

RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

<u>Instrument</u>	<u>Minimum # Operable</u>	<u>Alarm Setpoints Required</u>	<u>Applicability</u>	<u>Action</u>
1. Gross Radioactivity Monitors Providing Automatic Termination Of Release				
a. Clean Liquid Radwaste Effluent Line	1	Yes	*	A
b. Aerated Liquid Radwaste Effluent Line	1	Yes	***	A
c. Steam Generator Blowdown Monitor	1	Yes	****	B
d. Condensate Polishing Facility Waste Neut Sump.	1	Yes	***	E
2. Gross Radioactivity Monitors Not Providing Automatic Termination Of Release				
a. Reactor Building Closed Cooling Water Monitor#	1	Yes	*	C
3. Flow Rate Measurements				
a. Clean Liquid Radwaste Effluent Line	1	No	*	D
b. Aerated Liquid Radwaste Effluent Line	1	No	*	D
c. Condensate Polishing Facility	1	No	*	D
d. Dilution Water Flow	##	No	*	NA
e. Steam Generator Blowdown line ###		No	*	NA

TABLE IV.C-1 (Continued)

RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATIONTable Notes

- * At all times - which means that channels shall be OPERABLE and in service on a continuous, uninterrupted basis, except that outages are permitted, for a maximum of 12 hours, for the purpose of maintenance and performance of required test, checks, calibrations, or sampling.
 - ** Deleted.
 - *** Whenever the pathway is being used except that outages are permitted, for a maximum of 12 hours, for the purpose of maintenance and performance of required test, checks, calibrations, or sampling.
 - **** MODEs 1-4, except that outages are permitted, for a maximum of 12 hours, for the purpose of maintenance and performance of required test, checks, calibrations, or sampling.
 - # Since the only source of service water contamination is the reactor building closed cooling water, monitoring of the closed cooling water and conservative leakage assumptions will provide adequate control of service water effluents.
 - ## The dilution water is determined by the use of condenser cooling water and service water pump status. Only those pumps actually discharging to the quarry at the time of the release are included. Pump status is only reviewed for purpose of determining flows.
 - ### Determined by the use of valve curves and/or make up flow rates for the purpose of determining flows only.
- NA Not Applicable

TABLE IV.C-1 (Continued)

ACTION STATEMENTSAction A

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirements, effluent releases may continue provided that best efforts are made to repair the instrument and that prior to initiating a release:

1. At least two independent samples are analyzed in accordance with the first Surveillance Requirement of Specification IV.D.1.a and;
2. The original release rate calculations and discharge valving are independently verified by a second individual.

Action B

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, either:

1. Suspend all effluent releases via this pathway, or
2. Make best efforts to repair the instrument and obtain grab samples and analyze for gross radioactivity (beta or gamma) at a lower limit of detection of at least 3×10^{-7} uCi/ml;
 - a. Once per 12 hours when the specific activity of the secondary coolant is greater than 0.01 uCi/gm DOSE EQUIVALENT I-131.
 - b. Once per 24 hours when the specific activity of the secondary coolant is less than or equal to 0.01 uCi/gm DOSE EQUIVALENT I-131.

Action C

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and that once per 12 hours grab samples of the service water effluent are collected and analyzed for gross radioactivity (beta or gamma) at a lower limit of detection of at least 3×10^{-7} μ Ci/gm.

Action D

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and that the flow rate is estimated once per 4 hours during actual releases. Pump performance curves may be used to estimate flow.

Action E

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirements, effluent releases may continue provided that best efforts are made to repair the instrument and that prior to initiating a release:

1. At least two independent samples are analyzed in accordance with the first Surveillance Requirement of Specification IV.D.1.a, and;
2. If one of the samples has gross gamma greater than 5×10^{-7} uCi/ml, the original release rate calculations and discharge valving are independently verified by a second individual.

TABLE IV.C-2

RADIOACTIVE LIQUID EFFLUENT MONITORING

INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>Instrument</u>	<u>Channel Check</u>	<u>Source Check</u>	<u>Channel Calibration</u>	<u>Channel Functional Test</u>
1. Gross Radioactivity Monitors Providing Alarm And Automatic Termination Of Release				
a. Clean Liquid Radwaste Effluent Line	D*	P	R(1)	Q(2)
b. Aerated Liquid Radwaste Effluent Line	D*	P	R(1)	Q(2)
c. Steam Generator Blowdown Monitor	D*	M	R(1)	Q(2)
d. Condensate Polishing Facility Waste Neut Sump	D*	P	R(1)	Q(2)
2. Gross Radioactivity Monitors Providing Alarm But Not Providing Automatic Termination Of Release				
a. Reactor Building Closed Cooling Water	D*	M	R(1)	Q(2)
3. Flow Rate Measurement Devices				
a. Clean Liquid Radwaste Line	D*	NA	R	Q
b. Aerated Liquid Radwaste Line	D*	NA	R	Q
c. Condensate Polishing Facility Waste Neut Sump Line	D*	NA	R	Q
d. Dilution Water Flow	D(3)	NA	NA	NA
e. Steam Generator Blowdown line	D(3)	NA	NA	NA

D = Daily

M = Monthly

P = Prior to each batch release

R = Once every 18 months

Q = Once every 3 months

NA = Not Applicable

TABLE IV.C-2 (Continued)TABLE NOTATION

- * During releases via this pathway and when the monitor is required OPERABLE per Table IV.C-1. The CHANNEL CHECK should be done when the discharge is in progress.
- (1) Calibration shall include the use of a radioactive liquid or solid source which is traceable to an NIST source.
 - (2) The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exist:
 - a. Instrument indicates measured levels above the alarm/trip setpoint.
 - b. Instrument indicates a downscale or circuit failure.
 - Automatic isolation of the discharge stream shall also be demonstrated for this case for each monitor except the reactor building closed cooling water monitor.
 - (3) Pump or valve status, as appropriate, should be checked daily for the purposes of determining flow rates.

IV.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION (Cont'd)**2. Radioactive Gaseous Effluent Monitoring Instrumentation****LIMITING CONDITIONS OF OPERATIONS**

The radioactive gaseous effluent monitoring instrumentation channels shown in Table IV.C-3 shall be OPERABLE with applicable alarm/trip setpoints set to ensure that the limits of Specifications IV.D.2.a are not exceeded. The setpoints shall be determined in accordance with methods and parameters described in Section II.

Applicability: As shown in Table IV.C-3.

Action:

- a. With a radioactive gaseous effluent monitoring instrumentation channel alarm/trip setpoint less conservative than required by the above specification, without delay suspend the release of radioactive gaseous effluents monitored by the affected channel, or declare the channel inoperable, or change the setpoint so it is acceptably conservative.
- b. With the number of channels less than the minimum channels OPERABLE requirement, take the action shown in Table IV.C-3. Exert best efforts to restore the inoperable monitor to OPERABLE status within 30 days and, if unsuccessful, explain in the next Radioactive Effluent Release Report why the inoperability was not corrected in a timely manner. Release need not be terminated after 30 days provided the specified actions are continued.

SURVEILLANCE REQUIREMENT

Each radioactive gaseous effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION, and CHANNEL FUNCTIONAL TEST operations at the frequencies shown in Table IV.C-4.

TABLE IV.C-3

RADIOACTIVE GASEOUS EFFLUENT INSTRUMENTATION

<u>Instrument</u>	<u>Minimum Channels Operable</u>	<u>Alarm Setpoints Required</u>	<u>Applicability</u>	<u>Action</u>
1. MP2 Vent				
a. Noble Gas Activity Monitor	1	Yes***	**	A
b. Iodine Sampler	1	No	**	B
c. Particulate Sampler	1	No	**	B
d. Vent Flow Rate Monitor	1	No	**	C
e. Sampler Flow Rate Monitor	1	No	**	C
2. Millstone Stack - applicable to the WRGM (RM-8169)				
(a) Noble Gas Activity Monitor	1	Yes***	**	E
(b) Iodine Sampler	1	No	**	B
(c) Particulate Sampler	1	No	**	B
(d) Stack Flow Rate Monitor	1	No	**	C
(e) Sampler Flow Rate Monitor	1	No	**	C
3. Waste Gas Holdup System - Noble Gas Monitor Providing Automatic Termination of Release	1	Yes	*	D

* During waste gas holdup system discharge.

** At all times which means that channels be OPERABLE and in service on a continuous, uninterrupted basis, except that outages are permitted for a maximum of 12 hours for the purpose of maintenance and performance of required tests, checks, calibrations, or sampling.

*** No automatic isolation features.

TABLE IV.C-3 (Continued)

ACTION STATEMENTSAction A

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and that grab samples are taken once per 12 hours and these samples are analyzed for gross activity within 24 hours.

Action B

With the number of samplers OPERABLE less than required by the Minimum number OPERABLE requirement, effluent releases via this pathway may continue provided that the best efforts are made to repair the instrument and that samples are continuously collected with auxiliary sampling equipment for periods of seven (7) days and analyzed for principal gamma emitters with half lives greater than 8 days within 48 hours after the end of the sampling period. Auxiliary sampling must be initiated within 12 hours of initiation of this action statement. Auxiliary sampling outages are permitted for a maximum of 12 hours for the purpose of maintenance and performance of required tests, checks, calibrations, or sampling.

Action C

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and that the flow rate is estimated once per 4 hours.

Action D

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement:

Releases from the Millstone Unit 2 waste gas system may continue provided that best efforts are made to repair the instrument and that prior to initiating the release:

- (a) At least two independent samples of the tank's contents are analyzed; and
- (b) The original release rate calculations and discharge valve lineups are independently verified by a second individual. Otherwise, suspend releases from the waste gas holdup system.

Action E

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, Millstone Unit 2 releases via the Millstone Stack may continue provided that best efforts are made to repair the instrument and that grab samples are taken once per 12 hours and these samples are analyzed for gross activity within 24 hours

Table IV.C-4

RADIOACTIVE GASEOUS EFFLUENT MONITORING
INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>Instrument</u>	<u>Channel Check</u>	<u>Source Check</u>	<u>Channel Calibration</u>	<u>Channel Functional Test</u>
1. MP2 Vent				
a. Noble Gas Activity Monitor	D	M	R(1)	Q(2)
b. Iodine Sampler	W	NA	NA	NA
c. Particulate Sampler	W	NA	NA	NA
d. Vent Flow Rate Monitor	D	NA	R	Q
e. Sampler Flow Rate Monitor	D	NA	R	NA
2. MILLSTONE STACK				
(a) Noble Gas Activity Monitor	D	M	R(1)	Q(2)
(b) Iodine Sampler	W	NA	NA	NA
(c) Particulate Sampler	W	NA	NA	NA
(d) Stack Flow Rate Monitor	D	NA	R	Q(2)
(e) Sampler Flow Rate Monitor	D	NA	R	NA
3. WASTE GAS SYSTEM NOBLE GAS MONITOR	D*	P	R(1)	Q(2)

* During releases via this pathway and when the monitor is required OPERABLE per Table IV.C-3. The CHANNEL CHECK should be performed when the discharge is in progress.

P = Prior to discharge
D = Daily
W = Weekly
M = Monthly

R = Once every 18 months
Q = Once every 3 months
NA = Not Applicable

Table IV.C-4 (Continued)

TABLE NOTATION

- (1) Calibration shall include the use of a known source whose strength is determined by a detector which has been calibrated to a NIST source. These sources shall be in a known, reproducible geometry.
- (2) The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation* occurs if any of the following conditions exist:
 - a. Instrument indicates measured levels above the alarm/trip setpoint.
 - b. Instrument indicates a downscale failure.

* - Also demonstrate automatic isolation for the waste gas system noble gas monitor.

IV.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS**1. Radioactive Liquid Effluents****a. Radioactive Liquid Effluents Concentrations****LIMITING CONDITIONS OF OPERATIONS**

The concentration of radioactive material released from the site (see Figure IV.D-1) shall not exceed the concentrations specified in 10 CFR Part 20, Appendix B, Table II, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall not exceed 2×10^{-4} $\mu\text{Ci/ml}$ total activity.

APPLICABILITY: At all times.

ACTION:

With the concentration of radioactive material released from the site exceeding the above limits, restore the concentration to within the above limits within 15 minutes.

SURVEILLANCE REQUIREMENT

1. Radioactive liquid wastes shall be sampled and analyzed according to the sampling and analysis program specified in Section I.
2. The results of the radioactive analysis shall be used in accordance with the methods of Section II to assure that the concentrations at the point of release are maintained within the limits of Specification IV.D.1.a.

IV.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS (Cont'd)**1. Radioactive Liquid Effluents (Cont'd)****b. Radioactive Liquid Effluents Doses****LIMITING CONDITIONS OF OPERATIONS**

The dose or dose commitment to any REAL MEMBER OF THE PUBLIC from radioactive materials in liquid effluents from Unit 2 released from the site (see Figure IV.D-1) shall be limited:

- a. During any calendar quarter to less than or equal to 1.5 mrem to the total body and to less than or equal to 5 mrem to any organ; and,
- b. During any calendar year to less than or equal to 3 mrem to the total body and to less than or equal to 10 mrem to any organ.

APPLICABILITY: At all times.

ACTION:

- a. With the calculated dose from the release of radioactive materials in liquid effluents exceeding any of the above limits prepare and submit to the Commission within 30 days a Special Report which identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce the releases of radioactive materials in liquid effluents during the remainder of the current calendar quarter and the calendar year so that the cumulative dose or dose commitment to any REAL MEMBER OF THE PUBLIC from such releases during the calendar year is within 3 mrem to the total body and 10 mrem to any organ.

SURVEILANCE REQUIREMENTS

1. Dose Calculations. Cumulative dose contributions from liquid effluents shall be determined in accordance with Section II.
2. Relative accuracy or conservatism of the calculations shall be confirmed by performance of the Radiological Environmental Monitoring Program as detailed in Section I.

IV.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS

2. Radioactive Gaseous Effluents

a. Radioactive Gaseous Effluents Dose Rate

LIMITING CONDITIONS OF OPERATIONS

The dose rate, at any time, offsite (see Figure IV.D-1) due to radioactive materials released in gaseous effluents from the site shall be limited to the following values:

- a. The dose rate limit for noble gases shall be less than or equal to 500 mrem/yr to the total body and less than or equal to 3000 mrem/yr to the skin; and,
- b. The dose rate limit for Iodine-131, Iodine-133, Tritium, and for all radioactive materials in particulate form with half lives greater than 8 days shall be less than or equal to 1500 mrem/yr to any organ.

APPLICABILITY: At all times.

ACTION:

With the dose rate(s) exceeding the above limits, decrease the release rate to comply with the limit(s) given in Specification IV.D.2.a within 15 minutes.

SURVEILLANCE REQUIREMENTS

1. The release rate, at any time, of noble gases in gaseous effluents shall be controlled by the offsite dose rate as established above in Specification IV.D.2.a. The corresponding release rate shall be determined in accordance with the methodology of Section II.
2. The noble gas effluent monitors of Table IV.C-3 shall be used to control release rates to limit offsite doses within the values established in Specification IV.D.2.a.
3. The release rate of radioactive materials in gaseous effluents shall be determined by obtaining representative samples and performing analyses in accordance with the sampling and analysis program specified in Section I. The corresponding dose rate shall be determined using the methodology given in Section II.

IV.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS (Cont'd)**2. Radioactive Gaseous Effluents (Cont'd)****b. Radioactive Gaseous Effluents Noble Gas Dose****LIMITING CONDITIONS OF OPERATIONS**

The air dose offsite (see Figure IV.D-1) due to noble gases released in gaseous effluents from Unit 2 shall be limited to the following:

- a. During any calendar quarter, to less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation;
- b. During any calendar year to less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.

APPLICABILITY: At all times.

ACTION:

- a. With the calculated air dose from radioactive noble gases in gaseous effluents exceeding any of the above limits prepare and submit to the Commission within 30 days a Special Report which identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce the releases of radioactive noble gases in gaseous effluents during the remainder of the current calendar quarter and the calendar year so that the cumulative dose during the calendar year is within 10 mrad for gamma radiation and 20 mrad for beta radiation.

SURVEILLANCE REQUIREMENTS

1. Dose Calculations - Cumulative dose contributions for the current calendar quarter and current calendar year shall be determined in accordance with Section II once every 31 days.
2. Relative accuracy or conservatism of the calculations shall be confirmed by performance of the Radiological Environmental Monitoring Program as detailed in Section I.

IV.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS (Cont'd)**2. Radioactive Gaseous Effluents (Cont'd)****c. Gaseous Effluents - Doses from Radionuclides Other than Noble Gas****LIMITING CONDITIONS OF OPERATIONS**

The dose to any REAL MEMBER OF THE PUBLIC from Iodine-131, Iodine-133, Tritium, and radioactive materials in particulate form with half lives greater than 8 days in gaseous effluents released offsite from Unit 2 (see Figure IV.D-1) shall be limited to the following:

- a. During any calendar quarter to less than or equal to 7.5 mrem to any organ;
- b. During any calendar year to less than or equal to 15 mrem to any organ.

APPLICABILITY: At all times.

ACTION:

- a. With the calculated dose from the release of radioiodines, radioactive materials in particulate form, or radionuclides other than noble gases in gaseous effluents exceeding any of the above limits prepare and submit to the Commission within 30 days a Special Report which identifies the cause(s) for exceeding the limit and defines the corrective actions to be taken to reduce the releases during the remainder of the current calendar quarter and during the remainder of the calendar year so that the cumulative dose or dose commitment to any REAL MEMBER OF THE PUBLIC from such releases during the calendar year is within 15 mrem to any organ.

SURVEILLANCE REQUIREMENTS

1. Dose Calculations - Cumulative dose contributions for the current calendar quarter and current calendar year shall be determined in accordance with Section II once every 31 days.
2. Relative accuracy or conservatism of the calculations shall be confirmed by performance of the Radiological Environmental Monitoring Program as detailed in Section I.

IV.E. TOTAL RADIOLOGICAL DOSE FROM STATION OPERATIONS**LIMITING CONDITIONS OF OPERATIONS**

The annual dose or dose commitment to any REAL MEMBER OF THE PUBLIC from the Millstone Site is limited to less than or equal to 25 mrem to the total body or any organ (except the thyroid, which is limited to less than or equal to 75 mrem).

APPLICABILITY: At all times.

ACTION:

- a. With the calculated dose from the release of radioactive materials in liquid or gaseous effluents exceeding twice the limits of Specifications IV.D.1.b, IV.D.2.b, or IV.D.2.c prepare and submit a Special Report to the Commission within 30 days and limit the subsequent releases such that the dose commitment from the site to any REAL MEMBER OF THE PUBLIC from the Millstone Site is limited to less than or equal to 25 mrem to the total body or any organ (except thyroid, which is limited to less than or equal to 75 mrem) over 12 consecutive months. This Special Report shall include an analysis which demonstrates that radiation exposures from the site to any REAL MEMBER OF THE PUBLIC from the Millstone Site (including all effluent pathways and direct radiation) are less than the 40 CFR Part 190 Standard. If the estimated doses exceed the above limits, the Special Report shall include a request for a variance in accordance with the provisions of 40 CFR Part 190. Submittal of the report is considered a timely request, and a variance is granted until staff action on the request is complete.

SURVEILLANCE REQUIREMENTS

Cumulative dose contributions from liquid and gaseous effluents and direct radiation from the Millstone Site shall be determined in accordance with Section II once per 31 days.

IV.F. BASES

Section IV.C.1 - Radioactive Liquid Effluent Monitoring Instrumentation

The radioactive liquid effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in liquid effluents during actual or potential releases of liquid effluents. The alarm/trip setpoints for these instruments shall be calculated in accordance with the approved methods in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50. Monitoring of the turbine building sumps and condensate polishing facility floor drains is not required due to relatively low concentrations of radioactivity possible.

Section IV.C.2 - Radioactive Gaseous Effluent Monitoring Instrumentation

The radioactive gaseous effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in gaseous effluents during actual or potential releases. The alarm/trip setpoints for these instruments shall be calculated in accordance with the approved methods in the REMODOCM to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. This instrumentation also includes provisions for monitoring (and controlling) the concentrations of potentially explosive gas mixtures in the waste gas holdup system. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50.

Two types of radioactive gaseous effluent monitoring instrumentation, monitors and samplers, are being used at MP2 vent and Millstone Stack. Monitors have alarm/trip setpoints and are demonstrated operable by performing one or more of the following operations: CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION, and CHANNEL FUNCTIONAL TEST. Samplers are strictly collection devices made of canisters and filters. The CHANNEL CHECK surveillance requirements are met through (1) documented observation of the in-service rad monitor sample flow prior to filter replacement; (2) documented replacement of in-line iodine and particulate filters; and (3) documented observation of sample flow following the sampler return to service. The flow indicator is the only indication available for comparison. These observations adequately provide assurance that the sampler is operating and is capable of performing its design function.

There are a number of gaseous release points which could exhibit very low concentrations of radioactivity. For all of these release paths, dose consequences would be insignificant due to the intermittent nature of the release and/or the extremely low concentrations of radioactivity. Since it is not cost-beneficial (nor in many cases practical due to the nature of the release (steam) or the impossibility of detecting such low levels), to monitor these pathways, it has been determined that these release paths require no monitoring or sampling.

Section IV.D.1.a - Radioactive Liquid Effluents Concentrations

This specification is provided to ensure that the concentration of radioactive materials released in liquid waste effluents from the site will be less than the concentration levels specified in 10 CFR Part 20, Appendix B, Table II. This limitation provides additional assurance that the levels of radioactive materials in bodies of water outside the site will result in exposures within: (1) the Section II.A design objectives of Appendix I, 10 CFR Part 50, to an individual and (2) the limits of 10 CFR 20.106(e) to the population. The concentration limit for noble gases is based upon the assumption that Xe-135 is the controlling radioisotope and its MPC in air (submersion) was converted to an equivalent concentration in water using the methods described in International Commission on Radiological Protection (ICRP) Publication 2.

Section IV.D.1.b - Radioactive Liquid Effluents Doses

This specification is provided to implement the requirements of Sections II.A, III.A, and IV.A of Appendix I, 10 CFR Part 50. The specification implements the guides set forth in Section II.A of Appendix I. The Action statements provide the required operating flexibility and at the same time implement the guides set forth in Section III.A of Appendix I to assure that the releases of radioactive material in liquid effluents will be kept "as low as is reasonably achievable". The dose calculations in the ODCM implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I is to be shown by calculational procedures based on models and data such that the actual exposure of an individual through appropriate pathways is unlikely to be substantially underestimated. The equations specified in the ODCM for calculating the doses due to the actual release rates of radioactive materials in liquid effluents are consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I, "Revision 1, October 1977, and Regulatory Guide 1.113, "Estimating Aquatic Dispersion of Effluents from Accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I," April 1977.

Section IV.D.2.a - Radioactive Gaseous Effluents Dose Rate

This specification is provided to ensure that the dose rate at anytime from gaseous effluents from all units on the site will be within the annual dose limits of 10 CFR Part 20 for all areas offsite. The annual dose limits are the doses associated with the concentrations of 10 CFR Part 20, Appendix B, Table II. These limits provide reasonable assurance that radioactive material discharged in gaseous effluents will not result in the exposure of an individual offsite to annual average concentrations exceeding the limits specified in Appendix B, Table II of 10 CFR Part 20 (10 CFR 20.106(b)). For individuals who may, at times, be within the site boundary, the occupancy of that individual will be sufficiently low to compensate for any increase in the atmospheric diffusion factor above that for the site boundary. The specified release rate limits restrict, at all times, the corresponding gamma and beta dose rates above background to an individual at or beyond the site boundary to less than or equal to 500 mrem/year to the total body or to less than or equal to 3000 mrem/year to the skin. These release rate limits also restrict, at all times, the corresponding thyroid or any other organ dose rate above background to a child via the inhalation pathway to less than or equal to 1500 mrem/year.

Section IV.D.2.b - Radioactive Gaseous Effluents Noble Gas Dose

This specification is provided to implement the requirements of Sections II.B., III.A and IV.A of Appendix I, 10 CFR Part 50. The specification implements the guides set forth in Section II.B of Appendix I. The action statements provide the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in gaseous effluents will be kept "as low as is reasonably achievable." The Surveillance Requirements implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of an individual through the appropriate pathways is unlikely to be substantially underestimated. The dose calculations established in the ODCM for calculating the doses due to the actual release rates of radioactive noble gases in gaseous effluents will be consistent with the methodology provided in Regulatory Guide 1.109, "Calculational of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," Revision 1, July 1977.

The ODCM equations provided for determining the air doses at the site boundary were based upon utilizing successively more realistic dose calculational methodologies. More realistic dose calculational methods are used whenever simplified calculations indicate a dose approaching a substantial portion of the regulatory limits. The methods used are, in order, previously determined air dose per released activity ratio, historical meteorological data and actual radionuclide mix released, or real time meteorology and actual radionuclides released.

Section IV.D.2.c - Radioactive Gaseous Effluents Other Than Noble Gas Doses

These specifications is provided to implement the requirements of Sections II.C, III.A and IV.A of Appendix I, 10 CFR Part 50. The specifications are the guides set forth in Section II.C of Appendix I. The action statements provide the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive materials in gaseous effluents will be kept "as low as is reasonably achievable." The ODCM calculational methods specified in the surveillance requirements implement the requirements in Section III.A of Appendix I that conform with the guides for Appendix I be shown by calculational procedures based on models and data such that the actual exposure of an individual through appropriate pathways is unlikely to be substantially underestimated. The ODCM calculational methods for calculating the doses due to the actual release of the subject materials will to be consistent with the methodology provided in Regulatory Guide 1.109, "Calculating of Annual Dose to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision I, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," Revision I, July 1977.

The release rate specifications for radioiodines, radioactive material in particulate form and radionuclides other than noble gases are dependent on the existing radionuclide pathways to man. The pathways which are examined in the development of these calculations are: 1) individual inhalation of airborne radionuclides, 2) deposition of radionuclides onto green leafy vegetation with subsequent consumption by man, (3) deposition onto grassy areas where milk animals and meat producing animals graze with consumption of the milk and meat by man, and 4) deposition on the ground with subsequent exposure of man.

Section IV.E - Total Radiological Dose from Station Operations

This specification is provided to meet the reporting requirements of 40 CFR Part 190. For the purpose of the Special Report, it may be assumed that the dose commitment to any REAL MEMBER OF THE PUBLIC from other fuel cycle sources is negligible, with the exception that dose contributions from other nuclear fuel cycle facilities at the same site or within a radius of 5 miles must be considered.

SECTION V

MILLSTONE UNIT 3

RADIOLOGICAL EFFLUENT

CONTROLS

DOCKET NO. 50-423

Revision 22
October 1, 2001

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND
OFFSITE DOSE CALCULATION MANUAL (REMDCM)**

SECTION V: MILLSTONE UNIT THREE RADIOLOGICAL EFFLUENT CONTROLS

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE NO.</u>
TABLE OF CONTENTS	V-i
V.A. INTRODUCTION	V.A-1
V.B. DEFINITIONS	V.B-1
V.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION	
1. Radioactive Liquid Effluent Monitoring Instrumentation	V.C-1
2. Radioactive Gaseous Effluent Monitoring Instrumentation	V.C-7
V.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS	
1. Radioactive Liquid Effluents	
a. Radioactive Liquid Effluents Concentrations	V.D-1
b. Radioactive Liquid Effluents Doses	V.D-2
2. Radioactive Gaseous Effluents	
a. Radioactive Gaseous Effluents Dose Rate	V.D-3
b. Radioactive Gaseous Effluents Noble Gas Dose	V.D-4
c. Radioactive Gaseous Effluents	V.D-5
- Doses from Radionuclides Other Than Noble Gas	
V.E TOTAL RADIOLOGICAL DOSE FROM STATION OPERATIONS	V.E-1
V.F. BASES	V.F-1

**MILLSTONE STATION
RADIOLOGICAL EFFLUENT MONITORING AND
OFFSITE DOSE CALCULATION MANUAL (REMOTCM)**

SECTION V: MILLSTONE UNIT THREE RADIOLOGICAL EFFLUENT CONTROLS

TABLE OF CONTENTS (Cont'd)

<u>Table Number</u>	<u>Table Name</u>	<u>Page</u>
V.C-1	Radioactive Liquid Effluent Monitoring Instrumentation	V.C-2
V.C-2	Radioactive Liquid Effluent Monitoring Instrumentation Surveillance Requirements	V.C-5
V.C-3	Radioactive Gaseous Effluent Monitoring Instrumentation	V.C-8
V.C-4	Radioactive Gaseous Effluent Monitoring Instrumentation Surveillance Requirements	V.C-10
<u>Figure Number</u>	<u>Figure Name</u>	<u>Page</u>
V.D-1	Site boundary	V.D-6

V.A. INTRODUCTION

The purpose of this section is to provide the following for Millstone Unit Three:

- a. the effluent radiation monitor controls and surveillance requirements,
- b. the effluent radioactivity concentration and dose controls and surveillance requirements, and
- c. the bases for the controls and surveillance requirements.

Definitions of certain terms are provided as an aid for implementation of the controls and requirements.

Some surveillance requirements refer to specific sub-sections in Sections I and II as part of their required actions.

V.B DEFINITIONS

The defined terms of this sub-section appear in capitalized type and are applicable throughout Section V.

B.1 ACTION

ACTION shall be that part of the control which prescribes remedial measures required under designated conditions.

B.2 ANALOG CHANNEL OPERATIONAL TEST

AN ANALOG CHANNEL OPERATIONAL TEST shall be the injection of a simulated signal into the channel as close to the sensor as practicable to verify OPERABILITY of alarm, interlock and/or trip functions. The ANALOG CHANNEL OPERATIONAL TEST shall include adjustments, as necessary, of the alarm, interlock and/or trip setpoints such that the setpoints are within the required range and accuracy.

B.3 CHANNEL CALIBRATION

A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel such that it responds within the required range and accuracy to known values of input. The CHANNEL CALIBRATION shall encompass the entire channel including the sensors and alarm, interlock and/or trip functions and may be performed by any series of sequential, overlapping, or total channel steps such that the entire channel is calibrated.

B.4 CHANNEL CHECK

A CHANNEL CHECK shall be the qualitative assessment of channel behavior during operation by observation. This determination shall include, where possible, comparison of the channel indication and/or status with other indications and/or status derived from independent instrument channels measuring the same parameter.

B.5 DOSE EQUIVALENT I-131

DOSE EQUIVALENT I-131 shall be that concentration of I-131 (microCurie/gram) which alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factors used for this calculation shall be those listed in Regulatory Guide 1.109 Rev. 1, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluent for the Purpose of Evaluating Compliance with 10 CFR Part 50 Appendix I.

B.6 MEMBER(S) OF THE PUBLIC

MEMBER(S) OF THE PUBLIC shall include all persons who are not occupationally associated with the plant. This category does not include employees of the licensee, its contractors or its vendors. Also excluded from this category are persons who enter the site to service equipment or to make deliveries. This category does include persons who use portions of the site for recreational, occupational, or other purposes not associated with the plant.

The term "REAL MEMBER OF THE PUBLIC" means an individual who is exposed to existing dose pathways at one particular location.

B.7 MODE

Refers to Mode of Operation as defined in Safety Technical Specifications.

B.8 OPERABLE - OPERABILITY

An instrument shall be OPERABLE or have OPERABILITY when it is capable of performing its specified function(s) and when all necessary attendant instrumentation, controls, electrical power, or other auxiliary equipment that are required for the instrument to perform its function(s) are also capable of performing their related support function(s).

B.9 SITE BOUNDARY

The SITE BOUNDARY shall be that line beyond which the land is neither owned, nor leased, nor otherwise controlled by the licensee.

B.10 SOURCE CHECK

A SOURCE CHECK shall be the qualitative assessment of channel response when the channel sensor is exposed to radiation.

B.11 UNRESTRICTED AREA

An UNRESTRICTED AREA shall be any area at or beyond the SITE BOUNDARY to which access is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials, or any area within the SITE BOUNDARY used for residential quarters or for industrial, commercial, institutional, and/or recreational purposes.

V.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION**1. Radioactive Liquid Effluent Monitoring Instrumentation****LIMITING CONDITIONS OF OPERATION**

The radioactive liquid effluent monitoring instrumentation channels shown in Table V.C-1 shall be OPERABLE with their Alarm/Trip setpoints set to ensure that the limits of Specification V.D.1.a are not exceeded. The alarm/trip setpoints shall be determined in accordance with methodology and parameters as described in Section II.

APPLICABILITY

As shown in Table V.C-1

ACTION:

- a. With a radioactive liquid effluent monitoring instrumentation channel Alarm/Trip setpoint less conservative than required by the above specification, without delay suspend the release of radioactive liquid effluents monitored by the affected channel, or declare the channel inoperable, or change the setpoint so it is acceptably conservative.
- b. With less than the minimum number of radioactive liquid effluent monitoring instrumentation channels OPERABLE, take the action shown in Table V.C-1. Exert best efforts to restore the inoperable instrumentation to OPERABLE status within 30 days and, if unsuccessful, explain in the next Radioactive Effluent Release Report why the inoperability was not corrected in a timely manner. Releases need not be terminated after 30 days provided the specified actions are continued.

SURVEILLANCE REQUIREMENTS

Each radioactive liquid effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION, and ANALOG CHANNEL OPERATIONAL TEST at the frequencies shown in Table V.C-2.

TABLE V.C-1

RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

<u>Instrument</u>	<u>Minimum OPERABLE</u>	<u>Applicability</u>	<u>Action</u>
1. Radioactivity Monitors Providing Alarm and Automatic Termination Of Release			
a. Waste Neutralization Sump Monitor - Condensate Polishing Facility	1	##	D
b. Turbine Building Floor Drains	1	#	B***
c. Liquid Waste Monitor	1	#	A
d. Regenerate Evaporator Monitor - Condensate Polishing Facility	1*	##	B
e. Steam Generator Blowdown Monitor	1	##	B
2. Flow Rate Measurement Devices - No Alarm Setpoint Requirements			
a. Waste Neutralization Sump Effluents	1	#	C
b. Turbine Building Floor Drains	**	#	NA
c. Liquid Waste Effluent Line	1	#	C
d. Regenerate Evaporator Effluent Line	1*	#	C
e. Steam Generator Blowdown Effluent Line	1	#	C
f. Dilution Water Flow	**	#	NA

* NA if the Condensate Polishing Facility Regenerate Evaporator is not in service.

** Flow will be determined by pump status.

*** NA if the Turbine Building sump is less than MDA.

At all times - which means that channels shall be OPERABLE and in service on a continuous, uninterrupted basis, except that outages are permitted, for a maximum of 12 hours, for the purpose of maintenance and performance of required test, checks, calibrations, or sampling.

MODEs 1-5, and MODE 6 when pathway is being used, except that outages are permitted, for a maximum of 12 hours, for the purpose of maintenance and performance of required test, checks, calibrations, or sampling. The monitor must be on-line with no unexpected alarms. When the affected discharge path is isolated in MODE 6, the applicable LCO and Surveillance Requirements are not applicable.

TABLE V.C-1 (Continued)

ACTION STATEMENTSAction A

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirements, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and that prior to initiating a release:

1. At least two independent samples are analyzed in accordance with the first Surveillance Requirement of Specification V.D.1.a and;
2. The original release rate calculations and discharge line valving are independently verified by a second individual.

Action B

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided best efforts are made to repair the instrument and that grab samples are analyzed for gross radioactivity (beta or gamma) at a lower limit of detection of no more than 3×10^{-7} microCurie/ml:

1. At least once per 12 hours when the specific activity of the secondary coolant is greater than 0.01 microCurie/gram DOSE EQUIVALENT I-131, or
2. At least once per 24 hours when the specific activity of the secondary coolant is less than or equal to 0.01 microCurie/gram DOSE EQUIVALENT I-131.

Action C

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and that the flow rate is estimated at least once per 4 hours during actual releases. Pump performance curves may be used to estimate flow.

Action D

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirements, effluent releases may continue provided that best efforts are made to repair the instrument and that prior to initiating a release:

1. At least two independent samples are analyzed in accordance with the first Surveillance Requirement of Specification IV.D.1.a, and;
2. If one of the samples has gross gamma greater than 5×10^{-7} , the original release rate calculations and discharge valving are independently verified by a second individual.

TABLE V.C-2

RADIOACTIVE LIQUID EFFLUENT MONITORING

INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>Instrument</u>	<u>Channel Check</u>	<u>Source Check</u>	<u>Channel Calibration</u>	<u>Analog Channel Operational Test</u>
1. Radioactivity Monitors Providing Alarm And Automatic Termination Of Release				
a. Waste Neutralization Sump Monitor Condensate Polishing Facility	D	P	R(2)	Q(1)
b. Turbine Building Floor Drains	D	M	R(2)	Q(1)
c. Liquid Waste Monitor	D	P	R(2)	Q(1)
d. Regenerate Evaporator Monitor Condensate Polishing Facility (5)	D	M	R(2)	Q(1)
e. Steam Generator Blowdown Monitor	D	M	R(2)	Q(1)
2. Flow Rate Measurement Devices				
a. Waste Neutralization Sump Effluents	D(3)	NA	R	Q
b. Turbine Building Floor Drains	D(4)	NA	NA	NA
c. Liquid Waste Effluent Line	D(3)	NA	R	Q
d. Regenerate Evaporator Effluent Line (5)	D(3)	NA	R	Q
e. Steam Generator Blowdown Effluent Line	D(3)	NA	R	Q
f. Dilution Water Flow	D(4)	NA	NA	NA

D = Daily
M = Monthly
P = Prior to each batch release
R = Once every 18 months
Q = Once every 3 months
NA = Not Applicable

TABLE V.C-2 (Continued)TABLE NOTATION

- (1) The ANALOG CHANNEL OPERATIONAL TEST shall also demonstrate that automatic isolation of this pathway and control room alarm annunciation occur if any of the following conditions exists:
 - a. Instrument indicates measured levels above the alarm/trip setpoint, or
 - b. Circuit failure (Alarm only), or
 - c. Instrument indicates a downscale failure (Alarm only).
- (2) The initial CHANNEL CALIBRATION shall be performed using one or more of the reference standards certified by the National Institute of Standards and Technology (NIST) or using standards that have been obtained from suppliers that participate in measurement assurance activities of NIST. These standards shall permit calibrating the system over its intended range of energy and measurement range. For subsequent CHANNEL CALIBRATION, sources that have been related to the initial calibration shall be used.
- (3) CHANNEL CHECK shall consist of verifying indication of flow during periods of release. CHANNEL CHECK shall be made at least once per 24 hours on days on which continuous, periodic, or batch releases are made.
- (4) Pump status shall be checked daily for the purposes of determining flowrate.
- (5) Surveillance is required only if the monitor is required to be OPERABLE by Table V.C-1.

V.C. RADIOACTIVE EFFLUENT MONITORING INSTRUMENTATION (Cont'd)**2. Radioactive Gaseous Effluent Monitoring Instrumentation****LIMITING CONDITIONS OF OPERATION**

The radioactive gaseous effluent monitoring instrumentation channels shown in Table V.C-3 shall be OPERABLE with their Alarm/Trip Setpoints set to ensure that the limits of Specification V.D.2.a are not exceeded. The Alarm/Trip Setpoints of these channels shall be determined in accordance with the methodology and parameters in Section II.

Applicability: As shown in Table V.C-3.

Action:

- a. With a radioactive gaseous effluent monitoring instrumentation channel Alarm/Trip Setpoint less conservative than required by the above specification, without delay suspend the release of radioactive gaseous effluents monitored by the affected channel, or declare the channel inoperable, or change the setpoint so it is acceptably conservative.
- b. With the number of OPERABLE radioactive gaseous effluent monitoring instrumentation channels less than the Minimum Channels OPERABLE, take the ACTION shown in Table V.C-3. Exert best efforts to restore the inoperable instrumentation to OPERABLE status within 30 days and, if unsuccessful, explain in the next Radioactive Effluent Release Report why the inoperability was not corrected in a timely manner. Release need not be terminated after 30 days provided the specified actions are continued.

SURVEILLANCE REQUIREMENT

Each radioactive gaseous effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION, and ANALOG CHANNEL OPERATIONAL TEST at the frequencies shown in Table V.C-4.

TABLE V.C-3

RADIOACTIVE GASEOUS EFFLUENT INSTRUMENTATION

<u>Instrument</u>	<u>Minimum Channels Operable</u>	<u>Applicability</u>	<u>Action</u>
1. Millstone Unit 3 Ventilation Vent (Turbine Building - HVR-RE10B)			
a. Noble Gas Activity Monitor - Providing Alarm	1	*A	
b. Iodine Sampler	1	*	B
c. Particulate Sampler	1	*	B
d. Vent Flow Rate Monitor	1	*	C
e. Sampler Flow Rate Monitor	1	*	C
2. Millstone Stack - applicable to SLCRS (HVR-RE19B)			
a. Noble Gas Activity Monitor - Providing Alarm	1	*	D
b. Iodine Sampler	1	*	B
c. Particulate Sampler	1	*	B
d. Process Flow Rate Monitor	1	*	C
e. Sampler Flow Rate Monitor	1	*	C
3. Engineered Safeguards Building Monitor (HVQ-RE49)			
a. Noble Gas Activity Monitor - Providing Alarm	1	*	A
b. Iodine Sampler	1	*	B
c. Particulate Sampler	1	*	B
d. Discharge Flow Rate Monitor	1	*	C
e. Sampler Flow Rate Monitor	1	*	C
4. Warehouse No. 5 Vent			
a. Noble Gas Monitor	1 ⁽¹⁾	**	A
b. Iodine Sampler	1 ⁽¹⁾	**	A
c. Particulate Sampler	1 ⁽¹⁾	**	A

Table Notations

* At all times - which means that channels shall be OPERABLE and in service on a continuous, uninterrupted basis except that outages are permitted for a maximum of 12 hours for the purpose of maintenance and performance of required tests, checks, calibrations, or sampling.

** When the gross activity of the regenerated waste is greater than 1×10^{-4} microCuries/ml.

(1) This minimum channel requirement may be met with a portable continuous air monitor (Eberline PING-3 or equivalent).

TABLE V.C-3 (Continued)

ACTION STATEMENTSAction A

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and that grab samples are taken at least once per 12 hours and these samples are analyzed for radioactivity within 24 hours.

Action B

With the number of samplers OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that the best efforts are made to repair the instrument and that samples are continuously collected with auxiliary sampling equipment for periods of seven (7) days and analyzed for principal gamma emitters with half lives greater than 8 days within 48 hours after the end of the sampling period. Auxiliary sampling must be initiated within 12 hours after initiation of this ACTION statement. Auxiliary sampling outages are permitted for a maximum of 12 hours for the purpose of maintenance and performance of required tests, checks, calibrations, or sampling.

Action C

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that best efforts are made to repair the instrument and that the flow rate is estimated at least once per 4 hours.

Action D

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, Millstone Unit 3 releases via the Millstone Stack may continue provided that best efforts are made to repair the instrument and that grab samples are taken at least once per 12 hours and analyzed for gross radioactivity within 24 hours.

Table V.C-4

RADIOACTIVE GASEOUS EFFLUENT MONITORING
INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>Instrument</u>	<u>Check</u>	<u>Source Check</u>	<u>Channel Calibration</u>	<u>Analog Channel Operational Test</u>	<u>When Surveillance is Required</u>
1. Millstone Unit 3 Ventilation Vent (Turbine Building - HVR-RE10B)					
a. Noble Gas Activity Monitor	D	M	R(1)	Q(2)	*
b. Iodine Sampler	W	NA	NA	NA	*
c. Particulate Sampler	W	NA	NA	NA	*
d. Vent Flow Rate Monitor	D	NA	R	Q	*
e. Sampler Flow Rate Monitor	D	NA	R	Q	*
2. Millstone Stack (HVR-19B)					
a. Noble Gas Activity Monitor	D	M	R(3)	Q(2)	*
b. Iodine Sampler	W	NA	NA	NA	*
c. Particulate Sampler	W	NA	NA	NA	*
d. Process Flow Rate Monitor	D	NA	R	Q	*
e. Sampler Flow Rate Monitor	D	NA	R	Q	*
3. Engineered Safeguards Building Monitor (HVQ-RE49)					
a. Noble Gas Activity Monitor	D	M	R(1)	Q(2)	*
b. Iodine Sampler	W	NA	NA	NA	*
c. Particulate Sampler	W	NA	NA	NA	*
d. Discharge Flow Rate Monitor	D	NA	R	Q	*
e. Sampler Flow Rate Monitor	D	NA	R	Q	*
4. Warehouse No. 5 Vent					
a. Noble Gas Monitor	D	NA	R(3)	NA	**
b. Iodine Sampler	D	NA	R(3)	NA	**
c. Particulate Sampler	D	NA	R(3)	NA	**

* At all times except when the vent path is isolated.

** When the gross activity of the regenerated waste is greater than 1×10^{-4} microCuries/ml.

D = Daily
W = Weekly
M = Monthly

R = Once every 18 months
Q = Once every 3 months
NA = Not Applicable

Table V.C-4 (Continued)

TABLE NOTATION

- (1) The initial CHANNEL CALIBRATION shall be performed using one or more of the reference standards certified by the National Institute of Standards and Technology (NIST) or using standards that have been obtained from suppliers that participate in measurement assurance activities of NIST. These standards shall permit calibrating the system over its intended range of energy and measurement range. For subsequent CHANNEL CALIBRATION, sources that have been related to the initial calibration shall be used.

- (2) The ANALOG CHANNEL OPERATIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exist:
 - a. Instrument indicates measured levels above the Alarm Setpoint, or
 - b. Circuit failure, or
 - c. Instrument indicates a downscale failure.

- (3) The CHANNEL CALIBRATION shall include the use of a known source whose strength is determined by a detector which has been calibrated to an NIST source. These sources shall be in know, reproducible geometry.

V.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS**1. Radioactive Liquid Effluents****a. Radioactive Liquid Effluents Concentrations****LIMITING CONDITIONS OF OPERATION**

The concentration of radioactive material released from the site (see Figure V.D-1) shall be limited to the concentrations specified in 10 CFR Part 20, Appendix B, Table II, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall not exceed 2×10^{-4} $\mu\text{Ci/ml}$ total activity.

APPLICABILITY: At all times.

ACTION:

With the concentration of radioactive material released from the site exceeding the above limits, restore the concentration to within the above limits within 15 minutes.

SURVEILLANCE REQUIREMENT

1. Radioactive liquid wastes shall be sampled and analyzed according to the sampling and analysis program specified in Section I.
2. The results of the radioactive analysis shall be used in accordance with the methods of Section II to assure that the concentrations at the point of release are maintained within the limits of Specification V.D.1.a.

V.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS (Cont'd)**1. Radioactive Liquid Effluents (Cont'd)****b. Radioactive Liquid Effluents Doses****LIMITING CONDITIONS OF OPERATION**

The dose or dose commitment to any REAL MEMBER OF THE PUBLIC from radioactive materials in liquid effluents from Unit 3 released from the site (see Figure V.D-1) shall be limited:

- a. During any calendar quarter to less than or equal to 1.5 mrem to the total body and to less than or equal to 5 mrem to any organ; and,
- b. During any calendar year to less than or equal to 3 mrem to the total body and to less than or equal to 10 mrem to any organ.

APPLICABILITY: At all times.

ACTION:

- a. With the calculated dose from the release of radioactive materials in liquid effluents exceeding any of the above limits prepare and submit to the Commission within 30 days a Special Report which identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce the releases of radioactive materials in liquid effluents during the remainder of the current calendar quarter and the remainder of the calendar year so that the cumulative dose or dose commitment to any REAL MEMBER OF THE PUBLIC from such releases during the calendar year is within 3 mrem to the whole body and 10 mrem to any organ.

SURVEILANCE REQUIREMENTS

1. **Dose Calculations.** Cumulative dose contributions from liquid effluents shall be determined in accordance with Section II.
2. Relative accuracy or conservatism of the calculations shall be confirmed by performance of the Radiological Environmental Monitoring Program as detailed in Section I.

V.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS**2. Radioactive Gaseous Effluents****a. Radioactive Gaseous Effluents Dose Rate****LIMITING CONDITIONS OF OPERATION**

The dose rate, at any time, offsite (see Figure V.D-1) due to radioactive materials released in gaseous effluents from the site shall be limited to the following values:

- a. The dose rate limit for noble gases shall be less than or equal to 500 mrem/yr to the total body and less than or equal to 3000 mrem/yr to the skin; and,
- b. The dose rate limit due to inhalation for Iodine-131, Iodine-133, Tritium, and for all radioactive materials in particulate form with half lives greater than 8 days shall be less than or equal to 1500 mrem/yr to any organ.

APPLICABILITY: At all times.

ACTION:

With the dose rate(s) exceeding the above limits, decrease the release rate to comply with the limit(s) given in Specification V.D.2.a within 15 minutes.

SURVEILLANCE REQUIREMENTS

1. The release rate, at any time, of noble gases in gaseous effluents shall be controlled by the offsite dose rate as established in Specification V.D.2.a. The corresponding release rate shall be determined in accordance with the methodology of Section II.
2. The noble gas effluent monitors of Table V.C-3 shall be used to control release rates to limit offsite doses within the values established in Specification V.D.2.a.
3. The release rate of radioactive materials in gaseous effluents shall be determined by obtaining representative samples and performing analyses in accordance with the sampling and analysis program, specified in Section I. The corresponding dose rate shall be determined using the methodology given in Section II.

V.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS (Cont'd)**2. Radioactive Gaseous Effluents (Cont'd)****b. Radioactive Gaseous Effluents Noble Gas Dose****LIMITING CONDITIONS OF OPERATION**

The air dose offsite (see Figure V.D-1) due to noble gases released from Unit 3 in gaseous effluents shall be limited to the following:

- a. During any calendar quarter: Less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation, and
- b. During any calendar year: Less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.

APPLICABILITY: At all times.

ACTION:

- a. With the calculated air dose from radioactive noble gases in gaseous effluents exceeding any of the above limits prepare and submit to the Commission within 30 days a Special Report which identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce the releases of radioactive noble gases in gaseous effluents during the remainder of the current calendar quarter and during the remainder of the calendar year so that the cumulative dose during the calendar year is within 10 mrad for gamma radiation and 20 mrad for beta radiation.

SURVEILLANCE REQUIREMENTS

1. **Dose Calculations** - Cumulative dose contributions for the current calendar quarter and current calendar year shall be determined in accordance with Section II once every 31 days.
2. Relative accuracy or conservatism of the calculations shall be confirmed by performance of the Radiological Environmental Monitoring Program as detailed in Section I.

V.D. RADIOACTIVE EFFLUENTS CONCENTRATIONS AND DOSE LIMITATIONS (Cont'd)**2. Radioactive Gaseous Effluents (Cont'd)****c. Gaseous Effluents - Doses from Radionuclides Other than Noble Gas****LIMITING CONDITIONS OF OPERATION**

The dose to any REAL MEMBER OF THE PUBLIC from Iodine-131, Iodine-133, Tritium, and radioactive materials in particulate form with half lives greater than 8 days in gaseous effluents released offsite from Unit 3 released offsite (see Figure V.D-1) shall be limited to the following:

- a. During any calendar quarter: Less than or equal to 7.5 mrem to any organ and,
- b. During any calendar year: Less than or equal to 15 mrem to any organ.

APPLICABILITY: At all times.

ACTION:

- a. With the calculated dose from the release of radioiodines, radioactive materials in particulate form, or radionuclides other than noble gases in gaseous effluents exceeding any of the above limits prepare and submit to the Commission within 30 days a Special Report which identifies the cause(s) for exceeding the limit and defines the corrective actions to be taken to reduce the releases during the remainder of the current calendar quarter and during the remainder of the calendar year so that the cumulative dose or dose commitment to any REAL MEMBER OF THE PUBLIC from such releases during the calendar year is within 15 mrem to any organ.

SURVEILLANCE REQUIREMENTS

1. **Dose Calculations** - Cumulative dose contributions for the current calendar quarter and current calendar year shall be determined in accordance with Section II once every 31 days.
2. Relative accuracy or conservatism of the calculations shall be confirmed by performance of the Radiological Environmental Monitoring Program as detailed in Section I.




Figure V.D-1
Site Boundary for Liquid and Gaseous Effluents

V.E. TOTAL RADIOLOGICAL DOSE FROM STATION OPERATIONS**LIMITING CONDITIONS OF OPERATION**

The annual dose or dose commitment to any REAL MEMBER OF THE PUBLIC from the Millstone Site shall be limited to less than or equal to 25 mrem to the whole body or any organ (except the thyroid, which shall be limited to less than or equal to 75 mrem).

APPLICABILITY: At all times.

ACTION:

- a. With the calculated dose from the release of radioactive materials in liquid or gaseous effluents exceeding twice the limits of Specifications V.D.1.b, V.D.2.b, or V.D.2.c prepare and submit a Special Report to the Commission within 30 days and limit the subsequent releases such that the dose commitment from the site to any REAL MEMBER OF THE PUBLIC from the Millstone Site is limited to less than or equal to 25 mrem to the total body or any organ (except thyroid, which is limited to less than or equal to 75 mrem) over 12 consecutive months. This Special Report shall include an analysis which demonstrates that radiation exposures from the site to any REAL MEMBER OF THE PUBLIC from the Millstone Site (including all effluent pathways and direct radiation) are less than the 40 CFR Part 190 Standard. If the estimated dose(s) exceeds the above limits, the Special Report shall include a request for a variance in accordance with the provisions of 40 CFR Part 190. Submittal of the report is considered a timely request, and a variance is granted until staff action on the request is complete.

SURVEILLANCE REQUIREMENTS

Cumulative dose contributions from liquid and gaseous effluents and direct radiation from the Millstone Site shall be determined in accordance with Section II once per 31 days.

V.F. BASES**Section V.C.1 - Radioactive Liquid Effluent Monitoring Instrumentation**

The radioactive liquid effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in liquid effluents during actual or potential releases of liquid effluents. The Alarm/Trip Setpoints for these instruments shall be calculated and adjusted in accordance with the methodology and parameters in Section II to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50.

OPERABILITY of a radiation monitor is determined by its ability to perform its specified function. The specified function of the radioactivity monitors listed in Table V.C-1 is to provide Control Room alarm annunciation and automatic termination of release. The monitor must be on-line with no unexpected alarms in order to perform its specified function.

Definition B.7 states a component is OPERABLE when it is capable of performing its specified function. The monitors are described in Tables V.C-1 and V.C-2 as "Radioactivity Monitors Providing Alarm and Automatic Termination of Releases." Table V.C-2 Note 1 requires that the Analog Channel Operational Test (ACOT) demonstrate that automatic isolation and "control room annunciation" occur. Control room annunciation cannot occur unless the monitor is on line (i.e. in communication with the RMS computer.). Section V.C.1 Surveillance Requirement requires that the ACOT be performed to demonstrate OPERABILITY. General Design Criteria 64 states in part: "Means shall be provided for monitoring effluent discharge paths for radioactivity." Regulatory Guide 1.21 Appendix A describes a monitor program that is acceptable to the Regulatory staff. Under Section B of Appendix A, "LIQUID EFFLUENTS", the first paragraph states in part: "During the release of radioactive wastes, the effluent control monitor should be set to alarm and to initiate automatic closure..."

Certain of the monitors listed in Table V.C-1 are designed to operate without sample pumps. These monitors utilize pressure in the effluent line during discharge to provide sample flow and sample pressure. Low sample flow and/or low sample pressure alarms may be received when no discharge is in progress. These are expected alarms. Sample flow and/or sample pressure will return to normal when the discharge is initiated. These alarms will clear when discharge begins. The monitors are OPERABLE since they are able to perform their specified function with the expected alarms in.

Table V.C-1 note ## requires entry into the radioactive liquid effluent monitoring action statements whenever the radiation monitors are not available in the required MODE. This note applies to items 1.a (3CND-RE07, Waste Neutralization Sump), 1.d (3LWC-RE65, Regenerate Evaporator Monitor), and 1.e (3SSR-RE08, Steam Generator Blowdown Monitor) in Table V.C-1. The original issue of this requirement (as a Technical Specification) in January 1986 stated the applicability was "At all times." Technical Specification Amendment 22 added "APPLICABILITY" to Table V.C-1 (then Tech Spec Table 3.3-12). The applicability added in Amendment 22 is the present wording. The letter 1312821, dated February 24, 1988, in the following sections discusses the change request and are quoted below:

- In "Discussion": "The proposed changes will now explicitly allow a monitor to be taken out of service for up to 12 hours for maintenance/testing without entering the ACTION statement."

- In "Significant Hazards Consideration" item 1: "the proposed changes would only allow these radiation monitors to be out of service for a short period of time (12 hours)."
- In "Significant Hazards Consideration" item 2: "The proposed changes also have no effect on alarm setpoints or control functions. Further, no operator actions that are required to mitigate any accident rely solely on these monitors, and these monitors provide no protective functions."

Technical Specification Amendment 22 provided for the following:

- allowance for planned inoperability of monitoring instrumentation for up to 12 hours for the purpose of maintenance and performance of required test, check, calibration or sampling
- a requirement to initiate auxiliary sampling within 12 hours after inoperability of certain gaseous effluent monitors
- allowance for inoperability of certain effluent monitoring instrumentation, during MODE 6 (refueling) when the effluent pathway is not being used.

Section V.C.2 - Radioactive Gaseous Effluent Monitoring Instrumentation

The radioactive gaseous effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in gaseous effluents during actual or potential releases of gaseous effluents. The Alarm/Trip Setpoints for these instruments shall be calculated and adjusted in accordance with the methodology and parameters in Section II to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50. The sensitivity of any noble gas activity monitors used to show compliance with the gaseous effluent release requirements of Specification V.C.2.a shall be such that concentrations as low as 1×10^{-6} uCi/cc are measurable.

The vent normal range radiation monitor, HVR*10B, satisfies the requirements of Section V.C.2 for Unit 3 releases to the vent which is located on the turbine building. There are no requirements in the REMODOCM associated with the vent high range radiation monitor, HVR*10A.

The SLCRS normal range radiation monitor, HVR*19B, satisfies the requirements of Section V.C.2 for Unit 3 releases to the Millstone Stack. There are no requirements in the REMODOCM associated with the SLCRS high range radiation monitor, HVR*19A.

Section V.D.1.a - Radioactive Liquid Effluents Concentrations

This specification is provided to ensure that the concentration of radioactive materials released in liquid waste effluents from the site will be less than the concentration levels specified in 10 CFR Part 20, Appendix B, Table II. This limitation provides additional assurance that the levels of radioactive materials in bodies of water outside the site will result in exposures within: (1) the Section II.A design objectives of Appendix I, 10 CFR Part 50, to an individual and (2) the limits of 10 CFR 20.106(e) to the population. The concentration limit for noble gases is based upon the assumption that Xe-135 is the controlling radioisotope and its MPC in air (submersion) was converted to an equivalent concentration in water using the methods described in International Commission on Radiological Protection (ICRP) Publication 2.

Section V.D.1.b - Radioactive Liquid Effluents Doses

This specification is provided to implement the requirements of Sections II.A, III.A, and IV.A of Appendix I, 10 CFR Part 50. The specification implements the guides set forth in Section

II.A of Appendix I. The ACTION statements provide the required operating flexibility and at the same time implement the guides set forth in Section III.A of Appendix I to assure that the releases of radioactive material in liquid effluents will be kept "as low as is reasonably achievable." The dose calculation methodology and parameters in Section II implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I is to be shown by calculational procedures based on models and data such that the actual exposure of an individual through appropriate pathways is unlikely to be substantially underestimated. The equations specified in Section II for calculating the doses due to the actual release rates of radioactive materials in liquid effluents will be consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I, "Revision 1, October 1977, and Regulatory Guide 1.113, "Estimating Aquatic Dispersion of Effluents from Accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I," April 1977.

Section V.D.2.a - Radioactive Gaseous Effluents Dose Rate

This specification is provided to ensure that the dose rate at any time from gaseous effluents from all units on the site will be within the annual dose limits of 10 CFR Part 20 for all areas offsite. The annual dose limits are the doses associated with the concentrations of 10 CFR Part 20, Appendix B, Table II. These limits provide reasonable assurance that radioactive material discharged in gaseous effluents will not result in the exposure of an individual offsite to annual average concentrations exceeding the limits specified in Appendix B, Table II of 10 CFR Part 20 (10 CFR 20.106(b)). For individuals who may, at times, be within the SITE BOUNDARY, the occupancy of that individual will be usually be sufficiently low to compensate for any increase in the atmospheric diffusion factor above that for the SITE BOUNDARY. The specified release rate limits restrict, at all times, the corresponding gamma and beta dose rates above background to an individual at or beyond the SITE BOUNDARY to less than or equal to 500 mrem/year to the whole body or to less than or equal to 3000 mrem/year to the skin. These release rate limits also restrict, at all times, the corresponding thyroid or any other organ dose rate above background to a child via the inhalation pathway to less than or equal to 1500 mrem/year.

Section V.D.2.b - Radioactive Gaseous Effluents Noble Gas Dose

This specification is provided to implement the requirements of Sections II.B., III.A and IV.A of Appendix I, 10 CFR Part 50. The specification implements the guides set forth in Section II.B of Appendix I. The ACTION statements provide the required operating flexibility and at the same time implement the guides set forth in Section V.A of Appendix I to assure that the releases of radioactive material in gaseous effluents will be kept "as low as is reasonably achievable." The Surveillance Requirements implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of an individual through the appropriate pathways is unlikely to be substantially underestimated. The dose calculations established in Section II for calculating the doses due to the actual release rates of radioactive noble gases in gaseous effluents will be consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," Revision 1, July 1977.

The Section II equations provided for determining the air doses at the site boundary are based upon utilizing successively more realistic dose calculational methodologies. More

realistic dose calculational methods are used whenever simplified calculations indicate a dose approaching a substantial portion of the regulatory limits. The methods used are, in order, previously determined air dose per released activity ratio, historical meteorological data and actual radionuclide mix released, or real time meteorology and actual radionuclides released.

Section V.D.2.c - Radioactive Gaseous Effluents for Radionuclides Other Than Noble Gas
These specifications are provided to implement the requirements of Sections II.C, III.A and IV.A of Appendix I, 10 CFR Part 50. The specifications are the guides set forth in Section II.C of Appendix I. The ACTION statements provide the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive materials in gaseous effluents will be kept "as low as is reasonably achievable." The Section II calculational methods specified in the surveillance requirements implement the requirements in Section III.A of Appendix I that conformance with the guides for Appendix I be shown by calculational procedures based on models and data such that the actual exposure of an individual through appropriate pathways is unlikely to be substantially underestimated. The Section II calculational methodology and parameters for calculating the doses due to the actual release rates of the subject materials are consistent with the methodology provided in Regulatory Guide 1.109, "Calculating of Annual Dose to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision I, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors," Revision I, July 1977. The release rate specifications for radioiodines, radioactive material in particulate form and radionuclides other than noble gases are dependent on the existing radionuclide pathways to man. The pathways that are examined in the development of these calculations are: 1) individual inhalation of airborne radionuclides, 2) deposition of radionuclides onto green leafy vegetation with subsequent consumption by man, (3) deposition onto grassy areas where milk animals and meat producing animals graze with consumption of the milk and meat by man, and 4) deposition on the ground with subsequent exposure of man.

Section V.E - Total Radiological Dose from Station Operations

This specification is provided to meet the dose limitations of 40 CFR Part 190. For the purpose of the Special Report, it may be assumed that the dose commitment to any REAL MEMBER OF THE PUBLIC from other fuel cycle sources is negligible, with the exception that dose contributions from other nuclear fuel cycle facilities at the same site or within a radius of 5 miles must be considered.