



Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609-2000

April 30, 2003

10 CFR 50.36a(a)(2)
10 CFR 50, Appendix I,
Section IV.B.1

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Stop: OWFN, P1-35
Washington, D.C. 20555-0001

Gentlemen:

In the Matter of)	Docket Nos. 50-259
Tennessee Valley Authority)	50-260
		50-296

BROWNS FERRY NUCLEAR PLANT (BFN) - UNITS 1, 2, AND 3 -
ANNUAL RADIOACTIVE EFFLUENT RELEASE (ARER) REPORT -
JANUARY THROUGH DECEMBER 2002

In accordance with 10 CFR 50.36a(a)(2); 10 CFR 50, Appendix I, Section IV.B; and the BFN Technical Specification (TS) 5.6.3, TVA is submitting the BFN ARER report for January through December 2002. Also, in accordance with the BFN Offsite Dose Calculation Manual (ODCM) Section 1.1.1, Action (b), and Section 1.1.2, Action (c), TVA is providing the BFN's Inoperable Radioactive Effluent Instrumentation Report. However, TVA is not submitting any revision of the ODCM since no ODCM changes were made during this reporting period.

This report includes the following:

Radiological Impact Assessment Report (Enclosure 1)

Meteorological Data Tables (Enclosure 2)

IE48
A009

U.S. Nuclear Regulatory Commission
Page 2


April 30, 2003

Effluent and Waste Disposal Annual Report
(Enclosure 3)

Inoperable Radiological Effluent Instrumentation
Report (Enclosure 4)

If you have any questions concerning this submittal,
please contact me at (256) 729-2636.

Sincerely,


T. E. Abney
Manager of Site Licensing
and Industry Affairs

Enclosures
cc (w/o Enclosures).
(via NRC Electronic Distribution)
Mr. Stephen J. Cahill, Branch Chief
U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street S.W., Suite 23T85
Atlanta, Georgia 30303-8931

NRC Resident Inspector
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, Alabama 35611-6970

Mr. Kahtan N. Jabbour, Senior Project Manager
U.S. Nuclear Regulatory Commission
(MS 08G9)
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

Mr. Ronald Sanacore (w/Enclosures)
American Nuclear Insurers
Town Center, Suite 300S
29 South Main Street
West Hartford, Connecticut 06107-2445

ENCLOSURE 1

**TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT (BFN)
UNITS 1, 2, AND 3**

**RADIOLOGICAL IMPACT ASSESSMENT REPORT
JANUARY THROUGH DECEMBER 2002**

TABLE OF CONTENTS

I.	Introduction	E1-2
II.	Dose Limits	E1-2
III.	Dose Calculations	E1-3
IV.	Doses from Airborne Effluents	E1-3
V.	Doses from Liquid Effluents	E1-5
VI.	Population Doses	E1-5
VII.	Offsite Direct Radiation Dose	E1-6
VIII.	Dose to a Member of the Public Inside the Site Boundary	E1-6
IX.	Total Dose	E1-7

TABLE OF CONTENTS (Continued)

Listing of Tables

Table 1 - Doses from Airborne Effluents - First Quarter	E1-8
Table 2 - Doses from Airborne Effluents - Second Quarter	E1-9
Table 3 - Doses from Airborne Effluents - Third Quarter	E1-10
Table 4 - Doses from Airborne Effluents - Fourth Quarter	E1-11
Table 5 - Doses from Liquid Effluents - First Quarter	E1-12
Table 6 - Doses from Liquid Effluents - Second Quarter	E1-13
Table 7 - Doses from Liquid Effluents - Third Quarter	E1-14
Table 8 - Doses from Liquid Effluents - Fourth Quarter	E1-15
Table 9 - Total Dose from Fuel Cycle	E1-16
Table 10 - Joint Frequency Distribution in Percent for Ground Level Releases - First Quarter	E2-2- E2-9
Table 11 - Joint Frequency Distribution in Percent for Ground Level Releases - Second Quarter	E2-10- E2-17
Table 12 - Joint Frequency Distribution in Percent for Ground Level Releases - Third Quarter	E2-18- E2-25
Table 13 - Joint Frequency Distribution in Percent for Ground Level Releases - Fourth Quarter	E2-26- E2-33
Table 14 - Joint Frequency Distribution in Percent for Split Level Releases (Ground Level Portion) - First Quarter	E2-34- E2-41
Table 15 - Joint Frequency Distribution in Percent for Split Level Releases (Ground Level Portion) - Second Quarter	E2-42- E2-49
Table 16 - Joint Frequency Distribution in Percent for Split Level Releases (Ground Level Portion) - Third Quarter	E2-50- E2-57
Table 17 - Joint Frequency Distribution in Percent for Split Level Releases (Ground Level Portion) - Fourth Quarter	E2-58- E2-65
Table 18 - Joint Frequency Distribution in Percent for Split Level Releases (Elevated Level Portion) - First Quarter	E2-66- E2-73

TABLE OF CONTENTS (Continued)

Listing of Tables

Table 19 - Joint Frequency Distribution in Percent for Split Level Releases (Elevated Level Portion) - Second Quarter	E2-74- E2-81
Table 20 - Joint Frequency Distribution in Percent for Split Level Releases (Elevated Level Portion) - Third Quarter	E2-82- E2-89
Table 21 - Joint Frequency Distribution in Percent for Split Level Releases (Elevated Level Portion) - Fourth Quarter	E2-90- E2-97
Table 22 - Joint Frequency Distribution in Percent for Elevated Releases - First Quarter	E2-98- E2-105
Table 23 - Joint Frequency Distribution in Percent for Elevated Releases - Second Quarter	E2-106- E2-113
Table 24 - Joint Frequency Distribution in Percent for Elevated Releases - Third Quarter	E2-114- E2-121
Table 25 - Joint Frequency Distribution in Percent for Elevated Releases - Fourth Quarter	E2-122- E2-129

**Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002**

I. INTRODUCTION

Potential doses to the "maximum exposed individual" and the population around Browns Ferry are calculated for each quarter as required in Section 5.2 of the Offsite Dose Calculation Manual (ODCM). The methodology for determining plant releases for the reporting period used to estimate dose is specified in Sections 6 and 7 of the ODCM. Dispersion of radioactive effluents in the environment is estimated using meteorological data and river flow measured during the period. In this report, the doses resulting from releases are described and compared to limits established for Browns Ferry.

II. DOSE LIMITS

The ODCM specifies limits for the release of radioactive effluents, as well as limits for doses to the general public from the release of radioactive effluents. These limits are set well below the Technical Specification limits which govern the concentrations of radioactivity and doses permissible in unrestricted areas. This ensures that radioactive effluent releases are As Low As Reasonably Achievable.

The air dose limits in areas at and beyond the Site Boundary due to noble gases released in gaseous effluents per unit are:

$\leq 5 \text{ mrad per quarter and}$
 $\leq 10 \text{ mrad per year for gamma radiation}$
- and -
 $\leq 10 \text{ mrad per quarter and}$
 $\leq 20 \text{ mrad per year for beta radiation.}$

The dose limits to a Member of the Public in an unrestricted area from radioiodines, radioactive materials in particulate form, and radionuclides other than noble gases with half-lives > 8 days released in gaseous effluents for each unit are:

$\leq 7.5 \text{ mrem per quarter and}$
 $\leq 15 \text{ mrem per year to any organ.}$

The dose or dose commitment to a Member of the Public from radioactive material in liquid effluents released to unrestricted areas are:

$\leq 1.5 \text{ mrem per quarter and}$
 $\leq 3 \text{ mrem per year to the total body,}$
- and -
 $\leq 5 \text{ mrem per quarter and}$
 $\leq 10 \text{ mrem per year to any organ.}$

The limit for the total effective dose equivalent to an individual Member of the Public inside the site boundary is:

100 mrem per year.

The EPA limits for total dose to any Member of the Public in the vicinity of a nuclear power plant, established in the Environmental Dose Standard of 40 CFR 190, are:

$\leq 25 \text{ mrem per year to the whole body,}$
 $\leq 75 \text{ mrem per year to the thyroid,}$
- and -
 $\leq 25 \text{ mrem per year to any other organ.}$

**Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002**

III. DOSE CALCULATIONS

Estimated doses to Members of the Public are determined using computer models (the Gaseous Effluent Licensing Code, GELC, and the Quarterly Water Dose Assessment Code, QWATA). These models are based on guidance provided by the NRC (in Regulatory Guides 1.109, 1.111 and 1.113) for determining the potential dose to individuals and populations living in the vicinity of the plant. The area around the plant is analyzed to determine the pathways through which the public may receive a dose. The doses calculated are a representation of the dose to a "maximum exposed individual." Some of the factors used in these calculations (such as ingestion rates) are maximum values to ensure conservative reporting data. Many of these factors are obtained from NUREG/CR-1004. The values chosen will tend to overestimate the dose. The expected dose to actual individuals is lower. The calculated doses are presented in Tables 1, 2, 3, 4, 5, 6, 7, 8, and 9.

IV. DOSES FROM AIRBORNE EFFLUENTS

For airborne effluents, Members of the Public can be exposed to radiation from several sources: direct radiation from the radioactivity in the air, direct radiation from radioactivity deposited on the ground, inhalation of airborne radioactivity, ingestion of vegetation which contains radioactivity deposited from the atmosphere, and ingestion of milk and beef which contains radioactivity deposited from the atmosphere onto vegetation and subsequently consumed by milk and beef animals.

Airborne Release Points

There are four monitored release points from Browns Ferry Nuclear Plant: the turbine building, the radwaste building, the reactor building, and the stack.

Releases from the turbine building are considered ground-level releases. The ground-level Joint Frequency Distribution (JFD) is derived from windspeeds and directions measured 10 meters above ground and from the vertical temperature difference between 10 and 45 meters, and are presented for each quarter in Tables 10, 11, 12, and 13.

Releases from the radwaste and reactor buildings are considered split-level releases. Portions of the release are treated as ground-level while other portions are considered elevated depending on the ratio of the vertical exit velocity to the horizontal wind speed. The split-level dispersion approach is implemented using a model that requires two complete quarterly JFDs for each effluent vent, one for the ground-level releases and one for the elevated releases. The ground-level portion of the split-level JFD is based on wind speeds and directions measured 10 meters above ground-level and from the vertical temperature difference between 10 and 45 meters. The elevated portion of the split-level JFD is based on wind speeds and direction measurements at the 45 meter level and the vertical temperature difference between 45 and 91 meters. Both of these JFDs are given for each quarter in Tables 14, 15, 16, 17, 18, 19, 20, and 21.

Releases from the stack are considered to be elevated releases. The JFDs for elevated releases are based on wind directions and wind speeds measured at 91 meters and the vertical temperature difference between 45 and 91 meters, and are given for each quarter in Tables 22, 23, 24, and 25.

Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002

Meteorological Data

Meteorological variables at BFN are measured continuously. Measurements collected include wind speed, wind direction, and temperature at heights of 10, 45, and 91 meters above the ground. Quarterly JFDs are calculated for each release point using the appropriate levels of meteorological data. A quarterly JFD gives the percentage of the time that the wind is blowing out of a particular upwind compass sector in a particular range of wind speeds for a given stability class A through G. The wind speeds are divided into nine wind speed ranges. Calms are distributed by direction in proportion to the distribution of noncalm wind directions less than 1.6 m/s (3.5 mph). Stability classes are determined from the vertical temperature difference between two measurement levels.

The generally open terrain around BFN does not cause any significant effects on the transport and dispersion of gaseous effluents from the plant. Within 30 kilometers of BFN, the terrain is mostly gently rolling hills (30-60 meters). Between 30 and 80 kilometers the hills become larger to the north and south, and mountainous to the east and northeast. The Tennessee River/Wheeler Lake may have a minor effect on transport and dispersion in the immediate vicinity of BFN during periods of winds with a southerly component, overcast skies, and relatively high wind speeds. Also, the lower layer (10-45 meters) stability class tends to be more stable. However, during this infrequent condition, dose estimates will be conservative.

External Exposure Dose

Dose calculated for maximum external air dose (gamma-air and beta-air) are made for points at and beyond the unrestricted area boundary as described in the BFN ODCM. The highest of these doses is then selected.

Submersion Dose

External doses to the skin and total body, due to submersion in a cloud of noble gases, are calculated for the nearest residence in each sector. The residence with the highest dose is then selected from all sectors.

Organ Dose

Dose to an organ due to releases of airborne effluents are estimated for the inhalation, ground contamination, and ingestion pathways. The ingestion pathway is further divided into three possible contributing pathways: ingestion of cow/goat milk, ingestion of beef, and ingestion of vegetables. Doses from applicable pathways are calculated for each receptor location identified in the most recent land use survey. To determine the maximum organ dose, the doses from the pathways are summed for each receptor. For the ingestion dose, however, only those pathways that exist for each receptor are considered in the sum, i.e., milk ingestion doses are included only for locations where milk was consumed without commercial preparation and vegetable ingestion is included only for those locations where a garden was identified. To conservatively account for beef ingestion, a beef ingestion dose equal to that for the highest unrestricted area boundary location is added to each identified receptor. For ground contamination, the dose added to the organ dose being calculated is the total body dose calculated for that location, i.e., it is assumed that the dose to an individual organ is equal to the total body dose.

The maximum organ dose, thyroid dose, and total body dose from airborne effluents are presented in Tables 1, 2, 3, and 4.

**Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002**

V. DOSES FROM LIQUID EFFLUENTS

For liquid effluents, the public can be exposed to radiation from three sources: the ingestion of water from the Tennessee River, the ingestion of fish caught in the Tennessee River, and direct exposure from radioactive material deposited on the river shoreline sediment (recreation)

The concentration of radionuclides in the Tennessee River are calculated by a computer model which uses measured hydraulic data downstream of BFN. Parameters used to determine the doses are based on guidance given by the NRC (in Regulatory Guides 1.109) for maximum ingestion rates, exposure times, etc. Wherever possible, parameters used in the dose calculation are site specific. The models that are used to estimate doses, as well as the parameters input to the models, are described in detail in the BFN ODCM.

Liquid Release Points and River Data

Radionuclide concentrations in the Tennessee River are calculated assuming that releases in liquid effluents are continuous. When necessary, liquid releases from BFN, located at Tennessee River Mile 294, are made through diffusers which extend into the Tennessee River. It is assumed that releases to the river through these diffusers will initially be entrained in one-fifth of the water which flows past the plant. The QWATA code makes the assumption that this mixing condition holds true until the water is completely mixed at the first downstream dam (Wheeler Dam), at Tennessee River Mile 283.0.

Doses are calculated for locations within a 50 mile radius downstream of the plant site. The maximum potential recreation dose is calculated for a location immediately downstream from the plant's release point. The maximum exposed individual dose from ingestion of fish is assumed to be that calculated for the consumption of fish caught anywhere between the plant and the first downstream dam. The maximum exposed individual dose from drinking water is assumed to be that calculated at the nearest downstream public water supply [West Morgan - East Lawrence (WMEL)]. This could be interpreted as indicating that the maximum exposed individual, as assumed for liquid releases from Browns Ferry, is an individual who obtains all of his drinking water at WMEL, consumes fish caught from the Tennessee River between BFN and Wheeler Dam, and spends 500 hours per year on the shoreline just downstream of the plant's release point. Doses calculated for the maximum exposed individual due to liquid effluents for each quarter in the period are presented in Tables 5, 6, 7, and 8, along with the average river flows past the plant site for the periods.

VI. POPULATION DOSES

Population doses due to airborne effluents are calculated for an estimated 627,000 persons living within a 50-mile radius of the plant site. Doses from external pathways and inhalation are based on the 50-mile human population distribution. Ingestion population doses are calculated assuming that each individual consumed milk, vegetables, and meat produced within the sector in which the individual resides.

Population doses due to liquid effluents are calculated for the entire downstream Tennessee River population. Water ingestion population doses are calculated using actual population figures for downstream public water supplies. Fish ingestion population doses are calculated assuming that all sport fish caught in the Tennessee River are consumed by the Tennessee River population. Recreation population doses are calculated using historical recreational data on the number of shoreline visits at downstream locations.

Population doses calculated for airborne and liquid effluents are presented in Tables 1, 2, 3, 4, 5, 6, 7, and 8.

**Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002**

VII. OFFSITE DIRECT RADIATION DOSE

External gamma radiation levels were measured by thermoluminescent dosimeters (TLDs) deployed around BFN as part of the offsite Radiological Environmental Monitoring Program (REMP). The quarterly gamma radiation levels determined from these TLDs during this reporting period averaged approximately 16.0 mrem/quarter at onsite (at or near the site boundary) stations and approximately 14.3 mrem/quarter at offsite stations or approximately 1.7 mrem/quarter higher onsite than at offsite stations. This difference is consistent with levels measured for pre-operation and construction phases of TVA nuclear plants where the average radiation levels onsite were generally 2-6 mrem/quarter higher than the levels offsite. This may be attributable to natural variations in environmental radiation levels, earth moving activities onsite, the mass of concrete employed in the construction of the plants, or other undetermined influences. Fluctuations in natural background dose rates and in TLD readings tend to mask any small increments which may be due to plant operations. Thus, there was no identifiable increase in dose rate levels attributable to direct radiation from plant equipment and/or gaseous effluents.

VIII. DOSE TO A MEMBER OF THE PUBLIC INSIDE THE SITE BOUNDARY

Pursuant to ODCM section 7.7.5, a review was performed to determine the highest dose to a member of the public in the site boundary. This review assumed that onsite TVA employees engaged in work activities not associated with nuclear power electric generation were considered as members of the public. The dose to a member of the public consists of the sum of dose commitments from effluent releases as well as any direct radiation dose. The effluent dose commitment is negligible compared to the direct radiation dose.

The direct radiation dose was determined from area TLDs located onsite. It consisted of gamma dose from the plume, ground contamination and from equipment sources (i.e., tanks, turbine shine, radioactive material storage areas, etc.). The highest direct radiation dose accounting for background and occupancy was 5.0 mrem during 2002.

The total annual dose commitment to the member of the public for 2002 is 5.0 mrem; the direct radiation dose while in the site boundary. It can be concluded that the dose limit for a member of the public inside the site boundary as specified in 10 CFR 20.1301 was not exceeded.

**Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002**

IX. TOTAL DOSE

To determine compliance with 40 CFR 190, annual total dose contributions to the maximum exposed individual from BFN radioactive effluents and all other nearby uranium fuel cycle sources are considered

The annual dose to any organ other than thyroid for the maximum exposed individual is conservatively calculated by summing the following doses: the total body air submersion dose for each quarter, the critical organ dose (for any organ other than the thyroid) from airborne effluents for each quarter from ground contamination, inhalation and ingestion, the total body dose from liquid effluents for each quarter, the maximum organ dose (for any organ other than the thyroid) from liquid effluents for each quarter, and any identifiable increase in direct radiation dose levels as measured by the REMP. This dose is compared to the 40 CFR 190 limit for total body or any organ dose (other than thyroid) to determine compliance.

The annual thyroid dose to the maximum exposed individual is conservatively estimated by summing the following doses: the total body air submersion dose for each quarter, the thyroid dose from airborne effluents for each quarter, the total body dose from liquid effluents for each quarter, the thyroid dose from liquid effluents for each quarter, and any identifiable increase in direct radiation dose levels as measured by the REMP. This dose is compared to the 40 CFR 190 limit for thyroid dose to determine compliance.

Total dose from the fuel cycle is presented in Table 9.

Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002

Table 1
Doses from Airborne Effluents
First Quarter

Individual Doses

Pathway	Dose	Quarterly Limit	Percent of Limit	Location
External				
Gamma Air	5.8E-06 mrad	5 mrad	< 1 %	S/6800 meters
Beta Air	9.3E-06 mrad	10 mrad	< 1 %	S/6800 meters
Submersion				
Total Body	2.7E-04 mrem	NA	NA	N/2000 meters
Skin	3.2E-04 mrem	NA	NA	N/2000 meters
Organ Doses				
Child/Bone	1.4E-02 mrem	7.5 mrem	< 1 %	NNW/1770 meters
Child/Thyroid	4.1E-02 mrem	7.5 mrem	< 1 %	NNW/1770 meters
Child/Total Body	1.2E-02 mrem	7.5 mrem	< 1 %	NNW/1770 meters

Population Doses

Total Body Dose 1.9E-02 man-rem

Maximum Organ Dose (organ) 8.1E-02 man-rem (thyroid)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).

Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002

Table 2
Doses from Airborne Effluents
Second Quarter

Individual Doses

Pathway	Dose	Quarterly Limit	Percent of Limit	Location
External				
Gamma Air	1.1E-05 mrad	5 mrad	< 1 %	NNW/5500 meters
Beta Air	3.0E-05 mrad	10 mrad	< 1 %	NNW/5500 meters
Submersion				
Total Body	9.4E-04 mrem	NA	NA	NNW/1639 meters
Skin	1.1E-03 mrem	NA	NA	NNW/1639 meters
Organ Doses				
Child/Liver	8.3E-03 mrem	7.5 mrem	< 1 %	NNW/1770 meters
Child/Thyroid	2.4E-01 mrem	7.5 mrem	3 %	NNW/1770 meters
Child /Total Body	4.6E-03 mrem	7.5 mrem	< 1 %	NNW/1770 meters

Population Doses

Total Body Dose 1.3E-02 man-rem

Maximum Organ Dose (organ) 7.7E-01 man-rem (thyroid)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).

Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002

Table 3
Doses from Airborne Effluents
Third Quarter

Individual Doses

Pathway	Dose	Quarterly Limit	Percent of Limit	Location
External				
Gamma Air	9.1E-04 mrad	5 mrad	< 1 %	NNW/5600 meters
Beta Air	1.2E-03 mrad	10 mrad	< 1 %	NNW/5600 meters
Submersion				
Total Body	1.6E-03 mrem	NA	NA	NNW/1639 meters
Skin	1.9E-03 mrem	NA	NA	NNW/1639 meters
Organ Doses				
Child/Bone	1.6E-02 mrem	7.5 mrem	< 1 %	NNW/1770 meters
Child/Thyroid	1.9E-02 mrem	7.5 mrem	< 1 %	NNW/1770 meters
Adult/Total Body	6.1E-03 mrem	7.5 mrem	< 1 %	NNW/1770 meters

Population Doses

Total Body Dose 3.2E-02 man-rem

Maximum Organ Dose (organ) 7.9E-02 man-rem (thyroid)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).

Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002

Table 4
Doses from Airborne Effluents
Fourth Quarter

Individual Doses

Pathway	Dose	Quarterly Limit	Percent of Limit	Location
External				
Gamma Air	5.3E-04 mrad	5 mrad	<1 %	SSE/7800 meters
Beta Air	5.7E-04 mrad	10 mrad	<1 %	SSE/7800 meters
Submersion				
Total Body	2.8E-03 mrem	NA	NA	NNW/1639 meters
Skin	3.3E-03 mrem	NA	NA	NNW/1639 meters
Organ Doses				
Child/ Bone	4.4E-02 mrem	7.5 mrem	<1 %	NNW/1770 meters
Child/Thyroid	6.5E-01 mrem	7.5 mrem	<1 %	NNW/1770 meters
Child /Total Body	2.1E-02 mrem	7.5 mrem	<1 %	NNW/1770 meters

Population Doses

Total Body Dose 8.2E-02 man-rem

Maximum Organ Dose (organ) 2.1E+00 man-rem (thyroid)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).

Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002

Table 5
Doses from Liquid Effluents
First Quarter*

Individual Doses (mrem)

Age Group	Organ	Dose Pathway	Dose	Quarterly Limit	Percent of Limit
	Total Body	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	1.5 mrem	0 %
	Liver	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	5 mrem	0 %
	Thyroid	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	5 mrem	0 %

*No liquid releases were made this quarter.

Average Riverflow past BFN (cubic feet per second): No Release

Population Doses

Total Body Dose 0 man-rem

Maximum Organ Dose (organ) 0 man-rem (organ)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002**

**Table 6
Doses from Liquid Effluents
Second Quarter***

Individual Doses (mrem)

Age Group	Organ	Dose Pathway	Dose	Quarterly Limit	Percent of Limit
	Total Body	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	1.5 mrem	0 %
	Liver	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	5 mrem	0 %
	Thyroid	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	5 mrem	0 %

*No liquid releases were made this quarter.

Average Riverflow past BFN (cubic feet per second): No Release

Population Doses

Total Body Dose 0 man-rem

Maximum Organ Dose (organ) 0 man-rem (organ)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002**

**Table 7
Doses from Liquid Effluents
Third Quarter**

Individual Doses (mrem)

Age Group	Organ	Dose Pathway	Dose	Quarterly Limit	Percent of Limit
	Total Body	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	1.5 mrem	0 %
	Liver	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	5 mrem	0 %
	Thyroid	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	5 mrem	0 %

*No liquid releases were made this quarter.

Average Riverflow past BFN (cubic feet per second): No Release

Population Doses

Total Body Dose 0 man-rem

Maximum Organ Dose (organ) 0 man-rem (organ)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).

**Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002**

**Table 8
Doses from Liquid Effluents
Fourth Quarter**

Individual Doses (mrem)

Age Group	Organ	Dose Pathway	Dose	Quarterly Limit	Percent of Limit
	Total Body	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	1.5 mrem	0 %
	Liver	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	5 mrem	0 %
	Thyroid	Fish Ingestion	0		
		Recreation	0		
		Water Ingestion	0		
		Total	0	5 mrem	0 %

*No liquid releases were made this quarter.

Average Riverflow past BFN (cubic feet per second): No Release

Population Doses

Total Body Dose 0 man-rem

Maximum Organ Dose (organ) 0 man-rem (organ)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 70,044 man-rem/year (based on 90 mrem/yr for natural background).

Radiological Impact Assessment
Browns Ferry Nuclear Plant
January - December 2002

Table 9
Total Dose from Fuel Cycle

Dose	First Quarter	Second Quarter	Third Quarter	Fourth Quarter	
Total Body or any Organ (except thyroid)					
Total body air submersion	2.7E-04	9.4E-04	1.6E-03	2.8E-03	
Critical organ dose (air)	1.4E-02	8.3E-03	1.6E-02	4.4E-02	
Total body dose (liquid)	0	0	0	0	
Maximum organ dose (liquid)	0	0	0	0	
Direct Radiation Dose	0	0	0	0	
Total	1.4E-02	9.2E-03	1.8E-02	4.7E-02	
Cumulative Total Dose (mrem) (Total body or any other organ)					8.8E-02
Annual Dose Limit (mrem)					2.5E+01
Percent of Limit					< 1 %
Thyroid Dose (mrem)					
Total body air submersion	2.7E-04	9.4E-04	1.6E-03	2.8E-03	
Thyroid dose (airborne)	4.1E-02	3.4E-01	1.9E-02	6.5E-01	
Total body dose (liquid)	0	0	0	0	
Thyroid dose (liquid)	0	0	0	0	
Direct Radiation Dose	0	0	0	0	
Total	4.1E-02	3.7E-01	2.1E-02	6.5E-01	
Cumulative Total Dose (Thyroid) mrem					9.6E-01
Annual Dose Limit (mrem)					7.5E+01
Percent of Limit					1.3 %

ENCLOSURE 2

**TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT (BFN)
UNITS 1, 2, AND 3**

**METEOROLIGICAL DATA TABLES
JANUARY THROUGH DECEMBER 2002**

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 10

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR GROUND LEVEL RELEASES
FIRST QUARTER

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)			12.5-18.4	>=24.5	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4			
N	0.000	0.000	0.000	0.000	0.236	0.142	0.000
NNE	0.000	0.000	0.000	0.095	0.331	0.095	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.095	0.000	0.095
SE	0.000	0.000	0.047	1.040	0.473	0.000	0.000
SSE	0.000	0.000	0.095	0.615	0.047	0.000	0.000
S	0.000	0.000	0.047	0.709	0.378	0.000	0.000
SSW	0.000	0.000	0.189	0.567	0.095	0.000	0.000
SW	0.000	0.000	0.047	0.000	0.047	0.000	0.000
WSW	0.000	0.000	0.047	0.047	0.000	0.000	0.000
W	0.000	0.000	0.000	0.095	0.142	0.047	0.000
WNW	0.000	0.000	0.000	0.047	0.095	0.615	0.284
NW	0.000	0.000	0.000	0.000	0.047	0.804	0.189
NNW	0.000	0.000	0.000	0.189	0.757	0.615	0.000
SUBTOTAL	0.000	0.000	0.473	3.215	1.844	3.262	1.371
					0.000	0.000	0.000
							10.165

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2125
215
215
215
0

TOTAL HOURS OF STABILITY CLASS A

2125
215
215
215
0

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A

2125
215
215
215
0

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2125
215
215
215
0

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 7.66

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.047	0.142	0.000	0.000	0.189
NNE	0.000	0.000	0.000	0.000	0.426	0.095	0.000	0.000	0.520
NE	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.047
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
ESE	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.047
SE	0.000	0.000	0.047	0.236	0.047	0.000	0.000	0.000	0.331
SSE	0.000	0.000	0.189	0.142	0.000	0.000	0.000	0.000	0.331
S	0.000	0.000	0.142	0.047	0.047	0.047	0.000	0.000	0.284
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.047
WSW	0.000	0.000	0.047	0.047	0.047	0.000	0.000	0.000	0.142
W	0.000	0.000	0.000	0.142	0.000	0.047	0.047	0.000	0.236
WNW	0.000	0.000	0.000	0.047	0.142	0.189	0.331	0.000	0.709
NW	0.000	0.000	0.000	0.047	0.000	0.236	0.189	0.000	0.473
NNW	0.000	0.000	0.000	0.000	0.000	0.189	0.000	0.000	0.189
SUBTOTAL	0.000	0.000	0.473	0.757	0.804	0.993	0.567	0.000	3.593

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2125
 TOTAL HOURS OF STABILITY CLASS B 76
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B 76
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2115
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 7.89

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.142	0.000	0.000	0.142
NNE	0.000	0.000	0.000	0.000	0.331	0.095	0.000	0.000	0.426
NE	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.047
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SE	0.000	0.000	0.047	0.284	0.047	0.000	0.000	0.000	0.378
SSE	0.000	0.000	0.095	0.095	0.047	0.000	0.000	0.000	0.236
S	0.000	0.000	0.095	0.189	0.000	0.000	0.000	0.000	0.284
SSW	0.000	0.000	0.000	0.095	0.000	0.047	0.000	0.000	0.142
SW	0.000	0.000	0.095	0.000	0.000	0.000	0.000	0.000	0.095
WSW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.047
W	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.142
WNW	0.000	0.000	0.000	0.095	0.000	0.142	0.236	0.095	0.567
NW	0.000	0.000	0.000	0.047	0.000	0.236	0.189	0.000	0.473
NNW	0.000	0.000	0.000	0.047	0.000	0.331	0.095	0.000	0.473
SUBTOTAL	0.000	0.000	0.331	0.851	0.757	0.946	0.520	0.095	3.499

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
 TOTAL HOURS OF STABILITY CLASS C
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM

2125
 74
 74
 2115
 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 8.02

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.142	0.426	0.662	2.364	0.047	0.047	0.000
NNE	0.000	0.000	0.331	0.709	1.040	0.757	0.000	0.000	0.000
NE	0.000	0.000	0.236	0.520	0.757	0.378	0.000	0.000	1.891
ENE	0.000	0.047	0.331	0.520	0.189	0.000	0.000	0.000	1.087
E	0.000	0.000	0.284	0.236	0.142	0.047	0.000	0.000	0.709
ESE	0.000	0.095	0.189	0.236	0.142	0.142	0.000	0.000	0.804
SE	0.000	0.000	0.520	0.709	0.189	0.284	0.000	0.000	1.702
SSE	0.000	0.000	0.615	0.567	0.047	0.000	0.000	0.000	1.229
S	0.000	0.000	0.378	0.189	0.473	0.142	0.000	0.000	1.182
SSW	0.000	0.000	0.331	0.331	0.000	0.047	0.000	0.000	0.709
SW	0.000	0.000	0.142	0.142	0.000	0.047	0.000	0.000	0.331
WSW	0.000	0.000	0.236	0.095	0.142	0.142	0.000	0.000	0.615
W	0.000	0.000	0.142	0.284	0.520	0.662	0.047	0.000	1.655
NNW	0.000	0.000	0.095	0.142	0.236	0.804	1.229	0.142	0.000
NW	0.000	0.000	0.095	0.236	0.473	2.270	1.986	0.142	5.201
NNW	0.000	0.000	0.378	0.709	2.128	0.473	0.047	0.000	3.830
SUBTOTAL	0.000	0.142	4.161	5.721	5.721	10.213	3.783	0.378	0.000
									30.118

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2125
641
637
2115
0TOTAL HOURS OF STABILITY CLASS D
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALMMETEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 7.73

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.426	0.567	0.426	0.331	0.000	0.000	1.749
NNE	0.000	0.000	0.284	0.331	0.426	0.142	0.000	0.000	1.182
NE	0.000	0.000	0.142	0.615	0.236	0.047	0.000	0.000	1.040
ENE	0.000	0.000	0.142	0.095	0.142	0.000	0.000	0.000	0.378
E	0.000	0.000	0.473	0.095	0.047	0.000	0.000	0.000	0.615
ESE	0.000	0.000	0.993	0.284	0.142	0.000	0.000	0.000	1.418
SE	0.000	0.000	1.087	0.615	0.236	0.047	0.000	0.000	1.986
SSE	0.000	0.095	0.898	1.466	0.095	0.189	0.000	0.000	2.742
S	0.000	0.095	0.851	2.175	1.182	0.709	0.000	0.000	5.012
SSW	0.000	0.047	0.662	0.709	0.189	0.142	0.000	0.000	1.749
SW	0.000	0.047	0.426	0.047	0.047	0.047	0.000	0.000	0.615
WSW	0.000	0.000	0.520	0.095	0.000	0.047	0.000	0.000	0.662
W	0.000	0.047	0.520	0.426	0.473	0.000	0.000	0.000	1.466
WNW	0.000	0.000	0.000	0.000	0.236	0.236	0.000	0.000	0.473
NW	0.000	0.047	0.284	0.426	0.378	0.520	0.047	0.000	1.702
NNW	0.000	0.047	0.189	0.757	0.520	0.331	0.047	0.000	1.891
SUBTOTAL	0.000	0.426	7.896	8.700	4.775	2.790	0.095	0.000	24.681

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2125
525
522
2115
0TOTAL HOURS OF STABILITY CLASS E
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALMMETEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 4.65

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA T <= 4.0 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)						>=24.5	TOTAL
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.004	0.047	0.615	0.567	0.000	0.000	0.000	0.000	0.000
NNE	0.001	0.000	0.236	0.378	0.095	0.000	0.000	0.000	0.711
NE	0.001	0.000	0.236	0.142	0.047	0.000	0.000	0.000	0.427
ENE	0.003	0.000	0.520	0.095	0.047	0.000	0.000	0.000	0.665
E	0.003	0.047	0.473	0.567	0.000	0.000	0.000	0.000	1.090
ESE	0.002	0.047	0.378	0.047	0.000	0.000	0.000	0.000	0.475
SE	0.010	0.095	1.702	0.567	0.047	0.000	0.000	0.000	2.422
SSE	0.010	0.142	1.513	0.378	0.236	0.047	0.000	0.000	2.326
S	0.004	0.189	0.473	1.135	0.898	0.993	0.000	0.000	3.692
SSW	0.002	0.142	0.236	0.331	0.236	0.047	0.000	0.000	0.995
SW	0.001	0.095	0.095	0.095	0.000	0.000	0.000	0.000	0.285
WSW	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.048
W	0.001	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.095
WNW	0.001	0.000	0.095	0.047	0.000	0.000	0.000	0.000	0.142
NW	0.001	0.000	0.142	0.095	0.095	0.000	0.000	0.000	0.332
NNW	0.003	0.142	0.331	0.898	0.095	0.000	0.000	0.000	1.468
SUBTOTAL	0.047	1.087	7.045	5.343	1.797	1.087	0.000	0.000	16.407

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
 TOTAL HOURS OF STABILITY CLASS F
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM 1

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 3.78

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.236	0.426	0.378	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.095	0.189	0.142	0.000	0.000	0.000	0.000	0.426
NE	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.047
ENE	0.000	0.000	0.284	0.000	0.000	0.000	0.000	0.000	0.284
E	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.047
ESE	0.000	0.095	0.047	0.047	0.000	0.000	0.000	0.000	0.189
SE	0.000	0.047	0.898	0.047	0.047	0.000	0.000	0.000	1.040
SSE	0.000	0.662	3.546	0.804	0.047	0.000	0.000	0.000	5.059
S	0.000	0.095	1.087	0.615	0.331	0.000	0.000	0.000	2.128
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.047
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.095
WNW	0.000	0.047	0.142	0.000	0.000	0.000	0.000	0.000	0.189
NW	0.000	0.095	0.047	0.000	0.000	0.000	0.000	0.000	0.142
NNW	0.000	0.047	0.615	0.095	0.047	0.000	0.000	0.000	0.804
SUBTOTAL	0.000	1.513	7.423	2.128	0.473	0.000	0.000	0.000	11.537

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
 TOTAL HOURS OF STABILITY CLASS G
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.73

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 11

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR GROUND LEVEL RELEASES
SECOND QUARTER

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.047	0.142	1.609	0.047	0.000	1.846
NNE	0.000	0.000	0.000	0.000	0.142	0.663	0.000	0.000	0.805
NE	0.000	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.047
ENE	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.473	0.947	0.237	0.000	0.000	1.656
SE	0.000	0.000	0.473	2.366	0.426	0.095	0.000	0.000	3.360
SSE	0.000	0.000	0.757	0.615	0.095	0.000	0.000	0.000	1.467
S	0.000	0.000	1.041	0.899	0.000	0.000	0.000	0.000	1.940
SSW	0.000	0.000	0.237	0.805	0.000	0.000	0.000	0.000	1.041
SW	0.000	0.000	0.047	0.331	0.000	0.000	0.000	0.000	0.379
WSW	0.000	0.000	0.000	0.331	0.000	0.047	0.000	0.000	0.379
W	0.000	0.000	0.000	0.095	0.095	0.000	0.000	0.000	0.189
WNW	0.000	0.000	0.000	0.047	0.095	0.331	0.047	0.000	0.521
NW	0.000	0.000	0.000	0.047	0.142	0.473	0.095	0.047	0.805
NNW	0.000	0.000	0.000	0.047	0.284	0.142	0.142	0.000	0.521
SUBTOTAL	0.000	0.000	2.556	6.105	2.177	3.739	0.379	0.047	0.000
									15.002

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2130
317
317
2113
0TOTAL HOURS OF STABILITY CLASS A
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALMMETEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 6.09

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <= -1.7 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.047	0.000	0.189	0.000	0.000	0.237
NNE	0.000	0.000	0.000	0.047	0.095	0.189	0.047	0.000	0.379
NE	0.000	0.000	0.000	0.000	0.000	0.189	0.000	0.000	0.189
ENE	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.047
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.284	0.095	0.000	0.000	0.000	0.379
SE	0.000	0.000	0.237	0.189	0.095	0.000	0.000	0.000	0.521
SSE	0.000	0.000	0.284	0.047	0.000	0.000	0.000	0.000	0.331
S	0.000	0.000	0.237	0.237	0.047	0.000	0.000	0.000	0.521
SSW	0.000	0.000	0.379	0.331	0.000	0.000	0.000	0.000	0.710
SW	0.000	0.000	0.189	0.331	0.000	0.000	0.000	0.000	0.521
WSW	0.000	0.000	0.095	0.473	0.000	0.047	0.000	0.000	0.615
W	0.000	0.000	0.000	0.142	0.000	0.047	0.000	0.000	0.189
WNW	0.000	0.000	0.047	0.000	0.047	0.047	0.000	0.000	0.142
NW	0.000	0.000	0.000	0.095	0.189	0.047	0.000	0.000	0.331
NNW	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SUBTOTAL	0.000	0.000	1.467	2.130	0.568	0.899	0.095	0.000	5.159

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2130
110
109
2113
0TOTAL HOURS OF STABILITY CLASS B
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALMMETEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 5.22

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.189	0.000	0.000	0.189
NNE	0.000	0.000	0.000	0.000	0.095	0.047	0.000	0.000	0.142
NE	0.000	0.000	0.000	0.000	0.000	0.142	0.000	0.000	0.142
ENE	0.000	0.000	0.000	0.095	0.142	0.000	0.000	0.000	0.237
E	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
ESE	0.000	0.000	0.000	0.047	0.284	0.095	0.047	0.000	0.473
SE	0.000	0.000	0.000	0.142	0.142	0.047	0.000	0.000	0.331
SSE	0.000	0.000	0.331	0.142	0.000	0.000	0.000	0.000	0.473
S	0.000	0.000	0.284	0.095	0.095	0.000	0.000	0.000	0.473
SSW	0.000	0.000	0.284	0.189	0.000	0.000	0.000	0.000	0.473
SW	0.000	0.000	0.237	0.237	0.000	0.000	0.000	0.000	0.473
WSW	0.000	0.000	0.000	0.047	0.047	0.047	0.000	0.000	0.095
W	0.000	0.000	0.047	0.095	0.047	0.000	0.000	0.000	0.189
WNW	0.000	0.000	0.000	0.000	0.095	0.047	0.000	0.000	0.142
NW	0.000	0.000	0.000	0.047	0.189	0.284	0.095	0.000	0.615
NNW	0.000	0.000	0.000	0.047	0.000	0.095	0.000	0.000	0.142
SUBTOTAL	0.000	0.000	1.372	1.467	0.852	0.852	0.095	0.000	4.638

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
 TOTAL HOURS OF STABILITY CLASS C
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM
 0

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2130
 101
 98
 2113
 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 5.48

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA_T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.047	0.237	0.379	0.757	0.000	0.000	0.000
NNE	0.000	0.000	0.142	0.284	0.426	0.568	0.000	0.000	0.420
NE	0.000	0.000	0.047	0.237	0.426	0.142	0.000	0.000	0.852
ENE	0.000	0.000	0.142	0.237	0.095	0.000	0.000	0.000	0.473
E	0.000	0.000	0.142	0.473	0.142	0.000	0.000	0.000	0.757
ESE	0.000	0.000	0.473	1.609	1.183	0.189	0.000	0.000	3.455
SE	0.000	0.000	1.230	1.325	0.331	0.047	0.000	0.000	2.934
SSE	0.000	0.000	0.947	0.284	0.047	0.000	0.000	0.000	1.278
S	0.000	0.047	1.514	0.426	0.237	0.000	0.000	0.000	2.224
SSW	0.000	0.095	1.514	1.088	0.379	0.000	0.000	0.000	3.076
SW	0.000	0.047	0.568	0.237	0.000	0.000	0.000	0.000	0.852
WSW	0.000	0.000	0.615	0.331	0.095	0.284	0.000	0.000	1.325
W	0.000	0.000	0.331	0.331	0.095	0.047	0.000	0.000	0.805
WNW	0.000	0.000	0.237	0.568	0.237	0.284	0.000	0.047	1.372
NW	0.000	0.047	0.142	0.331	0.710	0.899	0.095	0.000	2.224
NNW	0.000	0.000	0.047	0.331	0.237	0.663	0.426	0.000	1.704
SUBTOTAL	0.000	0.237	8.140	8.329	5.017	3.881	0.521	0.047	0.000
									26.171

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2130
562
553
2113
0TOTAL HOURS OF STABILITY CLASS D
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALMMETEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 5.12

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0-6-1.4		1.5-3.4		3.5-5.4		5.5-7.4		7.5-12.4		12.5-18.4		18.5-24.4		>=24.5		TOTAL
N	0.000	0.047	0.710	0.994	0.710	0.331	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2.792	
NNE	0.000	0.095	0.331	0.473	0.284	0.237	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.420	
NE	0.000	0.142	0.805	0.473	0.615	0.237	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2.272	
ENE	0.000	0.095	0.757	0.757	0.189	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.798	
E	0.000	0.095	1.325	2.035	0.142	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	3.644	
ESE	0.000	0.331	2.035	1.562	0.379	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	4.307	
SE	0.000	0.095	1.562	0.379	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2.082	
SSE	0.000	0.189	0.899	0.284	0.237	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.704	
S	0.000	0.189	1.183	0.426	0.142	0.189	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2.177	
SSW	0.000	0.095	0.615	0.805	0.379	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.940	
SW	0.000	0.000	0.284	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.284	
WSW	0.000	0.142	0.284	0.189	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.663	
W	0.000	0.095	0.521	0.331	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.947	
WW	0.000	0.047	0.000	0.047	0.047	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.189	
NW	0.000	0.047	0.142	0.189	0.095	0.142	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.615	
NNW	0.000	0.000	0.237	0.142	0.284	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.757	
SUBTOTAL	0.000	1.704	11.690	9.087	3.549	1.514	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	27.591		

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2130
 TOTAL HOURS OF STABILITY CLASS E 585
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E 583
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2113
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 3.89

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ($1.5 < \text{DELTA T} \leq 4.0$ C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.095	0.521	0.379	0.095	0.000	0.000	0.000	1.088
NNE	0.000	0.095	0.473	0.663	0.095	0.000	0.000	0.000	1.325
NE	0.000	0.237	0.805	0.142	0.142	0.000	0.000	0.000	1.325
ENE	0.000	0.095	0.663	0.189	0.095	0.000	0.000	0.000	1.041
E	0.000	0.237	1.088	0.568	0.047	0.000	0.000	0.000	1.940
ESE	0.000	0.142	0.852	0.095	0.000	0.000	0.000	0.000	1.088
SE	0.000	0.521	0.899	0.095	0.000	0.000	0.000	0.000	1.514
SSE	0.000	0.568	0.379	0.142	0.095	0.000	0.000	0.000	1.278
S	0.000	0.189	0.379	0.237	0.000	0.000	0.000	0.000	0.805
SSW	0.000	0.095	0.331	0.000	0.000	0.000	0.000	0.000	0.426
SW	0.000	0.142	0.095	0.000	0.000	0.000	0.000	0.000	0.237
WSW	0.000	0.047	0.095	0.000	0.000	0.000	0.000	0.000	0.142
W	0.000	0.142	0.331	0.047	0.000	0.000	0.000	0.000	0.521
WNW	0.000	0.095	0.000	0.000	0.000	0.000	0.000	0.000	0.095
NW	0.000	0.047	0.047	0.142	0.000	0.000	0.000	0.000	0.237
NNW	0.000	0.047	0.284	0.189	0.095	0.000	0.000	0.000	0.615
SUBTOTAL	0.000	2.792	7.241	2.887	0.663	0.095	0.000	0.000	13.677

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2130

TOTAL HOURS OF STABILITY CLASS F

290

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F

289

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2113

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL
 MEAN WIND SPEED = 2.69

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTAT > 4.0 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.331	1.183	0.331	0.000	0.000	0.000	0.000	1.846
NNE	0.000	0.189	0.710	0.189	0.000	0.000	0.000	0.000	1.088
NE	0.000	0.095	0.473	0.000	0.000	0.000	0.000	0.000	0.568
ENE	0.000	0.237	0.568	0.095	0.000	0.000	0.000	0.000	0.899
E	0.000	0.237	0.142	0.095	0.000	0.000	0.000	0.000	0.473
ESE	0.000	0.142	0.047	0.000	0.000	0.000	0.000	0.000	0.189
SE	0.000	0.284	0.047	0.000	0.000	0.000	0.000	0.000	0.331
SSE	0.000	0.284	0.189	0.047	0.000	0.000	0.000	0.000	0.521
S	0.000	0.047	0.189	0.095	0.000	0.000	0.000	0.000	0.331
SSW	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.047
SW	0.000	0.047	0.047	0.000	0.000	0.000	0.000	0.000	0.095
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.047
WNW	0.000	0.189	0.000	0.000	0.000	0.000	0.000	0.000	0.189
NW	0.000	0.095	0.142	0.000	0.000	0.000	0.000	0.000	0.237
NNW	0.000	0.142	0.757	0.000	0.000	0.000	0.000	0.000	0.899
SUBTOTAL	0.000	2.366	4.543	0.852	0.000	0.000	0.000	0.000	7.761

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2130
165
164
2113
0TOTAL HOURS OF STABILITY CLASS G
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALMMETEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 12

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR GROUND LEVEL RELEASES
THIRD QUARTER

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.185	0.000	0.000	0.185
NNE	0.000	0.000	0.000	0.000	0.000	0.139	0.000	0.000	0.139
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.046
ESE	0.000	0.000	0.000	0.278	0.371	0.000	0.000	0.000	0.649
SE	0.000	0.000	0.185	1.437	0.046	0.000	0.000	0.000	1.669
SSE	0.000	0.000	1.066	1.762	0.000	0.000	0.000	0.000	2.828
S	0.000	0.000	0.974	1.113	0.000	0.000	0.000	0.000	2.086
SSW	0.000	0.000	0.278	0.788	0.000	0.000	0.000	0.000	1.066
SW	0.000	0.000	0.139	0.742	0.046	0.000	0.000	0.000	0.927
WSW	0.000	0.000	0.046	0.417	0.046	0.000	0.000	0.000	0.510
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
NNW	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.046
SUBTOTAL	0.000	0.000	2.689	6.583	0.556	0.371	0.000	0.000	10.199

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

218

TOTAL HOURS OF STABILITY CLASS A

221

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A

220

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2157

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS

WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 4.16

DATE PRINTED: 2002/12/03

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)						>=24.5	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.046	0.000	0.046	0.000	0.046	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.371	0.000	0.000	0.371
NE	0.000	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.046
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.046	0.093	0.000	0.000	0.000	0.000	0.139
ESE	0.000	0.000	0.046	0.139	0.093	0.000	0.000	0.000	0.278
SE	0.000	0.000	0.185	0.185	0.000	0.000	0.000	0.000	0.371
SSE	0.000	0.000	0.834	0.278	0.000	0.000	0.000	0.000	1.113
S	0.000	0.000	0.510	0.232	0.000	0.000	0.000	0.000	0.742
SSW	0.000	0.000	0.556	0.232	0.000	0.000	0.000	0.000	0.788
SW	0.000	0.000	0.232	0.464	0.000	0.000	0.000	0.000	0.695
WSW	0.000	0.000	0.046	0.371	0.000	0.000	0.000	0.000	0.417
W	0.000	0.000	0.185	0.093	0.000	0.000	0.000	0.000	0.278
WNW	0.000	0.000	0.000	0.046	0.093	0.000	0.000	0.000	0.232
NW	0.000	0.000	0.000	0.093	0.000	0.000	0.000	0.000	0.093
NNW	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.139
SUBTOTAL	0.000	0.000	2.457	2.411	0.325	0.603	0.000	0.000	5.795

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
 TOTAL HOURS OF STABILITY CLASS B
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM
 0

2188
 126
 125
 2157
 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL
 MEAN WIND SPEED = 4.20

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <= -1.5 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.046	0.093	0.000	0.139	0.000	0.000	0.278
NNE	0.000	0.000	0.000	0.093	0.139	0.232	0.000	0.000	0.464
NE	0.000	0.000	0.000	0.093	0.000	0.000	0.000	0.000	0.093
ENE	0.000	0.000	0.000	0.093	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.093	0.232	0.046	0.000	0.000	0.093
SE	0.000	0.000	0.000	0.603	0.000	0.000	0.000	0.000	0.371
SSE	0.000	0.000	0.325	0.000	0.000	0.000	0.000	0.000	0.603
S	0.000	0.000	0.695	0.093	0.000	0.000	0.000	0.000	0.325
SSW	0.000	0.000	0.695	0.139	0.000	0.000	0.000	0.000	0.788
SW	0.000	0.000	0.417	0.232	0.000	0.000	0.000	0.000	0.834
WSW	0.000	0.000	0.093	0.556	0.046	0.000	0.000	0.000	0.649
W	0.000	0.000	0.046	0.185	0.139	0.046	0.000	0.000	0.695
WNW	0.000	0.000	0.046	0.093	0.185	0.000	0.000	0.000	0.417
NW	0.000	0.000	0.046	0.000	0.093	0.185	0.000	0.000	0.325
NNW	0.000	0.000	0.000	0.046	0.093	0.046	0.000	0.000	0.325
SUBTOTAL	0.000	0.000	3.106	1.901	0.742	0.649	0.000	0.000	6.398

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS C
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALM

2188
139
138
2157
0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 4.32

DATE PRINTED: 2002/12/03

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.417	0.417	0.695	0.278	0.000	0.000	1.808
NNE	0.000	0.000	0.371	0.417	0.556	0.649	0.046	0.000	2.040
NE	0.000	0.000	0.417	0.510	0.185	0.325	0.000	0.000	1.437
ENE	0.000	0.000	0.417	0.371	0.325	0.232	0.000	0.000	1.344
E	0.000	0.000	0.510	0.603	0.185	0.139	0.000	0.000	1.437
ESE	0.000	0.000	0.881	1.808	0.881	0.139	0.000	0.000	3.709
SE	0.000	0.046	1.391	0.464	0.185	0.000	0.000	0.000	2.086
SSE	0.000	0.046	1.205	0.139	0.000	0.000	0.000	0.000	1.391
S	0.000	0.046	1.854	0.185	0.000	0.046	0.000	0.000	2.133
SSW	0.000	0.139	2.550	0.185	0.046	0.185	0.000	0.000	3.106
SW	0.000	0.000	1.484	0.232	0.000	0.000	0.000	0.000	1.715
WSW	0.000	0.093	1.854	0.695	0.046	0.000	0.000	0.000	2.689
W	0.000	0.000	0.881	1.205	0.325	0.093	0.000	0.000	2.503
WNW	0.000	0.000	0.278	0.742	0.788	0.464	0.000	0.000	2.272
NW	0.000	0.000	0.185	0.510	0.556	0.695	0.046	0.000	1.994
NNW	0.000	0.000	0.278	0.278	0.417	0.464	0.000	0.000	1.437
SUBTOTAL	0.000	0.371	14.975	8.762	5.192	3.709	0.093	0.000	33.102

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS D

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

TOTAL HOURS CALM

2188
728
714
2157
0METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL
MEAN WIND SPEED = 4.36NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS
DATE PRINTED: 2002/12/03

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.046	0.927	0.927	0.510	0.093	0.000	0.000	0.000
NNE	0.000	0.185	0.788	0.788	0.695	0.371	0.000	0.000	0.000
NE	0.000	0.278	1.020	0.510	0.649	0.232	0.000	0.000	0.000
ENE	0.000	0.232	1.391	0.742	0.232	0.000	0.000	0.000	0.000
E	0.000	0.185	1.576	1.576	0.185	0.139	0.000	0.000	0.000
ESE	0.000	0.000	1.947	1.252	0.139	0.046	0.000	0.000	0.000
SE	0.000	0.139	1.020	0.139	0.093	0.000	0.000	0.000	0.000
SSE	0.000	0.232	0.510	0.000	0.000	0.046	0.000	0.000	0.000
S	0.000	0.325	0.927	0.000	0.046	0.046	0.000	0.000	0.000
SSW	0.000	0.185	0.927	0.000	0.093	0.139	0.000	0.000	0.000
SW	0.000	0.139	0.603	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.046	0.649	0.046	0.000	0.000	0.000	0.000	0.000
W	0.000	0.046	0.510	0.371	0.232	0.093	0.000	0.000	0.000
WNW	0.000	0.046	0.232	0.000	0.093	0.000	0.000	0.000	0.000
NW	0.000	0.046	0.325	0.139	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.139	0.464	0.417	0.046	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	2.272	13.815	6.908	3.013	1.205	0.000	0.000	27.214

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
 TOTAL HOURS OF STABILITY CLASS E
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM

2188
 598
 587
 2157
 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 3.49

DATE PRINTED: 2002/12/03

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA T <= 4.0 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.232	1.159	1.066	0.046	0.000	0.000	0.000	2.503
NNE	0.000	0.325	0.881	1.252	0.185	0.000	0.000	0.000	2.643
NE	0.000	0.000	0.417	0.185	0.046	0.000	0.000	0.000	0.649
ENE	0.000	0.139	0.881	0.417	0.000	0.000	0.000	0.000	1.437
E	0.000	0.046	0.556	0.603	0.000	0.000	0.000	0.000	1.205
ESE	0.000	0.093	0.185	0.000	0.000	0.000	0.000	0.000	0.278
SE	0.000	0.278	0.093	0.000	0.000	0.000	0.000	0.000	0.371
SSE	0.000	0.139	0.093	0.000	0.000	0.000	0.000	0.000	0.232
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.093	0.046	0.046	0.000	0.000	0.000	0.000	0.185
WSW	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
W	0.000	0.093	0.093	0.046	0.000	0.000	0.000	0.000	0.232
WNW	0.000	0.139	0.185	0.046	0.000	0.000	0.000	0.000	0.371
NW	0.000	0.000	0.325	0.046	0.000	0.000	0.000	0.000	0.371
NNW	0.000	0.139	0.417	0.046	0.000	0.000	0.000	0.000	0.603
SUBTOTAL	0.000	1.715	5.378	3.755	0.278	0.000	0.000	0.000	11.127

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2188

241

240

2157

0

TOTAL HOURS OF STABILITY CLASS F
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALMMETEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL
MEAN WIND SPEED = 2.89DATE PRINTED: 2002/12/03
NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.371	0.881	0.278	0.000	0.000	0.000	0.000	1.530
NNE	0.000	0.371	0.695	0.000	0.046	0.000	0.000	0.000	1.113
NE	0.000	0.510	0.556	0.046	0.000	0.000	0.000	0.000	1.113
ENE	0.000	0.046	0.649	0.139	0.000	0.000	0.000	0.000	0.834
E	0.000	0.046	0.325	0.046	0.000	0.000	0.000	0.000	0.417
ESE	0.000	0.000	0.093	0.000	0.000	0.000	0.000	0.000	0.093
SE	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.046
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
SW	0.000	0.093	0.000	0.000	0.000	0.000	0.000	0.000	0.093
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.046
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.325	0.371	0.139	0.000	0.000	0.000	0.000	0.834
SUBTOTAL	0.000	1.854	3.616	0.649	0.046	0.000	0.000	0.000	6.166

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS G

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

21.57

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS

WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.14

21.88

135

133

0

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 13

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR GROUND LEVEL RELEASES
FOURTH QUARTER

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.046	0.046	0.000	0.092
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.046	0.092	0.000	0.000	0.000	0.000	0.139
SE	0.000	0.000	0.000	0.416	0.000	0.000	0.000	0.000	0.416
SSE	0.000	0.000	0.139	0.139	0.000	0.000	0.000	0.000	0.277
S	0.000	0.000	0.277	0.462	0.000	0.000	0.000	0.000	0.740
SSW	0.000	0.000	0.000	0.185	0.000	0.000	0.000	0.000	0.185
SW	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.046	0.046	0.000	0.092
NNW	0.000	0.000	0.000	0.000	0.000	0.046	0.046	0.000	0.046
SUBTOTAL	0.000	0.000	0.462	1.341	0.000	0.092	0.139	0.000	2.034

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS A

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALM2172
44
44
2163
0METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL
MEAN WIND SPEED = 4.86DATE PRINTED: 2003/02/07
NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				18.5-24.4	>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.139	0.046	0.000	0.185
NNE	0.000	0.000	0.000	0.000	0.092	0.000	0.000	0.000	0.000	0.092
NE	0.000	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.046
ENE	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
E	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
ESE	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
SE	0.000	0.000	0.092	0.324	0.000	0.000	0.000	0.000	0.000	0.416
SSE	0.000	0.000	0.185	0.046	0.000	0.000	0.000	0.000	0.000	0.231
S	0.000	0.000	0.185	0.139	0.000	0.000	0.000	0.000	0.000	0.324
SSW	0.000	0.000	0.046	0.092	0.000	0.000	0.000	0.000	0.000	0.139
SW	0.000	0.000	0.046	0.092	0.000	0.000	0.000	0.000	0.000	0.139
WSW	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.092
W	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.092
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.046	0.046	0.000	0.046
NW	0.000	0.000	0.000	0.000	0.000	0.046	0.092	0.092	0.000	0.139
NNW	0.000	0.000	0.000	0.092	0.139	0.000	0.046	0.046	0.000	0.277
SUBTOTAL	0.000	0.000	0.555	0.786	0.324	0.462	0.231	0.000	0.000	2.358

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2172
51
51
2163
0

TOTAL HOURS OF STABILITY CLASS B
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALM

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL
MEAN WIND SPEED = 6.31

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)						>=24.5	TOTAL
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.046	0.000	0.185	0.046	0.000	0.000	0.277
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.185	0.000	0.000	0.000	0.000	0.185
SE	0.000	0.000	0.139	0.046	0.000	0.000	0.000	0.000	0.185
SSE	0.000	0.000	0.185	0.046	0.000	0.000	0.000	0.000	0.231
S	0.000	0.000	0.139	0.092	0.000	0.000	0.000	0.000	0.231
SSW	0.000	0.000	0.185	0.046	0.000	0.000	0.000	0.000	0.370
SW	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
WSW	0.000	0.000	0.046	0.092	0.046	0.046	0.000	0.000	0.231
W	0.000	0.000	0.000	0.000	0.046	0.000	0.046	0.000	0.092
WNW	0.000	0.000	0.000	0.092	0.046	0.185	0.139	0.000	0.462
NW	0.000	0.000	0.000	0.000	0.231	0.185	0.139	0.000	0.555
NNW	0.000	0.000	0.000	0.092	0.000	0.370	0.046	0.000	0.509
SUBTOTAL	0.000	0.000	0.693	0.925	0.416	0.971	0.416	0.000	3.421

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2172

TOTAL HOURS OF STABILITY CLASS C

74

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C

74

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2163

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 7.06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D ($-1.5 < \text{DELTAT} \leq -0.5$ C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.4	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.647	1.341	1.017	0.555	0.000	0.000	3.560
NNE	0.000	0.000	0.277	1.248	1.017	0.693	0.092	0.000	3.329
NE	0.000	0.046	0.462	1.156	0.462	0.324	0.139	0.000	2.589
E	0.000	0.000	0.740	0.370	0.324	0.046	0.046	0.000	1.526
ESE	0.000	0.000	0.925	1.248	0.046	0.092	0.000	0.000	2.312
SE	0.000	0.046	0.647	1.942	1.526	0.277	0.046	0.000	4.438
SSE	0.000	0.046	1.526	0.555	0.185	0.185	0.000	0.000	2.497
S	0.000	0.046	1.757	0.693	0.046	0.046	0.000	0.000	2.589
SSW	0.000	0.046	1.479	0.370	0.046	0.000	0.000	0.000	1.942
SW	0.000	0.092	0.647	0.092	0.092	0.000	0.000	0.000	0.878
WSW	0.000	0.000	0.555	0.324	0.000	0.000	0.000	0.000	0.971
W	0.000	0.000	0.416	0.277	0.231	0.277	0.000	0.000	1.202
WNW	0.000	0.000	0.462	0.555	0.832	0.971	0.231	0.000	3.051
NW	0.000	0.000	0.185	0.832	0.878	1.248	1.110	0.046	4.300
NNW	0.000	0.092	0.277	1.248	0.509	1.849	1.063	0.046	4.993
		0.370	1.110	1.202	3.282	0.370	0.000	0.000	6.426
SUBTOTAL	0.000	0.416	11.373	13.361	8.414	9.847	3.098	0.092	46.602

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2172

TOTAL HOURS OF STABILITY CLASS D

1013

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D

1008

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2163

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 6.05

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA_T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.046	0.509	0.878	0.462	0.185	0.000	0.000	2.080
NNE	0.000	0.092	0.601	0.370	0.277	0.000	0.000	0.000	1.341
NE	0.000	0.046	0.370	0.092	0.185	0.000	0.000	0.000	0.693
ENE	0.000	0.185	0.509	0.277	0.046	0.092	0.000	0.000	1.110
E	0.000	0.046	0.740	0.370	0.000	0.000	0.000	0.000	1.156
ESE	0.000	0.185	1.063	0.509	0.416	0.185	0.000	0.000	2.358
SE	0.000	0.324	0.878	0.324	0.324	0.231	0.000	0.000	2.080
SSE	0.000	0.139	1.618	0.647	0.509	0.000	0.000	0.000	2.913
S	0.000	0.139	1.711	0.878	0.647	0.462	0.000	0.000	3.837
SSW	0.000	0.139	0.370	0.509	0.092	0.231	0.000	0.000	1.341
SW	0.000	0.000	0.555	0.092	0.000	0.000	0.000	0.000	0.647
WSW	0.000	0.185	0.509	0.370	0.370	0.046	0.000	0.000	1.479
W	0.000	0.046	0.277	0.231	0.139	0.046	0.000	0.000	0.740
WNW	0.000	0.092	0.139	0.092	0.139	0.000	0.000	0.000	0.462
NW	0.000	0.092	0.324	0.231	0.185	0.092	0.000	0.000	1.017
NNW	0.000	0.139	0.647	0.878	0.509	0.324	0.046	0.000	2.543
SUBTOTAL	0.000	1.896	10.818	6.750	4.300	1.896	0.139	0.000	25.798

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2172
561

TOTAL HOURS OF STABILITY CLASS E

558

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E

2163

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

0

TOTAL HOURS CALM

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 4.01

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA T <= 4.0 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)				>=24.4	TOTAL
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4		
N	0.000	0.046	1.063	0.971	0.000	0.000	0.000
NNE	0.000	0.185	0.416	0.277	0.000	0.000	0.000
NE	0.000	0.092	0.277	0.000	0.000	0.000	0.370
ENE	0.000	0.000	0.231	0.046	0.000	0.000	0.277
E	0.000	0.092	0.740	0.231	0.000	0.000	1.063
ESE	0.000	0.092	0.555	0.000	0.000	0.000	0.647
SE	0.000	0.277	0.740	0.324	0.092	0.000	1.433
SSE	0.000	0.231	1.341	0.370	0.046	0.000	2.034
S	0.000	0.046	0.786	0.416	0.231	0.139	0.000
SSW	0.000	0.092	0.324	0.000	0.000	0.000	0.416
SW	0.000	0.046	0.185	0.000	0.000	0.000	0.231
WSW	0.000	0.139	0.092	0.000	0.000	0.000	0.231
W	0.000	0.000	0.092	0.000	0.000	0.000	0.092
WW	0.000	0.046	0.046	0.000	0.000	0.000	0.092
NW	0.000	0.000	0.092	0.000	0.046	0.000	0.139
NNW	0.000	0.046	0.601	0.416	0.092	0.000	1.202
SUBTOTAL	0.000	1.433	7.582	3.051	0.462	0.277	0.000
							12.806

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS F 2172
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F 278
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 277
 TOTAL HOURS CALM 2163
 TOTAL HOURS 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.90

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS G (DELTAT > 4.0 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.509	1.063	0.277	0.000	0.000	0.000	0.000	1.849
NNE	0.000	0.416	0.416	0.000	0.000	0.000	0.000	0.000	0.832
NE	0.000	0.139	0.462	0.000	0.000	0.000	0.000	0.000	0.601
ENE	0.000	0.046	0.509	0.000	0.000	0.000	0.000	0.000	0.555
E	0.000	0.092	0.092	0.000	0.000	0.000	0.000	0.000	0.185
ESE	0.000	0.231	0.139	0.000	0.000	0.000	0.000	0.000	0.370
SE	0.000	0.092	0.139	0.000	0.000	0.000	0.000	0.000	0.231
SSE	0.000	0.185	1.063	0.092	0.000	0.000	0.000	0.000	1.341
S	0.000	0.185	0.139	0.000	0.046	0.000	0.000	0.000	0.370
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.046	0.046	0.000	0.000	0.000	0.000	0.000	0.092
WNW	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.000	0.046
NW	0.000	0.092	0.046	0.000	0.000	0.000	0.000	0.000	0.139
NNW	0.000	0.092	0.277	0.000	0.000	0.000	0.000	0.000	0.370
SUBTOTAL	0.000	2.173	4.392	0.370	0.046	0.000	0.000	0.000	6.981

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
 TOTAL HOURS OF STABILITY CLASS G
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM

2172
 151
 151
 2163
 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT 10.50 METER LEVEL

MEAN WIND SPEED = 2.03

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 14

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR SPLIT LEVEL RELEASES
(GROUND LEVEL PORTION)
FIRST QUARTER

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED(MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.019	0.078	0.034	0.000
NNE	0.000	0.000	0.000	0.000	0.010	0.051	0.019	0.000	0.080
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.017	0.000	0.000	0.017
SE	0.000	0.000	0.000	0.059	0.070	0.000	0.000	0.000	0.129
SSE	0.000	0.000	0.000	0.033	0.008	0.000	0.000	0.000	0.041
S	0.000	0.000	0.000	0.070	0.072	0.000	0.000	0.000	0.142
SSW	0.000	0.000	0.009	0.047	0.018	0.000	0.000	0.000	0.075
SW	0.000	0.000	0.000	0.000	0.007	0.000	0.000	0.000	0.007
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.015	0.018	0.011	0.000	0.043
WNW	0.000	0.000	0.000	0.000	0.004	0.087	0.054	0.000	0.145
NW	0.000	0.000	0.000	0.000	0.002	0.122	0.037	0.000	0.162
MNW	0.000	0.000	0.000	0.000	0.014	0.117	0.124	0.000	0.255
SUBTOTAL	0.000	0.000	0.009	0.209	0.240	0.490	0.279	0.000	1.227

TOTAL HOURS OF VALID OBSERVATIONS

2108.000

TOTAL HOURS OF GROUND LEVEL RELEASE

310.980

TOTAL HOURS OF STABILITY CLASS A

25.860

TOTAL HOURS OF GROUND LEVEL STABILITY CLASS A

25.860

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS

WIND DIRECTION MEASURED AT 10.50 METER LEVEL

WIND SPEED MEASURED AT 10.50 METER LEVEL

EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <= -1.7 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.006	0.022	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.040	0.011	0.000	0.000	0.051
NE	0.000	0.000	0.000	0.000	0.000	0.007	0.000	0.000	0.007
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.009	0.000	0.000	0.000	0.009
SE	0.000	0.000	0.001	0.011	0.009	0.000	0.000	0.000	0.022
SSE	0.000	0.000	0.001	0.006	0.000	0.000	0.000	0.000	0.007
S	0.000	0.000	0.000	0.000	0.009	0.016	0.000	0.000	0.025
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.002	0.007	0.000	0.000	0.000	0.009
W	0.000	0.000	0.000	0.000	0.000	0.009	0.000	0.000	0.018
WNW	0.000	0.000	0.000	0.000	0.009	0.027	0.096	0.000	0.131
NW	0.000	0.000	0.000	0.000	0.000	0.037	0.043	0.000	0.080
MNW	0.000	0.000	0.000	0.000	0.000	0.031	0.000	0.000	0.031
SUBTOTAL	0.000	0.000	0.003	0.019	0.087	0.160	0.148	0.000	0.418

TOTAL HOURS OF VALID OBSERVATIONS

2108.000

TOTAL HOURS OF GROUND LEVEL RELEASE

310.980

TOTAL HOURS OF STABILITY CLASS B

8.810

TOTAL HOURS OF GROUND LEVEL STABILITY CLASS B

8.810

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS

WIND DIRECTION MEASURED AT 10.50 METER LEVEL

WIND SPEED MEASURED AT 10.50 METER LEVEL

EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.017	0.000	0.000	0.000	0.017
NNE	0.000	0.000	0.000	0.000	0.027	0.014	0.000	0.000	0.041
NE	0.000	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.006
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.004
SE	0.000	0.000	0.000	0.009	0.007	0.000	0.000	0.000	0.017
SSE	0.000	0.000	0.000	0.000	0.026	0.000	0.000	0.000	0.026
S	0.000	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.010
SSW	0.000	0.000	0.000	0.010	0.000	0.010	0.000	0.000	0.020
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.009	0.000	0.000	0.000	0.009
W	0.000	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.003
WNW	0.000	0.000	0.000	0.000	0.004	0.022	0.062	0.075	0.163
NW	0.000	0.000	0.000	0.000	0.000	0.037	0.059	0.000	0.096
NW	0.000	0.000	0.000	0.001	0.000	0.057	0.019	0.000	0.077
SUBTOTAL	0.000	0.000	0.000	0.035	0.083	0.155	0.139	0.075	0.488

TOTAL HOURS OF VALID OBSERVATIONS

2108.000

TOTAL HOURS OF GROUND LEVEL RELEASE

310.980

TOTAL HOURS OF STABILITY CLASS C

13.020

TOTAL HOURS OF GROUND LEVEL STABILITY CLASS C

10.280

METEOROLOGICAL FACILITY:

Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS

WIND DIRECTION MEASURED AT 10.50 METER LEVEL

WIND SPEED MEASURED AT 10.50 METER LEVEL

EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.023	0.082	0.424	0.029	0.047	0.000
NNE	0.000	0.000	0.000	0.040	0.127	0.126	0.000	0.000	0.294
NE	0.000	0.000	0.000	0.015	0.064	0.056	0.000	0.000	0.135
ENE	0.000	0.000	0.001	0.019	0.020	0.000	0.000	0.000	0.040
E	0.000	0.000	0.000	0.009	0.020	0.009	0.000	0.000	0.038
ESE	0.000	0.000	0.002	0.014	0.026	0.022	0.000	0.000	0.065
SE	0.000	0.000	0.010	0.055	0.035	0.126	0.000	0.000	0.225
SSE	0.000	0.000	0.011	0.080	0.014	0.000	0.000	0.000	0.104
S	0.000	0.000	0.000	0.027	0.101	0.054	0.000	0.000	0.181
SSW	0.000	0.000	0.010	0.048	0.000	0.018	0.000	0.000	0.076
SW	0.000	0.000	0.000	0.019	0.000	0.010	0.000	0.000	0.029
WSW	0.000	0.000	0.001	0.004	0.023	0.028	0.000	0.000	0.056
W	0.000	0.000	0.000	0.013	0.058	0.103	0.016	0.000	0.190
WNW	0.000	0.000	0.000	0.001	0.018	0.126	0.384	0.094	0.000
NW	0.000	0.000	0.000	0.002	0.042	0.381	0.646	0.097	0.000
NNW	0.000	0.000	0.000	0.019	0.085	0.363	0.198	0.045	0.000
SUBTOTAL	0.000	0.000	0.036	0.386	0.713	1.846	1.273	0.284	0.000
TOTAL HOURS OF VALID OBSERVATIONS						2108.000			
TOTAL HOURS OF GROUND LEVEL RELEASE						310.980			
TOTAL HOURS OF STABILITY CLASS D						1007.200			
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS D						95.660			

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.004	0.077	0.064	0.052	0.000	0.000	0.196
NNE	0.000	0.000	0.003	0.037	0.060	0.027	0.000	0.000	0.127
NE	0.000	0.000	0.003	0.059	0.036	0.008	0.000	0.000	0.106
ENE	0.000	0.000	0.000	0.009	0.014	0.000	0.000	0.000	0.023
E	0.000	0.000	0.021	0.011	0.008	0.000	0.000	0.000	0.040
ESE	0.000	0.000	0.033	0.038	0.025	0.000	0.000	0.000	0.096
SE	0.000	0.000	0.068	0.142	0.123	0.047	0.000	0.000	0.381
SSE	0.000	0.000	0.061	0.319	0.042	0.190	0.000	0.000	0.611
S	0.000	0.000	0.057	0.348	0.301	0.503	0.000	0.000	1.210
SSW	0.000	0.000	0.035	0.114	0.044	0.062	0.000	0.000	0.255
SW	0.000	0.000	0.013	0.005	0.008	0.009	0.000	0.000	0.035
WSW	0.000	0.000	0.025	0.009	0.009	0.000	0.000	0.000	0.044
W	0.000	0.000	0.017	0.038	0.063	0.000	0.000	0.000	0.118
WNW	0.000	0.000	0.000	0.000	0.026	0.040	0.000	0.000	0.066
NW	0.000	0.000	0.004	0.036	0.050	0.093	0.009	0.000	0.192
NNW	0.000	0.000	0.002	0.075	0.072	0.049	0.011	0.000	0.209
SUBTOTAL	0.000	0.000	0.348	1.317	0.935	1.090	0.020	0.000	3.711

TOTAL HOURS OF VALID OBSERVATIONS

2108.000

TOTAL HOURS OF GROUND LEVEL RELEASE

310.980

TOTAL HOURS OF STABILITY CLASS E

822.100

TOTAL HOURS OF GROUND LEVEL STABILITY CLASS E

78.230

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA T = 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.035	0.065	0.000	0.000	0.000	0.000	0.101
NNE	0.000	0.000	0.006	0.049	0.015	0.000	0.000	0.000	0.070
NE	0.000	0.000	0.006	0.019	0.008	0.000	0.000	0.000	0.032
ENE	0.000	0.000	0.026	0.013	0.000	0.000	0.000	0.000	0.039
E	0.000	0.004	0.030	0.063	0.000	0.000	0.000	0.000	0.097
ESE	0.000	0.000	0.034	0.008	0.000	0.000	0.000	0.000	0.041
SE	0.000	0.000	0.148	0.093	0.010	0.000	0.000	0.000	0.251
SSE	0.000	0.010	0.170	0.116	0.158	0.047	0.000	0.000	0.501
S	0.000	0.004	0.065	0.220	0.229	0.723	0.000	0.000	1.242
SSW	0.000	0.000	0.025	0.057	0.044	0.010	0.000	0.000	0.136
SW	0.000	0.000	0.000	0.013	0.000	0.000	0.000	0.000	0.013
WSW	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
W	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
WW	0.000	0.000	0.002	0.005	0.000	0.000	0.000	0.000	0.008
NW	0.000	0.000	0.001	0.009	0.016	0.000	0.000	0.000	0.027
NNW	0.000	0.000	0.020	0.106	0.015	0.000	0.000	0.000	0.141
SUBTOTAL	0.000	0.022	0.569	0.835	0.495	0.781	0.000	0.000	2.702
TOTAL HOURS OF VALID OBSERVATIONS					2108.000				
TOTAL HOURS OF GROUND LEVEL RELEASE					310.980				
TOTAL HOURS OF STABILITY CLASS F					159.840				
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS F					56.950				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.009	0.033	0.000	0.000	0.000	0.000	0.042
NNE	0.000	0.000	0.001	0.011	0.000	0.000	0.000	0.000	0.012
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.015	0.000	0.000	0.000	0.000	0.000	0.015
E	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.003
ESE	0.000	0.010	0.002	0.007	0.000	0.000	0.000	0.000	0.019
SE	0.000	0.001	0.122	0.010	0.027	0.000	0.000	0.000	0.160
SSE	0.000	0.080	0.596	0.240	0.043	0.000	0.000	0.000	0.959
S	0.000	0.005	0.175	0.132	0.103	0.000	0.000	0.000	0.416
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.022	0.012	0.009	0.000	0.000	0.000	0.043
SUBTOTAL	0.000	0.096	0.947	0.444	0.182	0.000	0.000	0.000	1.669

TOTAL HOURS OF VALID OBSERVATIONS

2108.000

TOTAL HOURS OF GROUND LEVEL RELEASE

310.980

TOTAL HOURS OF STABILITY CLASS G

71.170

TOTAL HOURS OF GROUND LEVEL STABILITY CLASS G

35.190

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS

WIND DIRECTION MEASURED AT 10.50 METER LEVEL

WIND SPEED MEASURED AT 10.50 METER LEVEL

EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 15

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR SPLIT LEVEL RELEASES
(GROUND LEVEL PORTION)
SECOND QUARTER

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=1.9 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.013	0.286	0.016	0.000
NNE	0.000	0.000	0.000	0.000	0.012	0.113	0.000	0.000	0.124
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.009	0.000	0.009
ENE	0.000	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.004
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.055	0.166	0.071	0.000	0.000	0.292
SE	0.000	0.000	0.028	0.213	0.078	0.022	0.000	0.000	0.341
SSE	0.000	0.000	0.053	0.043	0.047	0.000	0.000	0.000	0.143
S	0.000	0.000	0.094	0.147	0.000	0.000	0.000	0.000	0.241
SSW	0.000	0.000	0.007	0.144	0.000	0.000	0.000	0.000	0.151
SW	0.000	0.000	0.000	0.024	0.000	0.000	0.000	0.000	0.024
WSW	0.000	0.000	0.000	0.017	0.000	0.009	0.000	0.000	0.025
W	0.000	0.000	0.000	0.003	0.002	0.000	0.000	0.000	0.005
WNW	0.000	0.000	0.000	0.000	0.004	0.043	0.026	0.000	0.073
NW	0.000	0.000	0.000	0.000	0.007	0.070	0.031	0.032	0.139
NWW	0.000	0.000	0.000	0.000	0.005	0.046	0.028	0.000	0.079
SUBTOTAL	0.000	0.000	0.183	0.646	0.338	0.658	0.111	0.032	0.000
TOTAL HOURS OF VALID OBSERVATIONS				2114.000					
TOTAL HOURS OF GROUND LEVEL RELEASE				231.920					
TOTAL HOURS OF STABILITY CLASS A				41.580					
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS A				41.580					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <= -1.7 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.036	0.000	0.000	0.036
NNE	0.000	0.000	0.000	0.000	0.008	0.029	0.010	0.000	0.047
NE	0.000	0.000	0.000	0.000	0.000	0.026	0.000	0.000	0.026
ENE	0.000	0.000	0.000	0.000	0.004	0.000	0.000	0.000	0.004
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.034	0.014	0.000	0.000	0.000	0.048
SE	0.000	0.000	0.013	0.016	0.018	0.000	0.000	0.000	0.046
SSE	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000	0.009
S	0.000	0.000	0.006	0.032	0.010	0.000	0.000	0.000	0.048
SSW	0.000	0.000	0.005	0.029	0.000	0.000	0.000	0.000	0.034
SW	0.000	0.000	0.007	0.023	0.000	0.000	0.000	0.000	0.030
WSW	0.000	0.000	0.000	0.028	0.000	0.009	0.000	0.000	0.038
W	0.000	0.000	0.000	0.002	0.000	0.009	0.000	0.000	0.011
WNW	0.000	0.000	0.000	0.000	0.001	0.006	0.000	0.000	0.007
NW	0.000	0.000	0.000	0.000	0.009	0.030	0.024	0.000	0.064
NWW	0.000	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.003
SUBTOTAL	0.000	0.000	0.040	0.164	0.067	0.147	0.034	0.000	0.451
TOTAL HOURS OF VALID OBSERVATIONS				2114.000					
TOTAL HOURS OF GROUND LEVEL RELEASE				231.920					
TOTAL HOURS OF STABILITY CLASS B				9.540					
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS B				9.540					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T < -1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED(MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.038	0.000	0.000	0.038
NNE	0.000	0.000	0.000	0.000	0.009	0.007	0.000	0.000	0.015
NE	0.000	0.000	0.000	0.000	0.000	0.023	0.000	0.000	0.023
ENE	0.000	0.000	0.000	0.000	0.001	0.011	0.000	0.000	0.012
E	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.001
ESE	0.000	0.000	0.004	0.034	0.013	0.023	0.000	0.000	0.074
SE	0.000	0.000	0.000	0.017	0.008	0.000	0.000	0.000	0.024
SSE	0.000	0.000	0.015	0.000	0.000	0.000	0.000	0.000	0.015
S	0.000	0.000	0.022	0.009	0.018	0.000	0.000	0.000	0.049
SSW	0.000	0.000	0.005	0.041	0.000	0.000	0.000	0.000	0.046
SW	0.000	0.000	0.005	0.018	0.000	0.000	0.000	0.000	0.023
WSW	0.000	0.000	0.000	0.004	0.005	0.000	0.000	0.000	0.009
W	0.000	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.003
WNW	0.000	0.000	0.000	0.000	0.007	0.008	0.000	0.000	0.015
NW	0.000	0.000	0.000	0.000	0.014	0.045	0.022	0.000	0.080
NNW	0.000	0.000	0.000	0.000	0.016	0.000	0.000	0.000	0.016
SUBTOTAL	0.000	0.000	0.052	0.124	0.087	0.158	0.022	0.000	0.443
TOTAL HOURS OF VALID OBSERVATIONS				2114.000					
TOTAL HOURS OF GROUND LEVEL RELEASE				231.920					
TOTAL HOURS OF STABILITY CLASS C				14.150					
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS C				9.360					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/08/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.009	0.046	0.163	0.000	0.000	0.218
NNE	0.000	0.000	0.000	0.020	0.053	0.102	0.000	0.000	0.175
NE	0.000	0.000	0.000	0.000	0.038	0.019	0.000	0.000	0.058
ENE	0.000	0.000	0.000	0.009	0.008	0.000	0.000	0.000	0.018
E	0.000	0.000	0.001	0.038	0.018	0.000	0.000	0.000	0.056
ESE	0.000	0.000	0.032	0.198	0.232	0.048	0.000	0.000	0.510
SE	0.000	0.000	0.078	0.180	0.064	0.020	0.000	0.000	0.342
SSE	0.000	0.000	0.047	0.023	0.022	0.000	0.000	0.000	0.091
S	0.000	0.000	0.110	0.080	0.053	0.000	0.000	0.000	0.242
SSW	0.000	0.000	0.098	0.175	0.099	0.000	0.000	0.000	0.373
SW	0.000	0.000	0.019	0.031	0.000	0.000	0.000	0.000	0.050
WSW	0.000	0.000	0.010	0.027	0.016	0.053	0.000	0.000	0.106
W	0.000	0.000	0.000	0.010	0.011	0.009	0.000	0.000	0.031
WNW	0.000	0.000	0.000	0.000	0.012	0.038	0.000	0.043	0.093
NW	0.000	0.000	0.000	0.004	0.051	0.115	0.019	0.000	0.189
NNW	0.000	0.000	0.000	0.012	0.022	0.117	0.153	0.000	0.305
SUBTOTAL	0.000	0.000	0.396	0.818	0.744	0.684	0.172	0.043	0.000
TOTAL HOURS OF VALID OBSERVATIONS						2114.000			
TOTAL HOURS OF GROUND LEVEL RELEASE						231.920			
TOTAL HOURS OF STABILITY CLASS D						1073.710			
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS D						60.410			

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)					>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4		
N	0.000	0.004	0.015	0.106	0.124	0.062	0.000	0.000	0.000	0.311
NNE	0.000	0.000	0.005	0.049	0.041	0.044	0.000	0.000	0.000	0.139
NE	0.000	0.002	0.015	0.042	0.090	0.043	0.000	0.000	0.000	0.191
ENE	0.000	0.001	0.029	0.057	0.027	0.000	0.000	0.000	0.000	0.114
E	0.000	0.000	0.063	0.242	0.021	0.008	0.000	0.000	0.000	0.334
ESE	0.000	0.007	0.157	0.245	0.076	0.000	0.000	0.000	0.000	0.485
SE	0.000	0.000	0.159	0.072	0.020	0.000	0.000	0.000	0.000	0.252
SSE	0.000	0.002	0.128	0.114	0.221	0.095	0.000	0.000	0.000	0.559
S	0.000	0.008	0.178	0.081	0.060	0.178	0.047	0.000	0.000	0.552
SSW	0.000	0.000	0.064	0.160	0.124	0.035	0.000	0.000	0.000	0.385
SW	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.000	0.000	0.010
WSW	0.000	0.000	0.008	0.018	0.000	0.029	0.000	0.000	0.000	0.056
W	0.000	0.000	0.007	0.030	0.000	0.000	0.000	0.000	0.000	0.037
WNW	0.000	0.000	0.000	0.004	0.004	0.008	0.000	0.000	0.000	0.017
NW	0.000	0.000	0.000	0.021	0.012	0.025	0.000	0.000	0.000	0.059
NNW	0.000	0.000	0.001	0.018	0.037	0.017	0.000	0.000	0.000	0.073
SUBTOTAL	0.000	0.024	0.839	1.260	0.858	0.544	0.047	0.000	0.000	3.571
TOTAL HOURS OF VALID OBSERVATIONS				2114.000						
TOTAL HOURS OF GROUND LEVEL RELEASE				231.920						
TOTAL HOURS OF STABILITY CLASS E				741.240						
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS E				75.500						

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA T = 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	~	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)					>=24.5	TOTAL
					3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4		
N		0.000	0.004	0.018	0.049	0.016	0.000	0.000	0.000	0.000	0.088
NNE		0.000	0.000	0.008	0.092	0.016	0.000	0.000	0.000	0.000	0.115
NE		0.000	0.013	0.034	0.020	0.024	0.000	0.000	0.000	0.000	0.091
ENE		0.000	0.005	0.032	0.017	0.016	0.000	0.000	0.000	0.000	0.070
E		0.000	0.010	0.049	0.070	0.009	0.000	0.000	0.000	0.000	0.137
ESE		0.000	0.000	0.042	0.016	0.000	0.000	0.000	0.000	0.000	0.058
SE		0.000	0.035	0.070	0.014	0.000	0.000	0.000	0.000	0.000	0.118
SSE		0.000	0.027	0.033	0.063	0.069	0.095	0.000	0.000	0.000	0.288
S		0.000	0.000	0.073	0.054	0.000	0.000	0.000	0.000	0.000	0.128
SSW		0.000	0.001	0.020	0.000	0.000	0.000	0.000	0.000	0.000	0.021
SW		0.000	0.009	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.010
WSW		0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W		0.000	0.003	0.003	0.002	0.000	0.000	0.000	0.000	0.000	0.008
WNW		0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW		0.000	0.000	0.000	0.011	0.000	0.000	0.000	0.000	0.000	0.011
NNW		0.000	0.000	0.011	0.024	0.015	0.000	0.000	0.000	0.000	0.050
SUBTOTAL		0.000	0.108	0.393	0.432	0.165	0.095	0.000	0.000	0.000	1.192
TOTAL HOURS OF VALID OBSERVATIONS							2114.000				
TOTAL HOURS OF GROUND LEVEL RELEASE							231.920				
TOTAL HOURS OF STABILITY CLASS F							207.340				
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS F							25.200				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.056	0.039	0.000	0.000	0.000	0.000	0.095
NNE	0.000	0.003	0.019	0.018	0.000	0.000	0.000	0.000	0.041
NE	0.000	0.004	0.017	0.000	0.000	0.000	0.000	0.000	0.021
ENE	0.000	0.020	0.028	0.011	0.000	0.000	0.000	0.000	0.059
E	0.000	0.024	0.010	0.005	0.000	0.000	0.000	0.000	0.039
ESE	0.000	0.014	0.006	0.000	0.000	0.000	0.000	0.000	0.020
SE	0.000	0.035	0.006	0.000	0.000	0.000	0.000	0.000	0.041
SSE	0.000	0.037	0.027	0.032	0.000	0.000	0.000	0.000	0.096
S	0.000	0.000	0.027	0.017	0.000	0.000	0.000	0.000	0.044
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.006
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.006
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.003
NNW	0.000	0.000	0.019	0.000	0.000	0.000	0.000	0.000	0.019
SUBTOTAL	0.000	0.149	0.219	0.122	0.000	0.000	0.000	0.000	0.489
TOTAL HOURS OF VALID OBSERVATIONS				2114.000					
TOTAL HOURS OF GROUND LEVEL RELEASE				231.920					
TOTAL HOURS OF STABILITY CLASS G				26.440					
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS G				10.330					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 16

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR SPLIT LEVEL RELEASES
(GROUND LEVEL PORTION)
THIRD QUARTER

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTAT <= -1.9 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.031	0.000	0.000	0.031
NNE	0.000	0.000	0.000	0.000	0.025	0.000	0.000	0.000	0.025
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.003
ESE	0.000	0.000	0.000	0.035	0.064	0.000	0.000	0.000	0.098
SE	0.000	0.000	0.024	0.118	0.007	0.000	0.000	0.000	0.149
SSE	0.000	0.000	0.045	0.098	0.000	0.000	0.000	0.000	0.143
S	0.000	0.000	0.057	0.078	0.000	0.000	0.000	0.000	0.135
SSW	0.000	0.000	0.031	0.062	0.000	0.000	0.000	0.000	0.093
SW	0.000	0.000	0.003	0.027	0.009	0.000	0.000	0.000	0.039
WSW	0.000	0.000	0.000	0.016	0.005	0.000	0.000	0.000	0.021
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.008	0.000	0.000	0.000	0.008
SUBTOTAL	0.000	0.000	0.159	0.435	0.087	0.064	0.000	0.000	0.745

TOTAL HOURS OF VALID OBSERVATIONS

2156.000

TOTAL HOURS OF GROUND LEVEL RELEASE

139.510

TOTAL HOURS OF STABILITY CLASS A

18.920

TOTAL HOURS OF GROUND LEVEL STABILITY CLASS A

16.060

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/12/03

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9< DELTA T <=-1.7 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.007	0.000	0.000	0.007
NNE	0.000	0.000	0.000	0.000	0.000	0.052	0.000	0.000	0.052
NE	0.000	0.000	0.000	0.000	0.000	0.005	0.000	0.000	0.005
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.001
ESE	0.000	0.000	0.006	0.017	0.013	0.000	0.000	0.000	0.036
SE	0.000	0.000	0.008	0.010	0.000	0.000	0.000	0.000	0.018
SSE	0.000	0.000	0.030	0.003	0.000	0.000	0.000	0.000	0.033
S	0.000	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.010
SSW	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.000	0.008
SW	0.000	0.000	0.004	0.007	0.000	0.000	0.000	0.000	0.011
WSW	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.005
W	0.000	0.000	0.000	0.002	0.004	0.000	0.000	0.000	0.006
WNW	0.000	0.000	0.000	0.000	0.006	0.010	0.000	0.000	0.017
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.005	0.007	0.000	0.000	0.000	0.012
SUBTOTAL	0.000	0.000	0.058	0.053	0.028	0.082	0.000	0.000	0.221

TOTAL HOURS OF VALID OBSERVATIONS

2156.000

TOTAL HOURS OF GROUND LEVEL RELEASE

139.510

TOTAL HOURS OF STABILITY CLASS B

9.590

TOTAL HOURS OF GROUND LEVEL STABILITY CLASS B

4.760

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS

WIND DIRECTION MEASURED AT 10.50 METER LEVEL

WIND SPEED MEASURED AT 10.50 METER LEVEL

EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/12/03

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.020	0.000	0.000	0.020
NNE	0.000	0.000	0.000	0.003	0.008	0.035	0.000	0.000	0.046
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.015	0.006	0.000	0.000	0.000	0.022
SE	0.000	0.000	0.032	0.000	0.000	0.000	0.000	0.000	0.032
SSE	0.000	0.000	0.012	0.000	0.000	0.000	0.000	0.000	0.012
S	0.000	0.000	0.000	0.007	0.018	0.000	0.000	0.000	0.026
SSW	0.000	0.000	0.011	0.017	0.000	0.000	0.000	0.000	0.028
SW	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000	0.007
WSW	0.000	0.000	0.000	0.002	0.006	0.000	0.000	0.000	0.008
W	0.000	0.000	0.000	0.002	0.009	0.007	0.000	0.000	0.019
WNW	0.000	0.000	0.000	0.000	0.011	0.000	0.000	0.000	0.011
NW	0.000	0.000	0.000	0.000	0.009	0.025	0.000	0.000	0.034
NNW	0.000	0.000	0.000	0.000	0.008	0.007	0.000	0.000	0.016
SUBTOTAL	0.000	0.000	0.069	0.058	0.058	0.095	0.000	0.000	0.279

TOTAL HOURS OF VALID OBSERVATIONS

2156.000

139.510

TOTAL HOURS OF GROUND LEVEL RELEASE

31.740

TOTAL HOURS OF STABILITY CLASS C

6.020

TOTAL HOURS OF GROUND LEVEL STABILITY CLASS C

6.020

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS

WIND DIRECTION MEASURED AT 10.50 METER LEVEL

WIND SPEED MEASURED AT 10.50 METER LEVEL

EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/12/03

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.006	0.079	0.046	0.000	0.000	0.131
NNE	0.000	0.000	0.000	0.015	0.053	0.107	0.018	0.000	0.193
NE	0.000	0.000	0.000	0.004	0.014	0.052	0.000	0.000	0.070
ENE	0.000	0.000	0.000	0.008	0.040	0.038	0.000	0.000	0.087
E	0.000	0.000	0.000	0.034	0.025	0.046	0.000	0.000	0.105
ESE	0.000	0.000	0.000	0.052	0.296	0.184	0.068	0.000	0.600
SE	0.000	0.000	0.000	0.078	0.087	0.042	0.000	0.000	0.208
SSE	0.000	0.000	0.000	0.075	0.028	0.000	0.000	0.000	0.103
S	0.000	0.000	0.000	0.081	0.053	0.000	0.008	0.000	0.142
SSW	0.000	0.000	0.000	0.096	0.020	0.006	0.034	0.000	0.156
SW	0.000	0.000	0.000	0.012	0.008	0.000	0.000	0.000	0.020
WSW	0.000	0.000	0.000	0.003	0.019	0.006	0.000	0.000	0.029
W	0.000	0.000	0.000	0.001	0.037	0.023	0.014	0.000	0.075
WNW	0.000	0.000	0.000	0.000	0.008	0.046	0.058	0.000	0.113
NW	0.000	0.000	0.000	0.000	0.016	0.032	0.081	0.012	0.142
NW	0.000	0.000	0.000	0.009	0.050	0.068	0.000	0.000	0.127
SUBTOTAL	0.000	0.000	0.398	0.649	0.602	0.621	0.030	0.000	2.300
TOTAL HOURS OF VALID OBSERVATIONS				2156.000					
TOTAL HOURS OF GROUND LEVEL RELEASE				139.510					
TOTAL HOURS OF STABILITY CLASS D				1182.010					
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS D				49.580					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)				>24.5	TOTAL
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4		
N	0.000	0.005	0.022	0.108	0.086	0.015	0.000
NNE	0.000	0.000	0.014	0.078	0.106	0.061	0.000
NE	0.000	0.005	0.014	0.044	0.083	0.035	0.000
ENE	0.000	0.002	0.033	0.060	0.027	0.000	0.000
E	0.000	0.000	0.061	0.201	0.027	0.053	0.000
ESE	0.000	0.000	0.099	0.193	0.023	0.028	0.000
SE	0.000	0.000	0.074	0.023	0.050	0.000	0.000
SSE	0.000	0.001	0.028	0.000	0.000	0.007	0.000
S	0.000	0.001	0.073	0.000	0.045	0.009	0.000
SSW	0.000	0.001	0.055	0.000	0.040	0.035	0.000
SW	0.000	0.011	0.019	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.005	0.000	0.000	0.000
W	0.000	0.000	0.002	0.018	0.028	0.015	0.000
WNW	0.000	0.000	0.000	0.000	0.008	0.000	0.000
NW	0.000	0.003	0.003	0.007	0.000	0.000	0.000
NNW	0.000	0.000	0.006	0.036	0.006	0.000	0.000
SUBTOTAL	0.000	0.029	0.503	0.772	0.529	0.260	0.000
TOTAL HOURS OF VALID OBSERVATIONS						2156.000	
TOTAL HOURS OF GROUND LEVEL RELEASE						139.510	
TOTAL HOURS OF STABILITY CLASS E						717.040	
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS E						45.130	

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5< DELTA T= 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)					>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4		
N	0.000	0.000	0.069	0.121	0.007	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.002	0.026	0.167	0.031	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.010	0.026	0.006	0.000	0.000	0.000	0.000	0.042
ENE	0.000	0.000	0.026	0.034	0.000	0.000	0.000	0.000	0.000	0.060
E	0.000	0.000	0.018	0.077	0.000	0.000	0.000	0.000	0.000	0.095
ESE	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.005
SE	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
SSE	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.001
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.001
WNW	0.000	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.003
NW	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.005
NW	0.000	0.000	0.012	0.004	0.000	0.000	0.000	0.000	0.000	0.016
SUBTOTAL	0.000	0.002	0.167	0.439	0.045	0.000	0.000	0.000	0.000	0.653
TOTAL HOURS OF VALID OBSERVATIONS					2156.000					
TOTAL HOURS OF GROUND LEVEL RELEASE					139.510					
TOTAL HOURS OF STABILITY CLASS F					180.080					
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS F					14.070					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.039	0.037	0.000	0.000	0.000	0.000	0.076
NNE	0.000	0.000	0.013	0.000	0.008	0.000	0.000	0.000	0.021
NE	0.000	0.001	0.006	0.000	0.000	0.000	0.000	0.000	0.007
ENE	0.000	0.000	0.009	0.019	0.000	0.000	0.000	0.000	0.029
E	0.000	0.000	0.003	0.005	0.000	0.000	0.000	0.000	0.008
ESE	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.003
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.018	0.018	0.000	0.000	0.000	0.000	0.036
SUBTOTAL	0.000	0.001	0.091	0.080	0.008	0.000	0.000	0.000	0.180
TOTAL HOURS OF VALID OBSERVATIONS				2156.000					
TOTAL HOURS OF GROUND LEVEL RELEASE				139.510					
TOTAL HOURS OF STABILITY CLASS G				16.620					
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS G				3.890					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 17

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR SPLIT LEVEL RELEASES
(GROUND LEVEL PORTION)
FOURTH QUARTER

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.011	0.010	0.000	0.020
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.012	0.000	0.000	0.000	0.000	0.012
SE	0.000	0.000	0.000	0.032	0.000	0.000	0.000	0.000	0.032
SSE	0.000	0.000	0.006	0.012	0.000	0.000	0.000	0.000	0.018
S	0.000	0.000	0.023	0.065	0.000	0.000	0.000	0.000	0.088
SSW	0.000	0.000	0.000	0.024	0.000	0.000	0.000	0.000	0.024
SW	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.006
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.015
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.009
SUBTOTAL	0.000	0.000	0.029	0.151	0.000	0.017	0.027	0.000	0.224
TOTAL HOURS OF VALID OBSERVATIONS				2163.000					
TOTAL HOURS OF GROUND LEVEL RELEASE				267.730					
TOTAL HOURS OF STABILITY CLASS A				4.850					
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS A				4.850					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <= -1.7 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.024	0.010	0.000	0.033
NNE	0.000	0.000	0.000	0.000	0.011	0.000	0.000	0.000	0.011
NE	0.000	0.000	0.000	0.000	0.000	0.006	0.000	0.000	0.006
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.007	0.000	0.000	0.000	0.007
SE	0.000	0.000	0.002	0.018	0.000	0.000	0.000	0.000	0.020
SSE	0.000	0.000	0.012	0.000	0.000	0.000	0.000	0.000	0.012
S	0.000	0.000	0.015	0.015	0.000	0.000	0.000	0.000	0.030
SSW	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.006
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.005	0.005	0.008	0.000	0.000	0.013
W	0.000	0.000	0.000	0.006	0.006	0.008	0.000	0.000	0.014
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.009	0.000	0.009
NW	0.000	0.000	0.000	0.000	0.000	0.007	0.019	0.000	0.026
NNW	0.000	0.000	0.000	0.008	0.025	0.010	0.000	0.000	0.043
SUBTOTAL	0.000	0.000	0.030	0.040	0.037	0.079	0.048	0.000	0.233

TOTAL HOURS OF VALID OBSERVATIONS

2163.000

TOTAL HOURS OF GROUND LEVEL RELEASE

267.730

TOTAL HOURS OF STABILITY CLASS B

5.040

TOTAL HOURS OF GROUND LEVEL STABILITY CLASS B

5.040

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS

WIND DIRECTION MEASURED AT 10.50 METER LEVEL

WIND SPEED MEASURED AT 10.50 METER LEVEL

EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.001	0.000	0.032	0.018	0.000	0.052
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.005	0.000	0.000	0.000	0.005
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.018	0.000	0.000	0.000	0.000	0.018
SE	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000	0.007
SSE	0.000	0.000	0.006	0.043	0.000	0.000	0.000	0.000	0.050
S	0.000	0.000	0.008	0.007	0.000	0.000	0.000	0.000	0.016
SSW	0.000	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.008
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.006	0.008	0.000	0.000	0.014
W	0.000	0.000	0.000	0.000	0.004	0.000	0.011	0.000	0.015
WNW	0.000	0.000	0.000	0.000	0.002	0.027	0.051	0.000	0.080
NW	0.000	0.000	0.000	0.000	0.018	0.028	0.028	0.000	0.075
NNW	0.000	0.000	0.000	0.000	0.058	0.018	0.000	0.000	0.076
SUBTOTAL	0.000	0.000	0.022	0.079	0.036	0.153	0.127	0.000	0.417
TOTAL HOURS OF VALID OBSERVATIONS				2163.000					
TOTAL HOURS OF GROUND LEVEL RELEASE				267.730					
TOTAL HOURS OF STABILITY CLASS C				11.780					
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS C				9.020					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.003	0.075	0.121	0.095	0.000	0.000	0.294
NNE	0.000	0.000	0.000	0.046	0.117	0.114	0.036	0.000	0.313
NE	0.000	0.000	0.000	0.018	0.035	0.051	0.069	0.000	0.174
ENE	0.000	0.000	0.000	0.017	0.030	0.008	0.010	0.000	0.064
E	0.000	0.000	0.000	0.007	0.073	0.007	0.017	0.000	0.104
ESE	0.000	0.000	0.026	0.271	0.304	0.151	0.035	0.000	0.787
SE	0.000	0.000	0.066	0.076	0.123	0.145	0.000	0.000	0.410
SSE	0.000	0.006	0.157	0.165	0.046	0.008	0.000	0.000	0.382
S	0.000	0.003	0.111	0.052	0.008	0.000	0.000	0.000	0.174
SSW	0.000	0.000	0.013	0.016	0.018	0.000	0.000	0.000	0.047
SW	0.000	0.000	0.000	0.029	0.000	0.000	0.000	0.000	0.029
WSW	0.000	0.000	0.000	0.019	0.036	0.051	0.000	0.000	0.105
W	0.000	0.000	0.000	0.023	0.092	0.163	0.049	0.000	0.327
WNW	0.000	0.000	0.000	0.009	0.074	0.189	0.313	0.031	0.616
NW	0.000	0.000	0.000	0.035	0.050	0.305	0.271	0.038	0.699
NNW	0.000	0.000	0.000	0.036	0.136	0.564	0.084	0.000	0.820
SUBTOTAL	0.000	0.009	0.382	0.961	1.196	1.862	0.866	0.069	5.347

TOTAL HOURS OF VALID OBSERVATIONS

2163.000

TOTAL HOURS OF GROUND LEVEL RELEASE

267.730

TOTAL HOURS OF STABILITY CLASS D

1226.710

TOTAL HOURS OF GROUND LEVEL STABILITY CLASS D

115.650

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS

WIND DIRECTION MEASURED AT 10.50 METER LEVEL

WIND SPEED MEASURED AT 10.50 METER LEVEL

EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.015	0.101	0.075	0.035	0.000	0.000	0.227
NNE	0.000	0.000	0.009	0.037	0.043	0.000	0.000	0.000	0.088
NE	0.000	0.000	0.008	0.008	0.024	0.000	0.000	0.000	0.040
ENE	0.000	0.000	0.010	0.030	0.006	0.017	0.000	0.000	0.063
E	0.000	0.000	0.040	0.040	0.035	0.000	0.000	0.000	0.075
ESE	0.000	0.000	0.055	0.061	0.101	0.071	0.000	0.000	0.289
SE	0.000	0.005	0.096	0.120	0.280	0.093	0.000	0.000	0.594
SSE	0.000	0.003	0.185	0.330	0.444	0.000	0.000	0.000	0.963
S	0.000	0.000	0.176	0.184	0.255	0.269	0.000	0.000	0.885
SSW	0.000	0.000	0.019	0.074	0.018	0.174	0.000	0.000	0.285
SW	0.000	0.000	0.016	0.012	0.000	0.000	0.000	0.000	0.028
WSW	0.000	0.000	0.003	0.049	0.055	0.008	0.000	0.000	0.115
W	0.000	0.000	0.005	0.023	0.019	0.008	0.000	0.000	0.055
WW	0.000	0.000	0.000	0.008	0.014	0.000	0.000	0.000	0.022
NW	0.000	0.000	0.003	0.016	0.026	0.016	0.034	0.000	0.095
NNW	0.000	0.000	0.029	0.086	0.073	0.059	0.012	0.000	0.259
SUBTOTAL	0.000	0.009	0.670	1.174	1.432	0.750	0.046	0.000	4.081
TOTAL HOURS OF VALID OBSERVATIONS				2163.000					
TOTAL HOURS OF GROUND LEVEL RELEASE				267.730					
TOTAL HOURS OF STABILITY CLASS E				738.670					
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS E				88.280					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA T = 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.058	0.123	0.000	0.000	0.000	0.000	0.182
NNE	0.000	0.000	0.025	0.038	0.000	0.000	0.000	0.000	0.063
NE	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000	0.007
ENE	0.000	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.003
E	0.000	0.000	0.045	0.026	0.000	0.000	0.000	0.000	0.071
ESE	0.000	0.000	0.029	0.000	0.000	0.000	0.000	0.000	0.029
SE	0.000	0.015	0.051	0.123	0.069	0.000	0.000	0.000	0.258
SSE	0.000	0.002	0.105	0.220	0.046	0.041	0.000	0.000	0.415
S	0.000	0.002	0.098	0.097	0.108	0.127	0.000	0.000	0.432
SSW	0.000	0.003	0.015	0.000	0.000	0.000	0.000	0.000	0.018
SW	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.004
WSW	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.000	0.004
W	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.001
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.006
NW	0.000	0.000	0.033	0.055	0.008	0.018	0.000	0.000	0.114
SUBTOTAL	0.000	0.023	0.478	0.683	0.238	0.185	0.000	0.000	1.607
TOTAL HOURS OF VALID OBSERVATIONS					2163.000				
TOTAL HOURS OF GROUND LEVEL RELEASE					267.730				
TOTAL HOURS OF STABILITY CLASS F					153.490				
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS F					34.770				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.000	0.000	0.057	0.033	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.007	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000
E	0.000	0.006	0.005	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.010	0.011	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.012	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.015	0.227	0.040	0.000	0.000	0.000	0.282
S	0.000	0.003	0.015	0.000	0.012	0.000	0.000	0.030
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.034	0.349	0.073	0.012	0.000	0.000	0.468
TOTAL HOURS OF VALID OBSERVATIONS				2163.000				
TOTAL HOURS OF GROUND LEVEL RELEASE				267.730				
TOTAL HOURS OF STABILITY CLASS G				22.460				
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS G				10.120				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.50 METER LEVEL
 WIND SPEED MEASURED AT 10.50 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 18

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR SPLIT LEVEL RELEASES
(ELEVATED PORTION)
FIRST QUARTER

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)				12.5-18.4	>=24.5	TOTAL
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
TOTAL HOURS OF VALID OBSERVATIONS					2108.000			
TOTAL HOURS OF ELEVATED RELEASES					1797.020			
TOTAL HOURS OF STABILITY CLASS A					25.860			
TOTAL HOURS OF ELEVATED STABILITY CLASS A					0.000			

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45-30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <= -1.7 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)			12.5-18.4	18.5-24.4	>24.5	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4				
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
TOTAL HOURS OF VALID OBSERVATIONS					2108.000			
TOTAL HOURS OF ELEVATED RELEASES					1797.020			
TOTAL HOURS OF STABILITY CLASS B					8.810			
TOTAL HOURS OF ELEVATED STABILITY CLASS B					0.000			

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T < -1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1 2002 = MAB 31 - 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	TOTAL
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.047
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.035	0.000	0.035
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.047	0.047	0.000	0.000	0.000	0.035	0.000	0.130

TOTAL HOURS OF VALID OBSERVATIONS	2108.000
TOTAL HOURS OF ELEVATED RELEASES	1797.020
TOTAL HOURS OF STABILITY CLASS C	13.020
TOTAL HOURS OF ELEVATED STABILITY CLASS C	. 2.740

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND DIRECTION MEASURED AT 45.74 METER LEVEL
WIND SPEED MEASURED AT 45.74 METER LEVEL
EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNBOUNDED NUMBERS

DATE PRINTED: 2002/05/15

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.047	0.047	0.275	2.684	2.277	0.214	5.553
NNE	0.000	0.000	0.095	0.142	0.591	2.751	0.698	0.000	4.277
NE	0.000	0.000	0.047	0.285	0.363	0.761	0.039	0.000	1.496
ENE	0.000	0.000	0.047	0.095	0.134	0.211	0.000	0.000	0.487
E	0.000	0.000	0.190	0.285	0.094	0.169	0.038	0.000	0.777
ESE	0.000	0.000	0.237	0.095	0.278	0.423	0.426	0.062	1.522
SE	0.000	0.047	0.190	0.664	0.785	0.719	0.192	0.140	0.021
SSE	0.000	0.000	0.285	0.522	0.047	0.367	0.383	0.268	1.871
S	0.000	0.000	0.380	0.190	0.045	0.812	1.578	0.302	3.332
SSW	0.000	0.000	0.190	0.427	0.138	1.106	0.850	0.238	2.960
SW	0.000	0.000	0.047	0.142	0.227	0.579	0.269	0.000	1.265
WSW	0.000	0.000	0.095	0.237	0.185	0.246	0.191	0.000	0.954
W	0.000	0.000	0.047	0.427	0.231	1.208	0.346	0.068	2.326
WNW	0.000	0.000	0.047	0.095	0.452	1.371	1.579	0.603	4.153
NW	0.000	0.000	0.095	0.190	0.185	1.728	2.196	0.901	5.306
NNW	0.000	0.000	0.047	0.047	0.181	2.007	1.853	0.067	4.205
SUBTOTAL	0.000	0.047	2.087	3.890	4.210	17.142	12.917	2.863	43.242
TOTAL HOURS OF VALID OBSERVATIONS						2108.000			
TOTAL HOURS OF ELEVATED RELEASES						1797.020			
TOTAL HOURS OF STABILITY CLASS D						1007.200			
TOTAL HOURS OF ELEVATED STABILITY CLASS D						911.540			

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED(MPH)				>=24.5
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.000	0.000	0.095	0.095	0.180	1.594	0.154	0.000
NNE	0.000	0.000	0.142	0.332	0.185	1.154	0.000	0.037
NE	0.000	0.000	0.142	0.237	0.223	0.750	0.000	0.000
ENE	0.000	0.000	0.285	0.190	0.141	0.597	0.079	0.000
E	0.000	0.000	0.047	0.285	0.512	0.298	0.000	0.000
ESE	0.000	0.000	0.237	0.142	0.225	0.793	0.194	0.000
SE	0.000	0.000	0.237	0.190	0.811	1.545	0.653	0.268
SSE	0.000	0.000	0.095	0.427	0.680	2.361	1.895	0.472
S	0.000	0.047	0.095	0.380	0.727	2.068	2.507	0.789
SSW	0.000	0.047	0.142	0.237	0.179	0.782	0.966	0.068
SW	0.000	0.000	0.095	0.237	0.182	0.502	0.273	0.000
WSW	0.000	0.000	0.095	0.332	0.184	0.259	0.000	0.869
W	0.000	0.000	0.095	0.285	0.409	0.334	0.000	0.123
WNW	0.000	0.000	0.047	0.142	0.182	0.126	0.078	0.000
NW	0.000	0.000	0.095	0.142	0.414	0.375	0.233	0.000
NNW	0.000	0.000	0.047	0.332	0.181	1.121	0.390	0.000
Subtotal	0.000	0.095	1.992	3.985	5.416	14.662	7.422	1.635
								35.288
TOTAL HOURS OF VALID OBSERVATIONS				2108.000				
TOTAL HOURS OF ELEVATED RELEASES				1797.020				
TOTAL HOURS OF STABILITY CLASS E				822.100				
TOTAL HOURS OF ELEVATED STABILITY CLASS E				743.870				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA T = 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)				>=24.5	TOTAL
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4		
N	0.000	0.000	0.047	0.047	0.000	0.165	0.000
NNE	0.000	0.000	0.047	0.047	0.045	0.083	0.000
NE	0.000	0.000	0.095	0.095	0.142	0.250	0.000
ENE	0.000	0.000	0.095	0.047	0.092	0.042	0.000
E	0.000	0.000	0.047	0.047	0.045	0.125	0.000
ESE	0.000	0.000	0.047	0.047	0.138	0.254	0.000
SE	0.000	0.000	0.190	0.095	0.182	0.371	0.079
SSE	0.000	0.000	0.000	0.095	0.094	0.333	0.039
S	0.000	0.000	0.047	0.237	0.374	0.124	0.000
SSW	0.000	0.000	0.000	0.142	0.000	0.043	0.000
SW	0.000	0.000	0.000	0.000	0.047	0.040	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.047	0.000	0.000	0.047
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.047	0.046	0.126	0.039
SUBTOTAL	0.000	0.000	0.569	0.996	1.204	1.954	0.157
TOTAL HOURS OF VALID OBSERVATIONS						2108.000	
TOTAL HOURS OF ELEVATED RELEASES						1797.020	
TOTAL HOURS OF STABILITY CLASS F						159.840	
TOTAL HOURS OF ELEVATED STABILITY CLASS F						102.890	

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

TDW 1 3002 - MDR 31 3003

卷之三

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	WIND SPEED (MPH)	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	TOTAL
N	0.000	0.000	0.000	0.000	0.045	0.000	0.000	0.000	0.000	0.000	0.045
NNE	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
NE	0.000	0.000	0.047	0.000	0.000	0.000	0.039	0.000	0.000	0.000	0.087
ENE	0.000	0.000	0.000	0.000	0.000	0.040	0.000	0.000	0.000	0.000	0.040
E	0.000	0.000	0.095	0.047	0.000	0.085	0.000	0.000	0.000	0.000	0.228
ESE	0.000	0.000	0.000	0.047	0.185	0.127	0.000	0.000	0.000	0.000	0.359
SE	0.000	0.000	0.190	0.095	0.047	0.210	0.000	0.000	0.000	0.000	0.541
SSE	0.000	0.000	0.000	0.000	0.045	0.042	0.000	0.000	0.000	0.000	0.087
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.047	0.000	0.000	0.042	0.000	0.000	0.000	0.000	0.089
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.000	0.000	0.047
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.095	0.000	0.043	0.000	0.000	0.000	0.000	0.000	0.138
SUBTOTAL	0.000	0.000	0.380	0.332	0.368	0.588	0.039	0.000	0.000	0.000	1.707

TOTAL HOURS OF VALID OBSERVATIONS

卷之三

1/31/122011

TOTAL HOURS OF STABILITY CLASS G /1.100

TOTAL HOURS OF ELEVATED STABILITY CLASS G 35.980

BROWNS FERRY NUCLEAR PLANT
METEOROLOGICAL FACILITY:

STABILITY BASED ON DELTA-T BETWEEN 45° 30' AND 89° 59' METERS

WIND DIRECTION MEASURED AT 45° METER LEVEL

WIND SPEED MEASURED AT 45 METER LEVEL.

EFFLUENT VELOCITY = 12.60 M/S

THE ECONOMICS OF THE ENVIRONMENT

DATE PRINTED: 2002/05/15

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 19

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR SPLIT LEVEL RELEASES
(ELEVATED PORTION)
SECOND QUARTER

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
TOTAL HOURS OF VALID OBSERVATIONS						2114.000			
TOTAL HOURS OF ELEVATED RELEASES						1882.080			
TOTAL HOURS OF STABILITY CLASS A						41.580			
TOTAL HOURS OF ELEVATED STABILITY CLASS A						0.000			

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <= -1.7 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)			12.5-18.4	18.5-24.4	>=24.5	TOTAL
		0-6-1.4	1.5-3.4	3.5-5.4				
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
TOTAL HOURS OF VALID OBSERVATIONS					2114.000			
TOTAL HOURS OF ELEVATED RELEASES					1882.080			
TOTAL HOURS OF STABILITY CLASS B					9.540			
TOTAL HOURS OF ELEVATED STABILITY CLASS B					0.000			

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/08/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2002 ~ JUN 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)					>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.042	0.000	0.000	0.042
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SSW	0.000	0.000	0.000	0.000	0.047	0.000	0.043	0.000	0.000	0.090
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.043	0.000	0.000	0.043
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.004
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.095	0.000	0.128	0.000	0.000	0.004	0.227
TOTAL HOURS OF VALID OBSERVATIONS					2114.000					
TOTAL HOURS OF ELEVATED RELEASES					1882.080					
TOTAL HOURS OF STABILITY CLASS C					14.150					
TOTAL HOURS OF ELEVATED STABILITY CLASS C					4.790					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)					>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4		
N	0.000	0.000	0.000	0.331	0.228	1.277	1.920	0.414	0.000	4.170
NNE	0.000	0.000	0.047	0.237	0.272	1.414	0.965	0.110	0.000	3.045
NE	0.000	0.000	0.095	0.142	0.225	0.703	0.077	0.000	0.000	1.241
ENE	0.000	0.000	0.000	0.189	0.185	0.258	0.000	0.000	0.000	0.632
E	0.000	0.000	0.047	0.047	0.136	0.170	0.000	0.000	0.000	0.401
ESE	0.000	0.000	0.047	0.237	0.862	2.324	0.655	0.000	0.000	4.124
SE	0.000	0.000	0.284	0.757	1.139	2.642	1.922	0.393	0.001	7.139
SSE	0.000	0.000	0.473	0.662	0.682	1.820	0.735	0.111	0.004	4.487
S	0.000	0.000	0.378	0.757	0.548	1.257	1.461	0.246	0.011	4.659
SSW	0.000	0.000	0.662	0.568	0.496	1.878	1.432	0.212	0.000	5.248
SW	0.000	0.000	0.520	0.615	0.543	1.208	0.193	0.000	0.000	3.079
WSW	0.000	0.047	0.473	0.851	0.139	0.125	0.229	0.018	0.000	1.883
W	0.000	0.000	0.142	0.520	0.318	0.042	0.000	0.000	0.000	1.022
WNW	0.000	0.000	0.095	0.378	0.320	0.701	0.000	0.021	0.000	1.515
NW	0.000	0.000	0.142	0.473	0.731	1.551	0.427	0.064	0.000	3.388
NNW	0.000	0.000	0.047	0.095	0.364	0.695	0.576	0.121	0.000	1.898
SUBTOTAL	0.000	0.047	3.453	6.859	7.186	18.066	10.593	1.711	0.017	47.933
TOTAL HOURS OF VALID OBSERVATIONS						2114.000				
TOTAL HOURS OF ELEVATED RELEASES						1882.080				
TOTAL HOURS OF STABILITY CLASS D						1073.710				
TOTAL HOURS OF ELEVATED STABILITY CLASS D						1013.300				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.047	0.189	0.363	0.494	0.348	0.000	0.000
NNE	0.000	0.000	0.047	0.095	0.687	1.206	0.154	0.000	0.000
NE	0.000	0.000	0.095	0.331	0.412	0.832	0.196	0.000	0.000
ENE	0.000	0.000	0.189	0.378	0.273	0.502	0.194	0.000	0.000
E	0.000	0.047	0.142	0.331	0.591	0.853	0.000	0.000	0.000
ESE	0.000	0.000	0.047	0.378	0.912	2.277	0.118	0.000	0.000
SE	0.000	0.000	0.189	0.520	0.681	1.711	0.888	0.155	0.010
SSE	0.000	0.000	0.189	0.662	0.637	1.037	0.853	0.359	0.008
S	0.000	0.000	0.237	0.378	0.277	1.118	0.653	0.000	0.006
SSW	0.000	0.000	0.142	0.331	0.271	0.821	0.733	0.056	0.000
SW	0.000	0.047	0.378	0.378	0.316	0.169	0.000	0.000	0.289
WSW	0.000	0.000	0.284	0.142	0.276	0.254	0.078	0.000	0.034
W	0.000	0.000	0.189	0.426	0.367	0.125	0.000	0.000	1.107
WNW	0.000	0.000	0.426	0.142	0.045	0.128	0.039	0.000	0.780
NW	0.000	0.000	0.284	0.047	0.047	0.371	0.077	0.000	0.827
NNW	0.000	0.000	0.142	0.237	0.136	0.250	0.039	0.000	0.803
SUBTOTAL	0.000	0.095	3.027	4.967	6.294	12.147	4.369	0.570	0.024
TOTAL HOURS OF VALID OBSERVATIONS				2114.000					
TOTAL HOURS OF ELEVATED RELEASES				1882.080					
TOTAL HOURS OF STABILITY CLASS E				741.240					
TOTAL HOURS OF ELEVATED STABILITY CLASS E				665.740					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA T <= 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.000	0.000	0.000	0.047	0.045	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.047	0.088	0.739	0.000	0.000
NE	0.000	0.000	0.000	0.047	0.226	0.377	0.157	0.000
ENE	0.000	0.000	0.000	0.237	0.408	0.254	0.157	0.000
E	0.000	0.000	0.000	0.047	0.095	0.311	0.378	0.000
ESE	0.000	0.000	0.000	0.047	0.088	0.288	0.039	0.000
SE	0.000	0.000	0.000	0.047	0.237	0.184	0.376	0.000
SSE	0.000	0.000	0.095	0.189	0.272	0.291	0.000	0.000
S	0.000	0.000	0.000	0.142	0.455	0.168	0.000	0.000
SSW	0.000	0.000	0.095	0.237	0.091	0.126	0.000	0.000
SW	0.000	0.000	0.095	0.237	0.140	0.043	0.000	0.000
WSW	0.000	0.000	0.047	0.095	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.142	0.047	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.284	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.087	0.000	0.000
NWW	0.000	0.000	0.095	0.047	0.000	0.084	0.000	0.000
SUBTOTAL	0.000	0.000	0.568	2.129	2.355	3.211	0.353	0.000
TOTAL HOURS OF VALID OBSERVATIONS				2114.000				
TOTAL HOURS OF ELEVATED RELEASES				1882.080				
TOTAL HOURS OF STABILITY CLASS F				207.340				
TOTAL HOURS OF ELEVATED STABILITY CLASS F				182.140				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)			>=24.5			TOTAL
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.044	0.041	0.000	0.000
NE	0.000	0.000	0.000	0.047	0.047	0.043	0.000	0.086
ENE	0.000	0.000	0.000	0.000	0.000	0.123	0.000	0.137
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.123
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.047	0.092	0.044	0.000	0.183
SSE	0.000	0.000	0.000	0.095	0.000	0.000	0.000	0.095
S	0.000	0.000	0.047	0.000	0.045	0.000	0.000	0.092
SSW	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.095	0.189	0.228	0.250	0.000	0.762
TOTAL HOURS OF VALID OBSERVATIONS					2114.000			
TOTAL HOURS OF ELEVATED RELEASES					1882.080			
TOTAL HOURS OF STABILITY CLASS G					26.440			
TOTAL HOURS OF ELEVATED STABILITY CLASS G					16.110			

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45-30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 20

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR SPLIT LEVEL RELEASES
(ELEVATED PORTION)
THIRD QUARTER

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)				>24.5	TOTAL
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.090	0.043	0.133
TOTAL HOURS OF VALID OBSERVATIONS						2156.000	
TOTAL HOURS OF ELEVATED RELEASES						2016.490	
TOTAL HOURS OF STABILITY CLASS A						18.920	
TOTAL HOURS OF ELEVATED STABILITY CLASS A						2.860	

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/12/03

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.046	0.093	0.043	0.000	0.000	0.182
WSW	0.000	0.000	0.000	0.000	0.000	0.042	0.000	0.000	0.042
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.046	0.093	0.085	0.000	0.000	0.224
TOTAL HOURS OF VALID OBSERVATIONS				2156.000					
TOTAL HOURS OF ELEVATED RELEASES				2016.490					
TOTAL HOURS OF STABILITY CLASS B				9.590					
TOTAL HOURS OF ELEVATED STABILITY CLASS B				4.830					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/12/03

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <= -1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.039	0.000	0.000	0.039
NNE	0.000	0.000	0.000	0.000	0.000	0.038	0.000	0.000	0.038
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.045	0.000	0.000	0.000	0.045
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.093	0.089	0.126	0.000	0.000	0.308
SW	0.000	0.000	0.000	0.046	0.449	0.000	0.000	0.000	0.495
WSW	0.000	0.000	0.000	0.046	0.045	0.000	0.000	0.000	0.092
W	0.000	0.000	0.000	0.046	0.089	0.042	0.000	0.000	0.177
WW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.232	0.716	0.207	0.038	0.000	1.193

TOTAL HOURS OF VALID OBSERVATIONS

2156.000

TOTAL HOURS OF ELEVATED RELEASES

2016.490

TOTAL HOURS OF STABILITY CLASS C

31.740

TOTAL HOURS OF ELEVATED STABILITY CLASS C

25.720

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.371	0.417	0.183	1.129	0.190	0.000	0.000
NNE	0.000	0.000	0.186	0.325	0.492	1.212	0.457	0.000	0.000
NE	0.000	0.046	0.139	0.464	0.179	0.487	0.077	0.000	2.671
ENE	0.000	0.000	0.093	0.093	0.000	0.366	0.000	0.000	1.392
E	0.000	0.000	0.186	0.186	0.314	0.203	0.037	0.000	0.551
ESE	0.000	0.000	0.139	0.325	0.403	0.851	0.154	0.000	0.926
SE	0.000	0.000	0.603	1.020	0.945	1.922	1.624	0.404	1.872
SSE	0.000	0.000	0.835	2.365	1.609	2.401	1.093	0.173	8.482
S	0.000	0.000	0.881	1.623	1.512	1.718	0.340	0.013	6.087
SSW	0.000	0.000	1.160	1.855	0.937	1.229	0.376	0.030	5.587
SW	0.000	0.046	0.881	1.902	0.905	0.207	0.000	0.000	3.942
WSW	0.000	0.000	0.557	2.041	0.634	0.000	0.000	0.000	3.231
W	0.000	0.000	0.417	0.974	1.035	0.417	0.000	0.000	2.844
WNW	0.000	0.000	0.278	0.510	1.115	0.581	0.038	0.000	2.523
NW	0.000	0.000	0.371	0.232	0.705	0.942	0.000	0.000	2.250
NNW	0.000	0.000	0.186	0.093	0.229	0.775	0.075	0.000	1.357
SUBTOTAL	0.000	0.093	7.282	14.425	11.197	14.440	4.461	0.620	0.007
TOTAL HOURS OF VALID OBSERVATIONS						2156.000			
TOTAL HOURS OF ELEVATED RELEASES						2016.490			
TOTAL HOURS OF STABILITY CLASS D						1182.010			
TOTAL HOURS OF ELEVATED STABILITY CLASS D						1132.430			

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	TOTAL
N	0.000	0.000	0.139	0.371	0.313	0.604	0.231	0.000	0.000	1.657
NNE	0.000	0.000	0.417	0.417	0.398	1.661	0.460	0.029	0.000	3.383
NE	0.000	0.000	0.278	0.881	0.442	1.132	0.115	0.000	0.000	2.849
ENE	0.000	0.046	0.232	0.417	0.578	0.488	0.000	0.000	0.000	1.762
E	0.000	0.000	0.464	0.928	0.401	0.283	0.037	0.029	0.000	2.141
ESE	0.000	0.186	0.232	0.788	0.497	1.822	0.113	0.077	0.000	3.715
SE	0.000	0.000	0.278	0.557	0.675	0.528	0.037	0.018	0.000	2.093
SSE	0.000	0.000	0.510	0.742	0.537	0.592	0.151	0.000	0.000	2.532
S	0.000	0.139	0.325	0.788	0.269	0.576	0.038	0.000	0.000	2.135
SSW	0.000	0.000	0.325	0.881	0.130	0.573	0.000	0.000	0.000	1.910
SW	0.000	0.046	0.557	0.742	0.134	0.082	0.000	0.000	0.000	1.561
WSW	0.000	0.000	0.510	0.742	0.089	0.125	0.000	0.000	0.000	1.466
W	0.000	0.139	0.325	0.510	0.134	0.409	0.000	0.000	0.000	1.516
WNW	0.000	0.000	0.139	0.186	0.179	0.081	0.038	0.000	0.000	0.623
NW	0.000	0.000	0.232	0.232	0.224	0.250	0.000	0.034	0.000	0.973
NNW	0.000	0.000	0.093	0.278	0.312	0.166	0.000	0.000	0.000	0.849
SUBTOTAL	0.000	0.557	5.056	9.462	5.312	9.372	1.219	0.187	0.000	31.165

TOTAL HOURS OF VALID OBSERVATIONS

TOTAL HOURS OF ELEVATED RELEASES

TOTAL HOURS OF STABILITY CLASS E

TOTAL HOURS OF ELEVATED STABILITY CLASS E

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2002/12/03

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5< DELTA T<= 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.186	0.139	0.220	0.412	0.000	0.000	0.957
NNE	0.000	0.000	0.139	0.046	0.134	1.173	0.115	0.000	1.608
NE	0.000	0.000	0.046	0.139	0.135	0.769	0.038	0.000	1.128
ENE	0.000	0.046	0.093	0.139	0.179	0.332	0.000	0.000	0.789
E	0.000	0.000	0.046	0.046	0.177	0.500	0.000	0.000	0.769
ESE	0.000	0.000	0.046	0.093	0.046	0.359	0.000	0.000	0.545
SE	0.000	0.000	0.000	0.186	0.044	0.000	0.000	0.000	0.229
SSE	0.000	0.000	0.093	0.232	0.043	0.000	0.000	0.000	0.368
S	0.000	0.046	0.000	0.093	0.000	0.000	0.000	0.000	0.139
SSW	0.000	0.000	0.046	0.000	0.136	0.084	0.000	0.000	0.267
SW	0.000	0.000	0.046	0.186	0.000	0.000	0.000	0.000	0.232
WSW	0.000	0.000	0.046	0.000	0.045	0.000	0.000	0.000	0.092
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.093
NWW	0.000	0.000	0.046	0.139	0.132	0.167	0.000	0.000	0.484
SUBTOTAL	0.000	0.093	0.835	1.484	1.339	3.795	0.154	0.000	7.700
TOTAL HOURS OF VALID OBSERVATIONS					2156.000				
TOTAL HOURS OF ELEVATED RELEASES					2016.490				
TOTAL HOURS OF STABILITY CLASS F					180.080				
TOTAL HOURS OF ELEVATED STABILITY CLASS F					166.010				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.161	0.000	0.000	0.161
NNE	0.000	0.000	0.000	0.046	0.000	0.122	0.000	0.000	0.168
NE	0.000	0.000	0.000	0.000	0.088	0.082	0.000	0.000	0.169
ENE	0.000	0.000	0.000	0.000	0.045	0.000	0.000	0.000	0.045
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.046	0.046	0.133	0.365	0.000	0.000	0.590
TOTAL HOURS OF VALID OBSERVATIONS					2156.000				
TOTAL HOURS OF ELEVATED RELEASES					2016.490				
TOTAL HOURS OF STABILITY CLASS G					16.620				
TOTAL HOURS OF ELEVATED STABILITY CLASS G					12.730				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 21

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR SPLIT LEVEL RELEASES
(ELEVATED PORTION)
FOURTH QUARTER

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)				12.5-18.4	>=24.5	TOTAL
		3.5-5.4	5.5-7.4	7.5-12.4	18.5-24.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
TOTAL HOURS OF VALID OBSERVATIONS				2163.000				
TOTAL HOURS OF ELEVATED RELEASES				1895.270				
TOTAL HOURS OF STABILITY CLASS A				4.850				
TOTAL HOURS OF ELEVATED STABILITY CLASS A				0.000				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45-30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45-74 METER LEVEL
 WIND SPEED MEASURED AT 45-74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

TOTAL HOURS OF VALID OBSERVATIONS

2163.000

TOTAL HOURS OF ELEVATED RELEASES

1895.270

TOTAL HOURS OF STABILITY CLASS B

5.040

TOTAL HOURS OF ELEVATED STABILITY CLASS B

0.000

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS

WIND DIRECTION MEASURED AT 45.74 METER LEVEL

WIND SPEED MEASURED AT 45.74 METER LEVEL

EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.035	0.035
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
SUBTOTAL	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.035	0.000

TOTAL HOURS OF VALID OBSERVATIONS

2163.000

1895.270

TOTAL HOURS OF ELEVATED RELEASES

11.780

2.760

TOTAL HOURS OF STABILITY CLASS C

TOTAL HOURS OF ELEVATED STABILITY CLASS C

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS

WIND DIRECTION MEASURED AT 45.74 METER LEVEL

WIND SPEED MEASURED AT 45.74 METER LEVEL

EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <=-0.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.185	0.416	0.669	1.953	1.137	0.167	0.000
NNE	0.000	0.000	0.139	0.693	0.798	1.460	0.306	0.033	0.000
NE	0.000	0.000	0.092	0.693	0.671	0.607	0.000	0.043	0.000
ENE	0.000	0.000	0.139	0.231	0.223	0.208	0.075	0.000	0.000
E	0.000	0.000	0.231	0.462	0.489	0.164	0.038	0.000	0.000
ESE	0.000	0.000	0.139	0.416	1.024	0.977	0.112	0.012	0.000
SE	0.000	0.000	0.231	0.509	0.669	1.344	1.274	0.381	0.042
SSE	0.000	0.000	0.416	0.601	0.539	1.212	1.317	0.210	0.006
S	0.000	0.046	0.370	0.370	0.133	1.526	0.712	0.249	0.009
SSW	0.000	0.000	0.185	0.509	0.223	0.605	0.263	0.120	0.028
SW	0.000	0.000	0.601	0.462	0.043	0.686	0.152	0.000	0.000
WSW	0.000	0.000	0.231	0.462	0.136	0.720	0.379	0.000	0.000
W	0.000	0.046	0.139	0.509	0.404	1.220	0.600	0.078	0.000
NNW	0.000	0.046	0.185	0.555	0.488	1.510	0.977	0.440	0.008
NW	0.000	0.046	0.277	0.555	0.713	1.418	1.608	0.267	0.000
NNW	0.000	0.000	0.277	0.832	0.706	2.250	2.067	0.170	0.000
SUBTOTAL	0.000	0.185	3.837	8.276	7.928	17.861	11.017	2.170	0.093
TOTAL HOURS OF VALID OBSERVATIONS				2163.000					
TOTAL HOURS OF ELEVATED RELEASES				1895.270					
TOTAL HOURS OF STABILITY CLASS D				1226.710					
TOTAL HOURS OF ELEVATED STABILITY CLASS D				1111.060					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T < 1.5 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.092	0.139	0.370	0.406	1.061	0.228	0.000	0.000
NNE	0.000	0.046	0.092	0.416	0.618	1.216	0.075	0.024	0.000
NE	0.000	0.000	0.092	0.185	0.404	0.243	0.075	0.027	0.000
ENE	0.000	0.092	0.277	0.324	0.221	0.247	0.037	0.000	0.000
E	0.000	0.000	0.139	0.231	0.536	0.245	0.037	0.000	0.000
ESE	0.000	0.000	0.046	0.324	0.571	0.661	0.150	0.012	0.000
SE	0.000	0.046	0.277	0.416	0.794	1.070	0.564	0.385	0.043
SSE	0.000	0.000	0.277	0.647	0.675	0.676	0.790	0.410	0.014
S	0.000	0.046	0.324	0.509	0.496	0.878	0.905	0.254	0.008
SSW	0.000	0.000	0.370	0.462	0.488	0.406	0.112	0.050	0.012
SW	0.000	0.046	0.509	0.370	0.353	0.247	0.000	0.000	1.525
WSW	0.000	0.046	0.231	0.370	0.315	0.408	0.000	0.000	0.000
W	0.000	0.092	0.092	0.324	0.183	0.119	0.153	0.000	0.963
NNW	0.000	0.139	0.185	0.092	0.043	0.043	0.037	0.000	0.540
NW	0.000	0.000	0.139	0.185	0.266	0.200	0.077	0.000	0.866
NNW	0.000	0.000	0.185	0.231	0.659	1.137	0.227	0.000	2.439
SUBTOTAL	0.000	0.647	3.375	5.455	7.028	8.857	3.468	1.160	0.078
TOTAL HOURS OF VALID OBSERVATIONS				2163.000					
TOTAL HOURS OF ELEVATED RELEASES				1895.270					
TOTAL HOURS OF STABILITY CLASS E				738.670					
TOTAL HOURS OF ELEVATED STABILITY CLASS E				650.390					

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA T <= 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.046	0.046	0.413	0.000	0.000	0.506
NNE	0.000	0.000	0.092	0.092	0.087	0.279	0.000	0.000	0.551
NE	0.000	0.000	0.000	0.000	0.224	0.126	0.000	0.000	0.350
ENE	0.000	0.000	0.046	0.000	0.000	0.082	0.000	0.000	0.128
E	0.000	0.000	0.000	0.000	0.087	0.000	0.000	0.000	0.087
ESE	0.000	0.000	0.092	0.092	0.046	0.207	0.000	0.000	0.438
SE	0.000	0.000	0.139	0.139	0.491	0.248	0.000	0.032	0.000
SSE	0.000	0.000	0.046	0.324	0.088	0.000	0.000	0.000	0.458
S	0.000	0.000	0.092	0.277	0.228	0.041	0.000	0.000	0.639
SSW	0.000	0.000	0.046	0.324	0.178	0.042	0.000	0.000	0.589
SW	0.000	0.000	0.000	0.185	0.000	0.000	0.000	0.000	0.185
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.092	0.045	0.000	0.000	0.000	0.137
WNW	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
NW	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
NNW	0.000	0.000	0.000	0.000	0.280	0.000	0.000	0.000	0.280
SUBTOTAL	0.000	0.000	0.601	1.618	1.519	1.718	0.000	0.032	5.489
TOTAL HOURS OF VALID OBSERVATIONS					2163.000				
TOTAL HOURS OF ELEVATED RELEASES					1895.270				
TOTAL HOURS OF STABILITY CLASS F					153.490				
TOTAL HOURS OF ELEVATED STABILITY CLASS F					118.720				

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)				>=24.5	TOTAL
		0-6-1.4	1.5-3.4	3.5-5.4	5.5-7.4		
N	0.000	0.000	0.000	0.000	0.000	0.123	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.039	0.000
NE	0.000	0.000	0.000	0.000	0.131	0.000	0.131
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.046	0.000	0.000	0.000	0.046
SE	0.000	0.000	0.000	0.000	0.046	0.000	0.046
SSE	0.000	0.000	0.000	0.092	0.000	0.000	0.092
S	0.000	0.046	0.000	0.046	0.000	0.000	0.092
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.046	0.046	0.139	0.177	0.162	0.000
TOTAL HOURS OF VALID OBSERVATIONS						2163.000	
TOTAL HOURS OF ELEVATED RELEASES						1895.270	
TOTAL HOURS OF STABILITY CLASS G						22.460	
TOTAL HOURS OF ELEVATED STABILITY CLASS G						12.340	

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.74 METER LEVEL
 WIND SPEED MEASURED AT 45.74 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 22

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR ELEVATED RELEASES
FIRST QUARTER

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED(MPH)				18.5-24.4	>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS A

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2132

0

0

2120

0

TOTAL HOURS CALM	0
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A	0
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2120
TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2132

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 0.00

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/05/15

E2-99

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				18.5-24.4	>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4			
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2132

0

0

2120

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVELTOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALM

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

DATE PRINTED: 2002/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <= -1.5 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.047
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.047	0.000
TOTAL HOURS OF VALID STABILITY OBSERVATIONS						2132			
TOTAL HOURS OF STABILITY CLASS C						3			
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C						3			
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS						2120			
TOTAL HOURS CALM						0			

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 10.90

DATE PRINTED: 2002/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.047	0.000	0.189	0.236	2.500	3.208	0.708	0.189
NNE	0.000	0.000	0.094	0.047	0.377	2.783	1.557	0.142	0.000
NE	0.000	0.000	0.047	0.142	0.236	0.896	0.236	0.000	1.557
ENE	0.000	0.000	0.094	0.047	0.047	0.236	0.094	0.000	0.519
E	0.000	0.000	0.094	0.142	0.142	0.330	0.094	0.047	0.849
ESE	0.000	0.000	0.142	0.189	0.236	0.660	0.330	0.330	0.047
SE	0.000	0.000	0.094	0.377	0.519	0.425	0.189	0.236	2.075
SSE	0.000	0.000	0.236	0.377	0.283	0.377	0.519	0.613	0.000
S	0.000	0.047	0.283	0.142	0.047	0.660	1.840	0.896	0.283
SSW	0.000	0.000	0.142	0.330	0.094	0.708	1.462	0.566	0.142
SW	0.000	0.000	0.236	0.236	0.047	0.472	0.566	0.142	0.000
WSW	0.000	0.000	0.094	0.142	0.236	0.377	0.236	0.236	1.321
W	0.000	0.000	0.094	0.142	0.425	0.991	0.708	0.377	0.094
WNW	0.000	0.000	0.047	0.189	0.283	1.509	2.170	1.415	0.566
NW	0.000	0.000	0.047	0.094	0.189	0.849	2.170	1.934	0.236
NNW	0.000	0.000	0.000	0.047	0.142	1.509	2.689	0.566	0.142
SUBTOTAL	0.000	0.094	1.745	2.830	3.538	15.283	18.066	8.208	51.698

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
TOTAL HOURS OF STABILITY CLASS D
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALM

2132
1100
1096
2120
0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 13.42

DATE PRINTED: 2002/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T<= 1.5 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)						>=24.5	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.094	0.047	0.094	0.896	1.321	0.047	0.000
NNE	0.000	0.000	0.047	0.142	0.189	0.613	1.038	0.094	0.000
NE	0.000	0.000	0.236	0.142	0.142	0.472	0.377	0.047	0.000
ENE	0.000	0.000	0.142	0.236	0.094	0.660	0.425	0.047	0.000
E	0.000	0.000	0.094	0.094	0.142	0.472	0.142	0.000	0.943
ESE	0.000	0.000	0.142	0.094	0.189	0.472	0.236	0.142	0.000
SE	0.000	0.000	0.189	0.047	0.283	1.038	0.755	0.472	0.330
SSE	0.000	0.000	0.000	0.142	0.142	1.462	2.453	1.509	6.274
S	0.000	0.000	0.047	0.189	0.283	2.594	4.340	2.075	0.566
SSW	0.000	0.000	0.142	0.142	0.377	0.991	1.462	0.519	0.283
SW	0.000	0.000	0.094	0.189	0.189	0.566	0.708	0.047	1.792
WSW	0.000	0.000	0.047	0.094	0.189	0.283	0.283	0.000	0.896
W	0.000	0.000	0.047	0.094	0.000	0.613	0.330	0.000	1.085
WNW	0.000	0.000	0.000	0.094	0.094	0.472	0.189	0.000	0.849
NW	0.000	0.000	0.047	0.142	0.330	0.189	0.377	0.142	0.000
NNW	0.000	0.000	0.047	0.047	0.236	0.472	0.849	0.094	1.226
SUBTOTAL	0.000	0.000	1.415	1.934	2.972	12.264	15.283	5.236	41.179

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
 TOTAL HOURS OF STABILITY CLASS E
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM

2132
881
873
2120
0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 13.54

DATE PRINTED: 2002/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA T <= 4.0 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	TOTAL
N	0.000	0.000	0.000	0.000	0.047	0.094	0.094	0.000	0.000	0.236
NNE	0.000	0.000	0.000	0.000	0.000	0.094	0.142	0.000	0.000	0.236
NE	0.000	0.000	0.047	0.047	0.047	0.189	0.236	0.047	0.000	0.613
ENE	0.000	0.000	0.000	0.047	0.000	0.189	0.047	0.000	0.000	0.283
E	0.000	0.000	0.047	0.094	0.142	0.000	0.047	0.000	0.000	0.330
ESE	0.000	0.000	0.000	0.000	0.000	0.094	0.047	0.000	0.000	0.142
SE	0.000	0.000	0.094	0.047	0.094	0.425	0.142	0.000	0.000	0.802
SSE	0.000	0.000	0.000	0.047	0.047	0.236	0.472	0.000	0.000	0.802
S	0.000	0.000	0.000	0.000	0.094	0.425	0.094	0.094	0.000	0.708
SSW	0.000	0.000	0.000	0.047	0.094	0.425	0.142	0.000	0.000	0.708
SW	0.000	0.000	0.000	0.000	0.047	0.000	0.094	0.000	0.000	0.142
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NRTW	0.000	0.000	0.000	0.000	0.047	0.047	0.047	0.000	0.000	0.142
SUBTOTAL	0.000	0.000	0.189	0.330	0.660	2.217	1.604	0.189	0.000	5.189

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 10.97

MEAN WIND SPEED = 10.97
NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE BBTNTED: 2002/05/15

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

JAN 1, 2002 - MAR 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.4	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.094	0.094	0.000	0.189
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.094	0.000	0.047	0.000	0.142
E	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.047	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.047	0.142	0.047	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.047	0.377	0.094	0.047
SSE	0.000	0.000	0.000	0.047	0.000	0.094	0.000	0.000	0.000
S	0.000	0.000	0.000	0.094	0.047	0.000	0.047	0.000	0.189
SSW	0.000	0.000	0.000	0.000	0.094	0.000	0.047	0.000	0.189
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.047
SUBTOTAL	0.000	0.000	0.000	0.142	0.377	0.755	0.425	0.094	1.792

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS G

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2132

38

38

2120

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 10.36

DATE PRINTED: 2002/05/15

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 23

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR ELEVATED RELEASES
SECOND QUARTER

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=1.9 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)						>=24.5
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2145
0TOTAL HOURS OF STABILITY CLASS A
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALMMETEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 0.00

DATE PRINTED: 2002/08/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <=-1.7 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS B

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2134
TOTAL HOURS CALM	0

2145

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 0.00

DATE PRINTED: 2002/08/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1.7 < DELTA T <= -1.5 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)						>=24.5	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.000	0.047
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.047	0.000	0.000	0.000	0.000	0.047
SSW	0.000	0.000	0.000	0.000	0.047	0.047	0.000	0.000	0.047
SW	0.000	0.000	0.000	0.047	0.000	0.047	0.000	0.000	0.094
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.047
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.094	0.000	0.141	0.000	0.000	0.047	0.281

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS C

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C

2145

6

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2134

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 12.33

DATE PRINTED: 2002/08/06

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA_T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.141	0.281	0.984	2.015	1.172	0.047
NNE	0.000	0.000	0.047	0.187	0.234	1.687	1.265	0.281	3.702
NE	0.000	0.000	0.000	0.187	0.141	0.750	0.328	0.000	1.406
ENE	0.000	0.000	0.047	0.141	0.187	0.375	0.000	0.000	0.750
E	0.000	0.000	0.047	0.000	0.000	0.281	0.047	0.000	0.375
ESE	0.000	0.000	0.094	0.141	0.515	3.140	1.781	0.234	0.000
SE	0.000	0.000	0.094	0.422	0.890	2.156	1.968	1.500	0.187
SSE	0.000	0.000	0.234	0.515	0.703	1.687	1.218	0.422	0.281
S	0.000	0.000	0.375	0.328	0.422	1.359	1.453	0.750	0.141
SSW	0.000	0.000	0.187	0.656	0.281	1.640	1.781	1.125	0.187
SW	0.000	0.000	0.515	0.515	0.234	0.984	1.312	0.375	0.000
WSW	0.000	0.000	0.375	0.703	0.281	0.141	0.141	0.281	0.094
W	0.000	0.000	0.375	0.422	0.422	0.281	0.047	0.000	0.000
WNW	0.000	0.000	0.047	0.515	0.515	0.937	0.187	0.000	0.047
NW	0.000	0.000	0.047	0.469	0.609	1.500	0.562	0.094	0.094
NNW	0.000	0.047	0.000	0.047	0.187	0.609	0.656	0.469	0.047
SUBTOTAL.	0.000	0.047	2.484	5.389	5.904	18.510	14.761	6.701	1.125
									54.920

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
 TOTAL HOURS OF STABILITY CLASS D
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM

2145
 1180
 1172
 2134
 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL,

MEAN WIND SPEED = 11.82

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	0-6-1.4	1.5-3.4	WIND SPEED (MPH)				18.5-24.4	>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4			
N	0.000	0.000	0.000	0.047	0.234	0.187	0.609	0.281	0.000	1.359
NNE	0.000	0.047	0.047	0.000	0.328	0.890	0.843	0.141	0.000	2.296
NE	0.000	0.000	0.000	0.094	0.234	0.843	0.656	0.234	0.000	2.062
ENE	0.000	0.000	0.000	0.000	0.094	0.609	0.328	0.187	0.000	1.218
E	0.000	0.000	0.141	0.094	0.281	0.656	0.234	0.000	0.000	1.406
ESE	0.000	0.047	0.000	0.234	0.281	1.359	1.734	0.000	0.000	3.655
SE	0.000	0.000	0.141	0.281	0.422	1.453	1.828	0.328	0.141	4.592
SSE	0.000	0.000	0.187	0.234	0.422	1.687	0.984	0.562	0.422	4.499
S	0.000	0.000	0.234	0.094	0.234	1.500	1.500	0.422	0.094	4.077
SSW	0.000	0.047	0.000	0.141	0.375	0.515	1.172	0.656	0.000	2.905
SW	0.000	0.047	0.234	0.094	0.234	0.469	0.281	0.047	0.000	1.406
WSW	0.000	0.000	0.328	0.234	0.094	0.515	0.187	0.000	0.000	1.359
W	0.000	0.047	0.141	0.234	0.187	0.281	0.141	0.000	0.000	1.031
WNW	0.000	0.000	0.187	0.375	0.281	0.328	0.047	0.000	0.000	1.218
NW	0.000	0.047	0.234	0.094	0.141	0.141	0.234	0.047	0.000	0.937
NNW	0.000	0.000	0.094	0.047	0.141	0.281	0.234	0.047	0.000	0.843
SUBTOTAL	0.000	0.281	1.968	2.296	3.983	11.715	11.012	2.952	0.656	34.864

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS E

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

TOTAL HOURS CALM

2145
747
744
2134
0METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 11.68

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

E2-111

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5 < DELTA_T <= 4.0 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)			>=24.5			TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.000	0.000	0.047	0.000	0.047	0.000	0.047	0.094
NNE	0.000	0.000	0.000	0.000	0.000	0.187	0.422	0.694
NE	0.000	0.000	0.047	0.000	0.328	0.234	0.141	0.703
ENE	0.000	0.000	0.094	0.000	0.047	0.281	0.375	0.937
E	0.000	0.000	0.047	0.047	0.000	0.469	0.141	0.703
ESE	0.000	0.000	0.000	0.000	0.047	0.469	0.234	0.750
SE	0.000	0.000	0.000	0.094	0.094	0.375	0.187	0.000
SSE	0.000	0.000	0.047	0.000	0.234	0.187	0.515	0.984
S	0.000	0.000	0.047	0.047	0.000	0.422	0.562	1.078
SSW	0.000	0.000	0.047	0.047	0.141	0.234	0.187	0.656
SW	0.000	0.000	0.000	0.000	0.047	0.422	0.234	0.703
WSW	0.000	0.000	0.000	0.094	0.000	0.094	0.000	0.187
W	0.000	0.000	0.047	0.094	0.000	0.047	0.000	0.187
WNW	0.000	0.000	0.000	0.047	0.141	0.187	0.000	0.375
NW	0.000	0.000	0.000	0.000	0.000	0.047	0.000	0.047
NNW	0.000	0.000	0.000	0.094	0.047	0.047	0.000	0.234
SUBTOTAL	0.000	0.000	0.328	0.656	0.797	3.796	3.187	0.375
								9.138

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2145
 TOTAL HOURS OF STABILITY CLASS F 195
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F 195
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2134
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL
 MEAN WIND SPEED = 11.21

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

APR 1, 2002 - JUN 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)				>=24.5	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.047	0.047	0.094
NE	0.000	0.000	0.000	0.000	0.094	0.094	0.094
ENE	0.000	0.000	0.000	0.000	0.047	0.047	0.047
E	0.000	0.000	0.000	0.000	0.000	0.141	0.141
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.047	0.000	0.047
S	0.000	0.000	0.000	0.000	0.094	0.000	0.141
SSW	0.000	0.000	0.000	0.094	0.000	0.000	0.094
SW	0.000	0.000	0.047	0.000	0.047	0.000	0.094
WSW	0.000	0.000	0.047	0.000	0.000	0.000	0.047
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.047	0.141	0.234	0.187	0.000
						0.797	0.000

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2145
 TOTAL HOURS OF STABILITY CLASS G 17
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G 17
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2134
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 8.85

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/08/06

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 24

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR ELEVATED RELEASES
THIRD QUARTER

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.139	0.000	0.139
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.139	0.000	0.000	0.139

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2189
3
3
2157
0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.70

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <= -1.7 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)				>=24.5	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.046	0.000	0.185	0.232
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.046	0.000	0.185	0.232

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2189

TOTAL HOURS OF STABILITY CLASS B

5

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B

5

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2157

TOTAL HOURS CALM

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 8.12

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS C (-1.7 < DELTA T <= -1.5 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.093	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.046
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.046	0.046	0.278	0.000	0.000	0.371
SW	0.000	0.000	0.000	0.000	0.139	0.325	0.000	0.000	0.464
WSW	0.000	0.000	0.000	0.046	0.046	0.046	0.000	0.000	0.093
W	0.000	0.000	0.000	0.093	0.093	0.000	0.000	0.000	0.185
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.046	0.371	0.742	0.093	0.000	1.252

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2189
27
27
2157
0

TOTAL HOURS OF STABILITY CLASS C
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 8.55

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

E2-117

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1.5 < DELTA_T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.325	0.556	0.139	0.742	0.974	0.000	0.000
NNE	0.000	0.000	0.185	0.232	0.464	0.974	0.881	0.046	0.000
NE	0.000	0.000	0.093	0.185	0.232	0.278	0.371	0.000	1.159
ENE	0.000	0.000	0.232	0.232	0.000	0.185	0.325	0.000	0.974
E	0.000	0.000	0.139	0.093	0.139	0.278	0.139	0.046	0.000
ESE	0.000	0.000	0.093	0.325	0.278	1.066	0.881	0.046	0.000
SE	0.000	0.000	0.371	1.020	1.066	1.854	2.086	1.066	0.139
SSE	0.000	0.000	0.742	1.298	1.669	2.411	1.391	0.649	0.046
S	0.000	0.046	0.788	1.344	0.834	2.364	0.649	0.139	0.093
SSW	0.000	0.000	1.020	0.834	0.881	1.808	0.834	0.232	0.046
SW	0.000	0.000	0.834	1.113	0.742	1.484	0.046	0.000	4.219
WSW	0.000	0.000	0.371	1.623	1.113	0.417	0.000	0.000	3.523
W	0.000	0.000	0.232	0.742	1.205	0.881	0.093	0.000	3.153
WNW	0.000	0.000	0.417	0.464	0.927	1.113	0.000	0.000	2.921
NW	0.000	0.000	0.185	0.232	0.464	1.205	0.093	0.000	2.179
NNW	0.000	0.046	0.185	0.093	0.232	0.603	0.325	0.046	1.530
SUBTOTAL	0.000	0.093	6.212	10.385	10.385	17.663	9.087	2.272	0.325

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2189

TOTAL HOURS OF STABILITY CLASS D

1233

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D

1217

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2157

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 8.71

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5< DELTA T<= 1.5 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)						>=24.5	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.185	0.371	0.139	0.417	0.695	0.046	0.000
NNE	0.000	0.000	0.139	0.093	0.325	0.742	1.484	0.371	0.000
NE	0.000	0.000	0.139	0.232	0.371	0.742	1.020	0.278	0.000
ENE	0.000	0.000	0.046	0.185	0.325	0.834	0.556	0.000	1.947
E	0.000	0.000	0.000	0.232	0.325	0.046	0.371	0.185	0.000
ESE	0.000	0.000	0.000	0.232	0.371	0.325	1.113	0.974	0.093
SE	0.000	0.093	0.371	0.927	0.649	0.974	0.788	0.000	0.046
SSE	0.000	0.000	0.139	0.510	0.603	0.927	0.139	0.046	0.000
S	0.000	0.139	0.093	0.464	0.556	0.603	0.417	0.000	2.272
SSW	0.000	0.000	0.371	0.556	0.325	0.464	0.603	0.000	2.318
SW	0.000	0.000	0.232	0.649	0.278	0.556	0.046	0.000	1.762
WSW	0.000	0.000	0.232	0.649	0.278	0.232	0.046	0.000	1.437
W	0.000	0.000	0.232	0.742	0.464	0.417	0.139	0.000	1.994
WNW	0.000	0.000	0.046	0.139	0.232	0.139	0.232	0.000	0.788
NW	0.000	0.046	0.139	0.139	0.232	0.510	0.046	0.000	1.159
NNW	0.000	0.000	0.139	0.278	0.139	0.232	0.046	0.000	0.834
SUBTOTAL	0.000	0.278	2.967	6.630	5.285	9.272	7.418	0.881	33.055

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2189
726
713
2157
0TOTAL HOURS OF STABILITY CLASS E
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALMMETEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.05

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS F (1.5 < DELTA-T <= 4.0 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.093	0.000	0.371	0.371	0.000	0.834
NNE	0.000	0.000	0.000	0.139	0.232	0.927	0.185	0.000	1.623
NE	0.000	0.000	0.000	0.046	0.000	0.278	0.556	0.325	1.205
ENE	0.000	0.000	0.093	0.046	0.000	0.185	0.417	0.046	0.788
E	0.000	0.000	0.046	0.046	0.185	0.417	0.093	0.000	0.788
ESE	0.000	0.046	0.046	0.000	0.185	0.278	0.371	0.000	0.927
SE	0.000	0.000	0.000	0.093	0.093	0.093	0.139	0.000	0.417
SSE	0.000	0.046	0.046	0.046	0.185	0.093	0.000	0.000	0.417
S	0.000	0.000	0.046	0.000	0.139	0.139	0.000	0.000	0.325
SSW	0.000	0.000	0.000	0.000	0.093	0.139	0.093	0.000	0.325
SW	0.000	0.000	0.046	0.046	0.000	0.093	0.000	0.000	0.185
WSW	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
W	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
WNW	0.000	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.046
NW	0.000	0.000	0.000	0.000	0.093	0.093	0.000	0.000	0.093
NNW	0.000	0.000	0.000	0.046	0.000	0.093	0.000	0.000	0.185
SUBTOTAL	0.000	0.093	0.325	0.695	1.066	2.457	3.060	0.556	8.252

TOTAL HOURS OF VALID STABILITY OBSERVATIONS
 TOTAL HOURS OF STABILITY CLASS F
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
 TOTAL HOURS CALM

2189
 180
 178
 2157
 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 11.12

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

JUL 1, 2002 - SEP 30, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)				>=24.5	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4		
N	0.000	0.000	0.000	0.000	0.000	0.046	0.046
NNE	0.000	0.000	0.000	0.000	0.000	0.046	0.046
NE	0.000	0.000	0.000	0.000	0.000	0.139	0.000
ENE	0.000	0.000	0.000	0.000	0.046	0.000	0.046
E	0.000	0.000	0.000	0.000	0.185	0.000	0.185
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.046	0.000	0.000	0.000	0.046
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.046	0.046
SUBTOTAL	0.000	0.000	0.046	0.000	0.000	0.232	0.139
						0.000	0.649

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2189
 TOTAL HOURS OF STABILITY CLASS G 15
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G 14
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2157
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 13.66

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2002/12/03

RADIOLOGICAL IMPACT ASSESSMENT
BROWNS FERRY NUCLEAR PLANT
JANUARY - DECEMBER 2002

TABLE 25

JOINT FREQUENCY DISTRIBUTION IN PERCENT
FOR ELEVATED RELEASES
FOURTH QUARTER

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T<=-1.9 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2186
 TOTAL HOURS OF STABILITY CLASS A 0
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A 0
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2176
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 0.00

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (-1.9 < DELTA T <= -1.7 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2186
 TOTAL HOURS OF STABILITY CLASS B 0
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B 0
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2176
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 0.00

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS C (-1.7 < DELTA T <=-1.5 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
E	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSW	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.046
SW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.046	0.046
WNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.000	0.046
SUBTOTAL	0.000	0.000	0.000	0.046	0.046	0.000	0.000	0.046	0.000

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2186
 TOTAL HOURS OF STABILITY CLASS C 3
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C 3
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2176
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 11.13

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR
 STABILITY CLASS D (-1.5 < DELTA T <= -0.5 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.046	0.276	0.597	2.022	1.471	0.414	0.000
NNE	0.000	0.000	0.138	0.506	0.551	1.654	0.827	0.046	0.000
NE	0.000	0.046	0.046	0.276	0.643	0.827	0.368	0.000	3.722
ENE	0.000	0.000	0.138	0.046	0.138	0.368	0.092	0.092	2.298
E	0.000	0.000	0.000	0.000	0.368	0.276	0.643	0.138	0.000
ESE	0.000	0.000	0.046	0.276	0.689	1.425	0.551	0.046	0.092
SE	0.000	0.000	0.230	0.230	0.506	1.103	1.563	1.149	0.689
SSE	0.000	0.000	0.414	0.551	0.597	1.241	1.379	0.827	0.460
S	0.000	0.000	0.230	0.368	0.092	1.011	1.379	0.551	0.276
SSW	0.000	0.000	0.230	0.092	0.092	0.597	0.460	0.276	0.368
SW	0.000	0.000	0.184	0.873	0.184	0.551	0.643	0.046	0.000
WSW	0.000	0.000	0.276	0.368	0.230	0.276	0.919	0.230	0.000
W	0.000	0.000	0.138	0.551	0.368	1.057	0.873	0.735	0.138
WNW	0.000	0.000	0.276	0.414	0.322	1.700	1.057	1.011	0.138
NW	0.000	0.046	0.322	0.551	0.643	1.149	1.700	0.827	0.092
NNW	0.000	0.046	0.184	0.506	0.368	2.390	2.619	1.057	0.000
SUBTOTAL	0.000	0.138	2.895	6.250	6.296	18.015	16.039	7.353	2.344
TOTAL HOURS OF VALID STABILITY OBSERVATIONS								2186	
TOTAL HOURS OF STABILITY CLASS D								1296	
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D								1291	
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS								2176	
TOTAL HOURS CALM								0	

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 12.12

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 < DELTA T <= 1.5 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	WIND SPEED(MPH)				>=24.4	TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4		
N	0.000	0.000	0.046	0.276	0.138	1.057	0.965
NNE	0.000	0.092	0.092	0.184	0.184	1.149	0.965
NE	0.000	0.046	0.046	0.138	0.046	0.873	0.322
ENE	0.000	0.046	0.184	0.046	0.230	0.322	0.138
E	0.000	0.046	0.046	0.184	0.506	0.230	0.046
ESE	0.000	0.000	0.138	0.138	0.138	0.827	0.368
SE	0.000	0.000	0.322	0.138	0.230	1.195	0.368
SSE	0.000	0.092	0.322	0.092	0.368	1.195	0.781
S	0.000	0.092	0.230	0.322	0.460	0.597	1.057
SSW	0.000	0.046	0.138	0.092	0.460	0.827	0.414
SW	0.000	0.092	0.276	0.276	0.276	0.643	0.414
WSW	0.000	0.000	0.046	0.046	0.276	0.551	0.551
W	0.000	0.046	0.046	0.184	0.138	0.230	0.092
WNW	0.000	0.046	0.138	0.276	0.138	0.000	0.046
NW	0.000	0.046	0.092	0.230	0.092	0.368	0.276
NNW	0.000	0.092	0.092	0.138	0.506	0.735	0.092
SUBTOTAL	0.000	0.689	2.252	2.574	3.493	10.983	8.778
						3.401	2.022
							34.191

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2186

TOTAL HOURS OF STABILITY CLASS E

749

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E

744

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

2176

0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 12.00

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (1.5< DELTA T<= 4.0 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	WIND SPEED (MPH)			>=24.4			TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	
N	0.000	0.000	0.000	0.000	0.000	0.184	0.092	0.000
NNE	0.000	0.000	0.000	0.092	0.000	0.276	0.092	0.000
NE	0.000	0.000	0.046	0.046	0.000	0.138	0.046	0.000
ENE	0.000	0.000	0.092	0.000	0.046	0.092	0.092	0.322
E	0.000	0.000	0.092	0.000	0.000	0.000	0.000	0.092
ESE	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.046
SE	0.000	0.000	0.000	0.046	0.092	0.368	0.000	0.551
SSE	0.000	0.000	0.000	0.046	0.138	0.322	0.046	0.551
S	0.000	0.000	0.000	0.000	0.230	0.092	0.138	0.460
SSW	0.000	0.000	0.138	0.092	0.184	0.138	0.092	0.643
SW	0.000	0.000	0.138	0.092	0.138	0.322	0.000	0.689
WSW	0.000	0.000	0.046	0.046	0.184	0.184	0.000	0.460
W	0.000	0.000	0.000	0.000	0.046	0.138	0.000	0.184
WNW	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.046
NW	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
NNW	0.000	0.000	0.000	0.000	0.000	0.322	0.000	0.322
SUBTOTAL	0.000	0.000	0.597	0.506	1.149	2.114	1.195	5.744

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

2186
125
125
2176
0TOTAL HOURS OF STABILITY CLASS F
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS
TOTAL HOURS CALMMETEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant
STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.34

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

DATE PRINTED: 2003/02/07

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

Browns Ferry Nuclear Plant

OCT 1, 2002 - DEC 31, 2002

WIND DIRECTION	CALM	0.6-1.4	1.5-3.4	WIND SPEED (MPH)				>=24.5	TOTAL
				3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4		
N	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.138	0.000
NNE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.046	0.000
ENE	0.000	0.000	0.000	0.000	0.000	0.000	0.046	0.046	0.092
E	0.000	0.000	0.000	0.000	0.000	0.000	0.046	0.000	0.046
ESE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SSE	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
S	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.046
SSW	0.000	0.000	0.000	0.000	0.046	0.000	0.000	0.000	0.046
SW	0.000	0.000	0.000	0.000	0.092	0.000	0.000	0.000	0.092
WSW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
W	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
WNW	0.000	0.000	0.046	0.000	0.000	0.000	0.000	0.000	0.046
NW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
NNW	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SUBTOTAL	0.000	0.000	0.092	0.046	0.138	0.092	0.184	0.046	0.000

TOTAL HOURS OF VALID STABILITY OBSERVATIONS

TOTAL HOURS OF STABILITY CLASS G

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G

TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS

TOTAL HOURS CALM

2186
13
13
2176
0

METEOROLOGICAL FACILITY: Browns Ferry Nuclear Plant

STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT 90.29 METER LEVEL

MEAN WIND SPEED = 9.95

DATE PRINTED: 2003/02/07

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

ENCLOSURE 3

**TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT (BFN)
UNITS 1, 2, AND 3**

**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
JANUARY THROUGH DECEMBER 2002**

**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
YEAR 2002**

I. Regulatory and BFN ODCM Limits

A. Fission and Activation Gases in Gaseous Effluent:

The release of fission and activation gases is regulated by the dose limits of 10 CFR 50 Appendix I and BFN Offsite Dose Calculation Manual (ODCM). The air dose to areas at and beyond the site boundary due to noble gases released in gaseous effluents per unit, shall be limited during any calendar quarter to \leq 5 millirad (mrad) for gamma radiation and \leq 10 mrad for beta radiation; and during any calendar year to \leq 10 mrad for gamma radiation and \leq 20 mrad for beta radiation.

B. Iodines and Particulates with Half-Lives Greater than Eight Days in Gaseous Effluents.

The release of iodines and particulates in gaseous effluent is regulated by the dose limits of 10 CFR 50 Appendix I and the BFN ODCM. The dose to a member of the public from radioiodines, radioactive materials in particulate form, and radionuclides other than noble gases with half-lives greater than eight days in gaseous effluent released per unit to areas at and beyond the site boundary shall be limited to any organ during any calendar quarter to \leq 7.5 millirem (mrem), and during any calendar year to \leq 15 mrem.

C. Liquid Effluents

The release of radioactive liquid effluents is regulated by the dose limits of 10 CFR 50, Appendix I, and the BFN ODCM. The doses or dose commitment to a member of the public from radioactive materials in liquid effluents released from each unit to unrestricted areas shall be limited during any calendar quarter to \leq 1.5 mrem to the total body and \leq 5 mrem to any organ and during any calendar year to \leq 3 mrem to the total body and \leq 10 mrem to any organ.

II. Limitation on Dose Rate

A. Fission and Activation Gases in Gaseous Effluent:

1. The instantaneous release rate of fission and activation gases is based on the dose rate limits of 10 CFR 20.1301 and the BFN ODCM. The dose rate at any time to areas at and beyond the site boundary due to noble gases released in gaseous effluents from the site shall be limited to
 \leq 500 mrem per year to the total body and \leq 3000 mrem per year to the skin.

2. The BFN ODCM Section 7.2 determines the maximum noble gas release rate.

**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
YEAR 2002**

II. Limitations on Dose Rate (Continued)

B. Iodines and Particulates with Half-Lives Greater than Eight Days in gaseous effluents.

1. The instantaneous release rate of particulates and iodines is regulated by the dose rate limits of the BFN ODCM. The dose rate at any time to areas at and beyond the site boundary, due to I-131, I-133, H-3 and particulates with greater than eight days half-lives released in gaseous effluents from the site, shall be limited to ≤ 1500 mrem per year to any organ.
2. The BFN ODCM Section 7.3 determines the maximum particulate and iodine dose rates.

C. Liquid Effluents

1. The concentration of radionuclides in liquid effluents released at any time from the site to unrestricted areas shall be limited to the concentrations specified in 10 CFR 20.1001 - 20.2402, Appendix B, Table 2, Column 2 for radionuclides other than dissolved or entrained noble gases.
2. For dissolved or entrained noble gases, the concentration shall be limited to 2E-4 μCi per milliliter (ml) total activity.

III. Measurements and Approximations of Total Radioactivity

A. Fission and Activation Gases:

1. Noble gases in the building vent and stack (elevated) gaseous effluents are continuously monitored. The flow rate of the stack is continuously monitored and the building vent effluent flow rates are calculated once a shift based on the configuration of operating exhaust fans. The vent flow is calculated for each release. Gas grab samples of the stack are taken and analyzed weekly. Gas grab samples of in-service vents are taken and analyzed monthly. The specific noble gas activity concentrations and total volume of the gases are used to calculate the total curies of noble gases released.
2. The tritium concentration is determined by the analysis of a monthly grab sample for each release point.

**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
YEAR 2002**

III. Measurements and Approximations of Total Radioactivity (continued)

B. Iodines and Particulates

1. Iodines and particulates are continuously sampled on impregnated charcoal filters and particulate filters, respectively. The charcoal and particulate samples are replaced at least weekly and analyzed to determine specific activity concentrations. The specific activity concentrations and vent flow rate data are used weekly to verify that release rate limits were not exceeded. The specific activity concentrations and total volume of gaseous effluent are used on a monthly basis to determine the total curies of each particulate and iodine released during the month.
2. The gross alpha concentration is determined by analysis of a monthly particulate filter composite sample and strontium -89 and -90 are determined by analysis of a quarterly particulate filter composite sample for each release point.

C. Liquid Effluents

1. The gamma ray emitting radionuclide concentrations are determined for each batch by gamma ray spectroscopy analysis of a grab sample. The allowable release rate is calculated for each batch based upon the known dilution flow. The flow rate of the liquid effluent is continuously monitored and the total volume released in each batch is determined. The total gamma activity released in each batch is determined by multiplying the radionuclide concentrations by the total volume discharged. The total gamma activity released during the month is then determined by summing the gamma activity content of each batch discharged during the month.
 2. The gross alpha and tritium concentrations are measured on a monthly composite sample. The strontium -89 and -90 and iron -55 are measured on a quarterly composite sample.
- D. The Radioactive Gaseous and Liquid Waste Monitoring Sampling and Analysis Program is specified in ODCM Sections 1/2.2.1 and 1/2.2.2.**

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
SUPPLEMENTAL INFORMATION
2002

IV. Batch

	Units	<u>Quarter</u>			
		<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>
A. Liquid					
1. Number of batches released	Each	0	0	0	0
2. Total time for batches released	Minutes	0	0	0	0
3. Maximum time period for a batch release	Minutes	0	0	0	0
4. Average time period for a batch release	Minutes	0	0	0	0
5. Minimum time period for a batch release	Minutes	0	0	0	0
6. Average stream flow during period of release into a flowing stream	Cubic feet per second	0	0	0	0

B. Gaseous

None

C. Abnormal/Unplanned Releases*

Type	Number of Releases	Total Activity Releases (Curies)
Liquid	None	None
Gaseous	None	None

* An explanation of any liquid or gaseous abnormal/unexplained release shall be documented in the summary.

**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES
YEAR 2002**

	<u>Units</u>	<u>Quarter</u> <u>1</u>	<u>Quarter</u> <u>2</u>	<u>Quarter</u> <u>3</u>	<u>Quarter</u> <u>4</u>	<u>Error</u> <u>%</u>
A. Fission and Activation Products (Does not include tritium, gases, Alpha)						
1. Total Release	Curies	NR*	NR	NR	NR	9
2. Average Diluted Concentration Released During Period	µCi/ml	NR	NR	NR	NR	
3. Percent of Applicable Limit	%	**	**	**	**	
B. Tritium						
1. Total Releases	Curies	NR	NR	NR	NR	6
2. Average Diluted Concentration Released During Period	µCi/ml	NR	NR	NR	NR	
3. Percent of Applicable Limit	%	**	**	**	**	
C. Dissolved and Entrained Noble Gases						
1. Total Releases	Curies	NR	NR	NR	NR	8
2. Average Diluted Concentration Released During Period	µCi/ml	NR	NR	NR	NR	
3. Percent of Applicable Limit	%	**	**	**	**	
D. Gross Alpha Radioactivity						
1. Total Releases	Curies	NR	NR	NR	NR	48
2. Average Diluted Concentration Released During Period	µCi/ml	NR	NR	NR	NR	
E. Volume of Liquid Waste to Discharge Canal (Prior to dilution)	Liters	NR	NR	NR	NR	3
F. Volume of Dilution Water for Period	Liters	NR	NR	NR	NR	10
G. Total CCW	gigagallons	NR	NR	NR	NR	

*NR -- No liquid releases were made in the 1st 2nd 3rd and 4th quarters.

** The applicable limit is expressed in terms of dose. See Enclosure 1, Tables 5 through 8.

**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
LIQUID RELEASES FOR YEAR 2002 - BATCH MODE**

<u>CURIES</u>	<u>Isotope</u>	<u>Quarter</u>	<u>Quarter</u>	<u>Quarter</u>	<u>Quarter</u>
		<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>
(Required by Regulatory (REG) Guide 1.21)					
1.	Ba-140	NR*	NR	NR	NR
2.	Ce-141	NR	NR	NR	NR
3.	Co-58	NR	NR	NR	NR
4.	Co-60	NR	NR	NR	NR
5.	Cr-51	NR	NR	NR	NR
6.	Cs-134	NR	NR	NR	NR
7.	Cs-137	NR	NR	NR	NR
8.	Fe-59	NR	NR	NR	NR
9.	I-131	NR	NR	NR	NR
10.	La-140	NR	NR	NR	NR
11.	Mn-54	NR	NR	NR	NR
12.	Mo-99	NR	NR	NR	NR
13.	Nb-95	NR	NR	NR	NR
14.	Sr-89	NR	NR	NR	NR
15.	Sr-90	NR	NR	NR	NR
16.	Tc-99m	NR	NR	NR	NR
17.	Xe-133	NR	NR	NR	NR
18.	Xe-135	NR	NR	NR	NR
19.	Zn-65	NR	NR	NR	NR
20.	Zr-95	NR	NR	NR	NR

Others (Not Required by REG Guide 1.21)

NONE

*NR -- No liquid releases were made during the 1st 2nd 3rd and 4th quarters

**EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES
YEAR 2002**

	<u>Units</u>	<u>Quarter</u> <u>1</u>	<u>Quarter</u> <u>2</u>	<u>Quarter</u> <u>3</u>	<u>Quarter</u> <u>4</u>	<u>Error</u> <u>%</u>
A. Fission and Activation Gases						
1. Total Releases	Curies	1.59E+01	6.13E+01	1.20E+03	1.63E+03	45
2. Average Release Rate for Period	$\mu\text{Ci/sec}$	2.05E+00	7.79E+00	1.51E+02	2.05E+02	
3. Percent of Applicable Limit	%	*	*	*	*	*
B. Iodines						
1. Total Iodine-131	Curies	4.03E-03	8.73E-02	4.58E-03	1.80E-01	36
2. Average Release Rate for Period	$\mu\text{Ci/sec}$	5.18E-04	1.11E-02	5.77E-04	2.26E-02	
3. Percent of Applicable Limit	%	*	*	*	*	*
C. Particulates						
1. Particulates with half-lives > eight days	Curies	1.15E-03	1.13E-03	1.41E-03	2.42E-03	35
2. Average Release Rate for Period	$\mu\text{Ci/sec}$	1.48E-04	1.44E-04	1.78E-04	3.05E-04	
3. Percent of Applicable Limit	%	*	*	*	*	*
4. Gross Alpha Radioactivity	Curies	ND**	ND	ND	ND	
D. Tritium						
1. Total Release	Curies	3.10E+01	1.32E+01	1.06E+01	6.38E+01	21
2. Average Release Rate for Period	$\mu\text{Ci/sec}$	3.99E+00	1.67E+00	1.34E+00	8.02E+00	
3. Percent of Applicable Limit	%	*	*	*	*	*

*Applicable Limits are expressed in terms of dose. See Enclosure 1, Tables 1 through 4.

**ND – Not Detected.

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
YEAR 2002
GASEOUS EFFLUENTS - ELEVATED RELEASE

<u>CURIES</u>	<u>Quarter</u> <u>1</u>	<u>Quarter</u> <u>2</u>	<u>Quarter</u> <u>3</u>	<u>Quarter</u> <u>4</u>
1. Fission Gases				
Kr-85m	1.59E+01	2.59E+00	1.09E+02	2.03E+02
Kr-85	ND*	ND	ND	ND
Kr-87	ND	ND	ND	ND
Kr-88	ND	ND	4.51E+01	8.82E+01
Xe-133	ND	5.87E+01	1.04E+03	1.33E+03
Xe-135m	ND	ND	ND	ND
Xe-135	ND	ND	3.65E+00	3.63E+00
Xe-138	ND	ND	ND	ND
Others (specify)				
N-13	ND	ND	7.72 E+00	ND
Total for Period	<u>1.59E+01</u>	<u>6.12E+01</u>	<u>1.20E+03</u>	<u>1.63E+03</u>
2. Iodines				
I-131	2.44E-04	4.03E-03	5.31E-04	5.42E-03
I-133	2.11E-04	4.26E-04	2.61E-04	8.88E-04
Total for Period	<u>4.55E-04</u>	<u>4.46E-03</u>	<u>7.92E-04</u>	<u>6.31E-03</u>

*ND – Not Detected.

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
YEAR 2002
GASEOUS EFFLUENTS - ELEVATED RELEASE

<u>CURIES</u>	<u>Quarter</u> <u>1</u>	<u>Quarter</u> <u>2</u>	<u>Quarter</u> <u>3</u>	<u>Quarter</u> <u>4</u>
3. Particulates*				
Sr-89	9.95E-05	4.96E-05	8.66E-05	1.19E-04
Sr-90	ND**	ND	ND	ND
Cs-134	ND	2.51E-06	ND	ND
Cs-137	ND	2.05E-06	ND	ND
Ba-140	9.21E-05	4.58E-05	5.13E-05	7.60E-05
La-140	4.29E-05	1.62E-05	1.84E-05	2.32E-05
Others (specify)				
Rb-88	ND	ND	ND	1.32E-01
Rb-89	1.06E-01	2.21E-02	1.62E-01	3.25E-02
Sr-91	2.38E-04	3.18E-04	6.21E-05	3.65E-04
Y-91m	6.81E-04	5.02E-04	4.16E-04	5.98E-04
Cs-138	2.35E-01	7.66E-02	2.74E-01	9.60E-01
Ba-139	9.52E-02	5.60E-02	8.56E-02	1.21E-01
Au-199	2.16E-05	ND	ND	ND
<u>Total for Period*</u>	<u>4.37E-01</u>	<u>1.56E-01</u>	<u>5.23E-01</u>	<u>1.25E+00</u>
4. Tritium	<u>7.27E-01</u>	<u>9.62E-01</u>	<u>1.60E+00</u>	<u>1.84E+00</u>

*Includes all nuclides, even those with less than an eight day half-life.

**ND – Not Detected.

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
YEAR 2002
GASEOUS EFFLUENTS - GROUND RELEASE

<u>CURIES</u>	<u>Quarter</u> <u>1</u>	<u>Quarter</u> <u>2</u>	<u>Quarter</u> <u>3</u>	<u>Quarter</u> <u>4</u>
1. Fission Gases				
Kr-85m	ND*	ND	ND	ND
Kr-85	ND	ND	ND	ND
Kr-87	ND	ND	ND	ND
Kr-88	ND	ND	ND	ND
Xe-133	ND	ND	ND	ND
Xe-135m	ND	ND	ND	ND
Xe-135	ND	ND	ND	ND
Xe-138	ND	ND	ND	ND
Others(specify)				
NONE				
<u>Total for Period</u>	<u>ND</u>	<u>ND</u>	<u>ND</u>	<u>ND</u>

2. Iodines

I-131	1.88E-03	2.12E-03	1.01E-03	9.45E-03
I-132	ND	ND	ND	2.74E-04
I-133	4.20E-03	9.10E-04	1.03E-03	7.11E-03
I-135	ND	ND	ND	3.48E-04
<u>Total for Period</u>	<u>6.08E-03</u>	<u>3.03E-03</u>	<u>2.04E-03</u>	<u>1.72E-02</u>

*ND – Not Detected.

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
YEAR 2002
GASEOUS EFFLUENTS - GROUND RELEASE

3.	<u>CURIES</u> Particulates*	<u>Quarter</u>	<u>Quarter</u>	<u>Quarter</u>	<u>Quarter</u>
		<u>1</u>	<u>2</u>	<u>3</u>	<u>4</u>
	Sr-89	4.13E-05	1.45E-07	1.63E-05	1.15E-04
	Sr-90	ND**	ND	ND	ND
	Cs-134	ND	ND	ND	ND
	Cs-137	ND	ND	ND	ND
	Ba-140	6.54E-05	ND	ND	2.47E-05
	La-140	1.24E-05	ND	ND	ND
	Others (specify)				
	Cr-51	ND	4.02E-05	ND	ND
	Mn-54	1.22E-06	1.55E-05	ND	ND
	Co-60	ND	1.69E-05	ND	ND
	Sr-91	1.31E-04	ND	ND	ND
	Y-91m	1.42E-03	6.71E-06	6.11E-05	7.11E-04
	Cs-138	3.16E-02	1.39E-02	5.60E-02	3.68E-01
	Ba-139	2.71E-02	7.18E-04	8.67E-03	3.98E-02
	<u>Total for Period*</u>	<u>6.04E-02</u>	<u>1.47E-02</u>	<u>6.47E-02</u>	<u>4.08E-01</u>
4.	Tritium	<u>6.04E+00</u>	<u>2.03E+00</u>	<u>2.31E+00</u>	<u>4.14E+00</u>

*Include all nuclides even those with less than an eight day half-life.

**ND – Not Detected.

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
YEAR 2002
GASEOUS EFFLUENTS - MIXED MODE RELEASE*

<u>CURIES</u>	<u>Quarter</u> 1	<u>Quarter</u> 2	<u>Quarter</u> 3	<u>Quarter</u> 4
1. Fission Gases				
Kr-85m	ND**	ND	ND	ND
Kr-85	ND	ND	ND	ND
Kr-87	ND	ND	ND	ND
Kr-88	ND	ND	ND	ND
Xe-133	ND	ND	ND	3.86E-02
Xe-135m	ND	ND	ND	ND
Xe-135	ND	ND	ND	8.13E-03
Xe-138	ND	ND	ND	ND
Others(specify)	NONE			
<u>Total for Period</u>	ND	ND	ND	<u>4.68E-02</u>
2. Iodines				
I-131	1.91E-03	8.12E-02	3.04E-03	1.65E-01
I-133	4.29E-03	4.33E-03	4.53E-03	4.65E-02
I-135	1.02E-04	ND	ND	ND
<u>Total for Period</u>	<u>6.30E-03</u>	<u>8.55E-02</u>	<u>7.57E-03</u>	<u>2.11E-01</u>

*The Reactor Building and Radwaste Building are treated as split-level releases.

**ND – Not Detected

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
YEAR 2002
GASEOUS EFFLUENTS - MIXED MODE RELEASE*

<u>CURIES</u>	<u>Quarter</u> <u>1</u>	<u>Quarter</u> <u>2</u>	<u>Quarter</u> <u>3</u>	<u>Quarter</u> <u>4</u>
3. Particulates**				
Sr-89	7.82E-05	3.35E-05	3.29E-05	8.82E-05
Sr-90	ND***	ND	ND	ND
Cs-134	ND	1.12E-04	2.21E-04	4.60E-04
Cs-137	4.13E-06	1.70E-04	4.90E-04	7.90E-04
Ba-140	3.11E-04	7.85E-05	8.97E-05	2.54E-04
La-140	2.16E-04	1.14E-05	4.97E-05	7.87E-05
Others (specify)				
Na-24	2.06E-04	2.36E-03	2.89E-03	1.34E-03
Cr-51	2.08E-04	1.52E-04	ND	ND
Mn-54	6.68E-05	1.21E-04	1.18E-04	1.05E-04
Co-58	1.18E-05	4.15E-05	6.76E-05	2.53E-05
Fe-59	1.48E-05	2.65E-06	ND	ND
Co-60	9.00E-05	1.89E-04	1.12E-04	1.23E-04
Zn-65	ND	3.36E-05	5.40E-05	1.06E-04
Y-91m	2.93E-03	1.17E-03	2.50E-03	3.06E-03
Sr-91	2.96E-03	ND	2.53E-04	2.01E-03
Sr -92	2.47E-04	ND	ND	ND

*The Reactor Building and Radwaste Building are treated as split-level releases.

**Includes all nuclides, even those with less than an eight day half-life.

***ND – Not Detected.

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
YEAR 2002
GASEOUS EFFLUENTS - MIXED MODE RELEASE*

<u>CURIES</u>	<u>Quarter</u> <u>1</u>	<u>Quarter</u> <u>2</u>	<u>Quarter</u> <u>3</u>	<u>Quarter</u> <u>4</u>
Particulates** (Continued)				
Others (specify)				
Mo-99	5.53E-06	ND***	2.96E-05	3.01E-05
Tc-99m	5.40E-06	ND	2.89E-05	2.94E-05
Ag-110m	3.86E-05	2.00E-05	6.73E-05	1.33E-04
Cs-138	5.20E-03	ND	ND	2.26E-02
Ba-139	6.63E-02	2.50E-02	5.19E-03	8.51E-02
Au-199	ND	1.54E-06	ND	ND
Total for Period**	<u>7.90E-02</u>	<u>2.95E-02</u>	<u>1.22E-02</u>	<u>1.16E-01</u>
4. Tritium	<u>2.42E+01</u>	<u>1.02E+01</u>	<u>6.70E+00</u>	<u>5.78E+01</u>

*The Reactor Building and Radwaste Building are treated as split-level releases.

**Includes all nuclides, even those with less than an eight day half-life.

***ND – Not Detected.

**BROWNS FERRY NUCLEAR PLANT
ANNUAL EFFLUENT AND WASTE DISPOSAL REPORT
2002
SOLID WASTE AND IRRADIATED FUEL**

A. Solid Waste Shipped Off-site for Burial or Disposal (Not Irradiated Fuel)

1.	Type of Waste	Units	Amount	Error %
a.	Spent resins, filter sludge evaporator bottoms, etc.	m ³ Ci	0.00E+00 0.00E+00	
b.	Dry compressible waste, contaminated equipment, etc.	m ³ Ci	1.71E+02 6.47E+01	+/-25.0
c.	Irradiated components, control rod drives	m ³ Ci	0.00E+00 0.00E+00	
d.	Cartridge filters	m ³ Ci	0.00E+00 0.00E+00	

2. Estimate of Major Nuclide Composition by Waste Type

a.	Dry compressible waste, contaminated equipment, etc.	Nuclide	Percentage	Activity (Curies)
1.	Iron ⁵⁵	(1)	7.62E+01	4.98E+01
2.	Cobalt ⁶⁰	(1)	9.54E+00	6.17E+01
3.	Manganese ⁵⁴	(1)	7.10E+00	4.60E+00
4.	Silver ^{110m}	(1)	2.06E+00	1.34E+00
5.	Cesium ¹³⁷	(1)	1.24E+00	8.05E-01
6.	Chromium ⁵¹	(1)	9.76E-01	6.32E-01
7.	Iron ⁵⁹	(1)	8.85E-01	7.73E-01
8.	Zinc ⁶⁵	(1)	7.45E-01	4.82E-01
9.	Cesium ¹³⁴	(1)	3.91E-01	2.53E-01
10.	Cobalt ⁵⁸	(1)	3.27E-01	2.12E-01
11.	Nickel ⁶³	(1)	1.96E-01	1.27E-01
12.	Antimony ¹²⁴	(1)	1.19E-01	7.72E-02
13.	Antimony ¹²⁵	(1)	8.95E-02	5.79E-02
14.	Zirconium ⁹⁵	(1)	6.96E-02	4.51E-02
15.	Cerium ¹⁴⁴	(1)	3.98E-02	2.57E-02
16.	Strontium ⁸⁹	(1)	1.99E-02	1.29E-02
17.	Tin ¹¹³	(1)	9.95E-03	6.44E-03
18.	Strontium ⁹⁰	(1)	3.71E-05	2.40E-05
19.	Curium ^{243/244}	(1)	3.09E-06	2.00E-06

(1) Calculated

**BROWNS FERRY NUCLEAR PLANT
ANNUAL EFFLUENT AND WASTE DISPOSAL REPORT
2002
SOLID WASTE AND IRRADIATED FUEL**

3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
1	(1) Non Sole Use Truck	US Ecology Oak Ridge, TN
42	(24) Sole Use Truck (18) Non Sole Use Truck	Duratek Oak Ridge, TN
1	(1) Non Sole Use Truck	Tennessee Valley Authority Mixed Waste Storage Facility Muscle Shoals, AL

B. Irradiated Fuel Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
None	N/A	N/A

C. Description of Shipments

<u>Number of Shipments</u>	<u>Type Container</u>	<u>Type Quantity</u>	<u>Number of Containers</u>	<u>Container Volume</u>	<u>Waste Type</u>
44	Strong Tight Package	A-LSA II LTD QTY	52	See Note	DAW

Solidification Agents Used: None

Absorbents Used: None

NOTE: The 44 shipments of waste packaged in strong tight packages consisted of the following:

<u>Type of STC</u>	<u>Number of Packages</u>	<u>Volume of Packages (m³)</u>
40' "Sealand"	30	2.31E+03
20' "Sealand"	21	7.64E+02
55 Gal drum	1	2.12E-01

**BROWNS FERRY NUCLEAR PLANT
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
SUMMARY OF ABNORMAL/UNPLANNED RELEASES
2002**

The release of radioactive material to the environment from Browns Ferry has been a small fraction of the 10 CFR 20 Appendix B and 10 CFR 50 Appendix I limits. There were no limits exceeded as specified in 10 CFR 20 Appendix B and 10 CFR 50 Appendix I.

No abnormal gaseous or liquid releases occurred in 2002.

During the reporting period, January 1 through December 31, 2002, there was no missed compensatory measures.

In calendar year 2002 Browns Ferry had no changes to the radwaste system or the Process Control Program (PCP).

ENCLOSURE 4

**TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT (BFN)
UNITS 1, 2, AND 3**

**INOPERABLE RADIOLOGICAL EFFLUENT INSTRUMENTATION REPORT
JANUARY THROUGH DECEMBER 2002**

INOPERABLE RADIOLOGICAL EFFLUENT INSTRUMENTATION REPORT 2002

This report is to comply with Browns Ferry Nuclear Plant Offsite Dose Calculation Manual (Offsite Dose Calculation Manual (ODCM)) Sections 1/2.1.1 and 1/2.1.2. The ODCM requires the exertion of best efforts to return inoperable instruments to operable status within 30 days. Failure to return such instruments to an operable status within the prescribed interval requires a description in the Annual Radioactive Effluent Release Report.

During the reporting period, January 1 through December 31, 2002, there were no radioactive gaseous effluent monitoring instrumentation out of service for greater than 30 days; however, one liquid effluent monitor was out of service for greater than 30 days. The Unit 1 RHR service water monitor (1-RM-90-134) was considered inoperable between the times of December 08, 2001, at 0045 hours through January 7, 2002 at 1207 hours. The monitor had tripped due to low flow conditions. Work Orders were initiated in a timely manner and work packages were planned for implementation based on a priority status of not exceeding 21 days. Initial troubleshooting of the flow problem was completed on 12-29-2001 and had resolved the flow problem. However, during post maintenance testing activities, it was determined that a wiring error existed with a hand-switch in the pump start logic. A second work order was prepared to troubleshoot the wiring problem and was successfully completed on 01-07-2003. The monitor was then returned to service having exceeded 30 days by a few hours.

Some effluent monitors and flow instrumentation were placed in "out-of-service" status because these monitors' effluent streams were isolated. Therefore, these monitors are not included in this report.