

Challenges Encountered With Elevated Tritium Values



Perry Power Plant

Ω GE BWR 6

Ω 3758 MWt

Ω Rated Power 1306 MWe


Sources of Tritium

- ↳ **Activation of deuterium**
- ↳ **Directly from the fuel if a defect is present**
- ↳ **From control rod blade leakage**
- ↳ **In-adequate processing of Standby Liquid Control (SLC) waste in radwaste**


Tritium Concentration Changes During Cycle

- Historically tritium would build to an equilibrium value based on production rate from deuterium and the losses from steam cycle
- During Cycle 9, increases in control rod blade leakage and two small fuel defects contributed to an increase beyond equilibrium point


Tritium Trend for Cycle 8



Tritium Trend for Cycle 9



Reactor Water Boron Trend





Problems Encountered with Elevated Tritium

Tritium Detected in Turbine Building Supply Plenum Drains

- ⌚ **Influent air to Turbine Building is cooled with chilled water**
- ⌚ **Condensate from the cooling coils is directed to storm drains**
- ⌚ **Tritium was detected in drains at a level of 2.20E-06 uCi/ml.**
- ⌚ **Investigation determined that exhaust from plant vents was recycled back into the turbine building supply plenum**

Elevated Tritium Caused a Reduction in Radwaste Discharge Flow

∞ In order to ensure compliance with effluent concentration limits a reduction in radwaste discharge flow was necessary

∞
$$F_{\max} = \frac{0.64}{10 \left(\sum C_i / EC_i \right)}$$

- 0.64 Engineering factor to prevent spurious alarms
- C_i Concentration of radionuclide
- EC_i Effluent concentration of radionuclide

Elevated Tritium Caused a Reduction in Radwaste Discharge Flow (cont)

- ❧ **With a tritium value of 2.62 E-2 uci/ml and a Dilution Flow of 20,000 gpm this would calculate to a maximum discharge flow (Fmax) of 49 gpm. Discharge Duration at this flow rate is 12 hours.**
- ❧ **Tritium would have to decrease to 8.0 E-3 uci/ml to allow for a discharge at the maximum possible discharge flow of 160 gpm. Discharge duration at this flow rate is 3.6 hours.**

Elevated Tritium Caused a Reduction in Radwaste Discharge Flow (cont)

- ⌚ **Outage Water Management Plan required 210,000 gallons of water to be discharged in less than 3 days**
- ⌚ **At a discharge flow rate of 49 gpm it would take over 3 days to release this volume**
- ⌚ **Pre-outage discharges were performed to decrease tritium to allow for discharge at a higher flow rate during outage**

Controls for Tritium Established

- ❧ Concentration limits placed on condensate
- ❧ Discharges were performed prior to outage to reduce tritium
- ❧ 50.59 review was performed for the release of tritium to the storm drains
- ❧ Improved monitoring techniques for control rod blade leakage
- ❧ Composite Plans were written for outage